



LEGEND		ELECTRICAL NOTES :	
— 10 ECC — 10 ECC — 10 ECC —	PROPOSED 10mm ² 4 CORE ECC PVC SWA CABLE, TO BE INSTALLED INTO THE EXISTING PIPE AND CHAMBER.	1.	THIS DRAWING FOR ELECTRICAL LIGHTING & POWER ONLY.
		2.	A CERTIFICATE OF COMPLIANCE TO BE COMPLETED AND SUBMITTED BY THE CONTRACTOR ON COMPLETION OF WORK.
		3.	ALL WORK MUST COMPLY WITH THE GENERAL REQUIREMENTS OF SANS 10142-1 (as amended). THE CONTRACTOR AND PANEL MANUFACTURER IS REFERRED SPECIFICALLY TO CLAUSE 6.8.6.2/6.3/6.6.4 AND 6.6.5.
		4.	ALL ALTERNATIVES (OR SIMILAR) OF LIGHTING AND FIXTURES TO BE ACCEPTED BY ELECTRICAL ENGINEER PRIOR TO ORDERING.

NOTES	
1. DO NOT SCALE DRAWING - ONLY DIMENSIONS SHOWN TO BE USED.	
2. THE CONTRACTOR SHALL VERIFY ALL CONDITIONS, DIMENSIONS AND LEVELS ON THE SITE AND NOTIFY THE MEC SUPERVISOR OF ANY VARIATIONS BEFORE CONSTRUCTION.	

REFERENCE DRAWINGS	
2128313-1-000-E-LA-0001-02	ALTERATIONS OF THE EXISTING KIOSK SINGLE LINE LAYOUT REFERENCE

REVISIONS			
NO.	DESCRIPTION	BY	CHKD/APPD/DATE
01	ISSUED FOR TENDER	PM/AM/SS	17/04/2024

CONTRACTOR / CONSULTANT				TRANSET NATIONAL PORTS AUTHORITY			
TITLE	NAME	SIGN	DATE	TITLE	NAME	SIGN	DATE
				DRAWN	PM	[Signature]	25/06/22
				CHECKED	AM	[Signature]	25/06/22
				DESIGNED	PM	[Signature]	25/06/22
				CHECKED	SM	[Signature]	25/06/22
OPERATING DIVISIONS				PR.ENG. / PR.TECH./PR. ARCH			
TITLE	NAME	SIGN	DATE	NAME	S. SEWDAYAL	DATE	17/04/24
				SIGNATURE	[Signature]	DATE	20/07/23
				REG. NUMBER	200910129	SCALE:	AS SHOWN

Transnet National Ports Authority

QUEENS WAREHOUSE
237 MAHATMA GANDHI ROAD
DURBAN
TEL: 031 961 1996
P.O. BOX 1073, DURBAN
FAX: 0866 770815

PORT OF DURBAN

DURBAN HARBOUR ENTRANCE
NORTH GROUYNE PROMENADE TERRACING
AND CAR PARK UPGRADE

PROPOSED WALL LIGHTING LAYOUT

PROJECT NUMBER: 00104811000
DSD: [] F88: [] D88: [] TYPE: [] DRAWING NO: [] SHEET: [] REV: []

Copyright and all other rights are reserved by Transnet. This Document may only be used for its intended purpose.