



PROPOSED NORTH GROYNE LIGHTING LAYOUT (Sheet 18)
SCALE 1: 50



PROPOSED NORTH GROYNE LIGHTING LAYOUT (Sheet 19)
SCALE 1: 50



| LEGEND | |
|--------|--|
| | PROPOSED EQUAL OR SIMILAR APPROVED TO SERIES 52 BULKHEAD LED LIGHT FITTING WITH VANDAL PROOF TOUGHENED GLASS, IP65, CABLE ENTRY AT THE BACK (16W OPAQUE, 2190 LUMENS SURFACE MOUNTED LIGHT FITTING), TO BE MOUNTED INTO THE EXISTING WATER BREAK WALL. |
| | (360mm X 260mm) 316 STAINLESS STEEL BRUSHED PLATE 2mm THICK WITH A HOLE IN A CENTRE FOR ALLOWING CABLE ENTRY OF 25mm Dia. |
| | PROPOSED 4mm², 4 CORE ECC PVC SWA CABLE, TO BE INSTALLED INTO THE EXISTING PIPE AND CHAMBER. |

- ELECTRICAL NOTES :**
- THIS DRAWING FOR ELECTRICAL LIGHTING & POWER ONLY.
 - A CERTIFICATE OF COMPLIANCE TO BE COMPLETED AND SUBMITTED BY THE CONTRACTOR ON COMPLETION OF WORK.
 - ALL WORK MUST COMPLY WITH THE GENERAL REQUIREMENTS OF SANS 10142-1 (as amended). THE CONTRACTOR AND PANEL MANUFACTURER IS REFERRED SPECIFICALLY TO CLAUSE 6.6/6.6.2/6.6.3/6.6.4 AND 6.6.5.
 - ALL ALTERNATIVES (OR SIMILAR) OF LIGHTING AND FIXTURES TO BE ACCEPTED BY ELECTRICAL ENGINEER PRIOR TO ORDERING.

| NOTES | |
|---|--|
| 1. DO NOT SCALE DRAWING - ONLY DIMENSIONS SHOWN TO BE USED. | |
| 2. THE CONTRACTOR SHALL VERIFY ALL CONDITIONS, DIMENSIONS AND LEVELS ON THE SITE AND NOTIFY THE NEC SUPERVISOR OF ANY VARIATIONS BEFORE CONSTRUCTION. | |

| REVISIONS | | | | | |
|-----------|-------------------|----|------|------|------------|
| NO. | DESCRIPTION | BY | CHKD | APPD | DATE |
| 0A | ISSUED FOR TENDER | PM | AM | SS | 17-04-2024 |

| CONTRACTOR / CONSULTANT | | | | TRANSNET NATIONAL PORTS AUTHORITY | | | |
|-------------------------|------|------|------|-----------------------------------|------|------|----------|
| TITLE | NAME | SIGN | DATE | TITLE | NAME | SIGN | DATE |
| | | | | DRAWN | PM | | 26 06 22 |
| | | | | CHECKED | AM | | 26 06 22 |
| | | | | DESIGNED | PM | | 26 06 22 |
| | | | | CHECKED | SM | | 26 06 22 |

| OPERATING DIVISIONS | | | | PR.ENG. / PR.TECH./PR. ARCH | | | |
|---------------------|------|------|------|-----------------------------|--------------|------|----------|
| TITLE | NAME | SIGN | DATE | TITLE | NAME | SIGN | DATE |
| | | | | NAME | S. SEVUDAYAL | | |
| | | | | SIGNATURE | | | 17 04 24 |
| | | | | REG. NUMBER | 200970129 | | |
| | | | | SCALE : | AS SHOWN | | |

Transnet National Ports Authority
 QUEENS WAREHOUSE
 237 MAHATMA GANDHI ROAD
 DURBAN
 P.O. BOX 1073, DURBAN
 TEL: 031 361 1696
 FAX: 0866 770815

TRANSNET

PORT OF DURBAN
 DURBAN HARBOUR ENTRANCE
 NORTH GROYNE PROMENADE TERRACING
 AND CAR PARK UPGRADE

PROPOSED WALL LIGHTING LAYOUT

| | | | | | | | | |
|----------------|----|-----|-----|------|-------------|-------|-----|-------|
| PROJECT NUMBER | OD | FBS | DIS | TYPE | DRAWING NO. | SHEET | REV | ID |
| XDN048 | 1 | 0 | 0 | E | LA | 0002 | 06 | 0A TD |