



LEGEND

— 10 ECC — 10 ECC — 10 ECC —
 PROPOSED 10mm², 4 CORE ECC PVC SWA CABLE, TO BE INSTALLED INTO THE NEW 110mm PVC SLEEVES AND INTO THE EXISTING PIPE AND CHAMBER.

 EXISTING LOW VOLTAGE KIOSK

ELECTRICAL NOTES :

- THIS DRAWING FOR ELECTRICAL LIGHTING & POWER ONLY.
- A CERTIFICATE OF COMPLIANCE TO BE COMPLETED AND SUBMITTED BY THE CONTRACTOR ON COMPLETION OF WORK.
- ALL WORK MUST COMPLY WITH THE GENERAL REQUIREMENTS OF SANS 10142-1 (as amended). THE CONTRACTOR AND PANEL MANUFACTURER IS REFERRED SPECIFICALLY TO CLAUSE 6.6.6.2.6.6.3.6.4 AND 6.6.5.
- ALL ALTERNATIVES (OR SIMILAR) OF LIGHTING AND FIXTURES TO BE ACCEPTED BY ELECTRICAL ENGINEER PRIOR TO ORDERING.



PROPOSED NORTH GROYNE LIGHTING LAYOUT (Sheet 1)
 SCALE 1:50

REFERENCE DRAWINGS	
DRAWING NO.	REFERENCE
212813-1-000 E-LA-0001-02	ALTERATIONS OF THE EXISTING KIOSK SINGLE LINE LAYOUT

NOTES

- DO NOT SCALE DRAWING - ONLY DIMENSIONS SHOWN TO BE USED.
- THE CONTRACTOR SHALL VERIFY ALL CONDITIONS, DIMENSIONS AND LEVELS ON THE SITE AND NOTIFY THE NEC SUPERVISOR OF ANY VARIATIONS BEFORE CONSTRUCTION.

ISSUED FOR TENDER		BY		DATE	
NO.	DESCRIPTION	CHKD	APPD	DATE	
01	ISSUED FOR TENDER	PM	AM	SS	17-04-2024

CONTRACTOR / CONSULTANT				TRANSNET NATIONAL PORTS AUTHORITY			
TITLE	NAME	SIGN	DATE	TITLE	NAME	SIGN	DATE
				DRAWN	PM		26 06 22
				CHECKED	AM		26 06 22
				DESIGNED	PM		26 06 22
				CHECKED	SM		26 06 22

Transnet National Ports Authority

TRANSNET

QUEENS WAREHOUSE
 217 MAHATMA GANDHI ROAD
 DURBAN
 P.O. BOX 1073, DURBAN

TEL: 031 961 1696
 FAX: 0866 770815

PORT OF DURBAN

DURBAN HARBOUR ENTRANCE
 NORTH GROYNE PROMENADE
 TERRACING UPGRADE

PROPOSED WALL LIGHTING LAYOUT

PROJECT NUMBER: 048-1-00-0-E-LA-0002-01-OA TD