


Type. i Crealco Swift 38 or eq. approved top hung aluminium casement window, per layout. Casement sash 1500 x 1200mm max capacity
 Fixing lugs suitable for fixing to plastered brickwork reveals. Mullions in 100mm depth section, code W54454 with Lx 71.5
 Exposure AAAMSA exposure category: A3. SANS613 - 2000Pa wind load capacity
 Coating: Class 2 powder coated to SANS 10322:2014; Coatings in accordance with SANS 1796 using powders in accordance with SANS 1578.
 colour: TBC. Provisionally Mat Black
 Furniture 500mm Stays, 13mm stack, capacity 28Kg. Crealco code STF-TH600S-304 or equal app
 Handles - Per manufacturers specification to suite operation indicated.
 Glazing Glazing throughout to be 12mm thick toughened safety glass , per PFG Armourplate.
 SHGC Req. 0.7
 U-Value Req. 5.8 W/m².K (system)
 Mesh security screen: Per Trellidor Clearguard casement window, consisting of: 89x23 box section outer frame .
 s/steel woven mesh screen in 42x33 casement framing . Finish- Powder coated of colour to match window frame.
 Locking with cylinder deadlatch and escutcheon, at max 600mm cc. 100mm sinkless S/steel hinges.
 Blinds / Curtains: Vertical Louvre blinds, polycotton drape, 127mm width vanes, cord operable. 45x25 Aluminium head rail, per Hospitrack, Hospi-Lux

QUANTITY:	Incl Security Mesh
2	WG18 WG40

NOTES:	REVISIONS			
	Rev.	Date	Description	By
	A	2024.08.06	Window & description updated.	PD

PROJECT: PORT SHEPSTONE HOSPITAL NEW PSYCHIATRIC WARD	Architect: ARTEK 4 ARCHITECTS (KZN) CC Durban: 46 Lena Ahrens Road, Glenwood, Durban 4000 tel: 031 201 0445 fax: 031 201 6609 email: admin@artek4.co.za Port Shepstone: 19 Tradewinds, Marine Drive, Shelly Beach tel: 039 682 2447 fax: 039 682 2446 email: adminps@artek4.co.za	
DRAWING DESCRIPTION: WINDOW SCHEDULE WINDOW TYPE I		

Scale	Date	Drawn	Project No.	Drawing No.	Rev.
1:25	14.11.2022	WP	1518	401-9A	A