

Technical Evaluation **Three Phase Variac**. Data sheet to be provided **(If no data sheet is supplied or scoring below 85 points will be regarded as technically non-compliant)**

Nr	Criteria	Weighting (%)	Returnable with the RFQ/Tender Yes / No / Partial compliance	Returnable Datasheet to be provided (Yes/No)	Score
1	Rated Power: 500VA-100KVA	20	Yes – 20 Partial – 10 No - 0		
2	Input Voltage Three Phase: 380VAC	15	Yes – 15 Partial –10 No - 0		
3	Output Voltage Three Phase: 0-430VAC Adjustable	15	Yes – 15 Partial –10 No - 0		
4	Control Method: Manual	10	Yes – 10 Partial –5 No - 0		
5	Frequency: 50Hz±5%,	10	Yes – 10 Partial – 5 No - 0		
6	Efficiency: ≥98%,	10	Yes – 10 Partial – 5 No - 0		
7	Waveform Distortion: Nil	10	Yes – 10 Partial –5 No - 0		
8	Display: Analog or Digital Voltmeter	10	Yes – 10 Partial –5 No - 0		
	Total Score	100			
	Threshold	85			