



GENERAL NOTES

1. ALL DIMENSIONS ARE IN MILLIMETERS.
2. ALL WELDS TO BE CLEANED AND APPROVED PRIMER APPLIED THEN PAINTED TO FULL OUTDOOR SPECIFICATION.
3. ALL UNUSED CABLE ENTRIES TO BE PLUGGED.
4. LIGHTING POLE AND ACCESSORIES TO BE HOT DIP GALVANISED TO SANS 121
5. LUMINAIRE IS A STANDARD FITTING IN HAZARDOUS AREA USE FLAME PROOF JUNCTION BOX, SUITABLE FOR ZONE I AND ZONE II.
6. LUMINAIRE TO BE SUITABLY INSULATED FROM LIGHT POLE.

ITEM #	QTY	MATERIAL SUPPLIED	DESCRIPTION
1	1	PURCHASE	SUITABLE POLE MOUNT LUMINAIRE
2	2	FREE ISSUE	INSULATING MATERIAL
3	1	FREE ISSUE	SUITABLE POLE MOUNTING BRACKET
4	1	PURCHASE	SUITABLE BOLT AND NUT
5	1	FREE ISSUE	GROMMET
6	1	FREE ISSUE	EXTENSION TO ALL LIGHT POLES

PROPOSAL

TRANSNET
pipelines
TYPICAL ZONE 1 LAMP
(LAMP POLE EXTENSION)

REVISIONS			
PROJECT NAME			
DRAWN	W.D	REF.	
TRACED	CAD	DATE	25/05/2021
CHECKED	K.N	APPROVED	
SCALE	N.T.S		
DRAWING No.	PL -121591		REV