

OFFICE OF THE SUPPLY CHAIN MANAGEMENT

1.1 DESCRIPTION OF SERVICE: Supply, deliver and install a Submersible Sewage Pump or Equivalent to the old pump for Bien Donn  Research Farm

BACKGROUND: The main sewage pump at Bien Donn  Research farm is defective and too old to be repaired. The whole sewage system is currently on the back-up pump. If this pump breaks, then the whole system is down and cannot operate. It is crucial infrastructure that have to be replaced.

PURPOSE: The sewage pump is the main part of the sewage system. The sewage system cannot operate without a pump.

SCOPE OF WORK: If the sewage pump is not replaced the sewage system cannot operate and pump the sewage away.

SPECIFICATION	Comply with specification. Please indicate (Yes or No)		
	Yes	No	If no, indicate deviation
1. 3.7KW Submersible Sewage Pump or Equivalent to old pump (see pictures) Specifications: - Flow 72m3/h - Head 6m	Yes		
 	3.7KW Submersible Sewage Pump or Equivalent to old pump Old pump model information		
GENERAL CONDITIONS FOR THE PURCHASE ORDER AGREEMENT			

1. Site inspection compulsory			
2. Supply, deliver and install the pump			
3. A guarantee/warranty should be supplied			

1.2 PRICING SCHEDULE

Item description	QTY	Unit price	Total Price
3.7KW Submersible Sewage Pump or Equivalent to old pump	1		
Other: Supply, delivery and installation	1		
SUBTOTAL			
VAT			
GRANDTOTAL			

1. The specification prepared by

Name ...Carmen Samuels.....

Date...20/10/2022...

Signature...



.....

2. The specification approved by commodity specialist

Name Salomie Willemse.....

Date 20/10/2022.....