


WINDOW TYPE	C - Security mesh
QUANTITY	Refer Type C quantity
MESH	Powder coated aluminium casement window with fixed glazing and top hung opening sections
QUANTITY:	Refer Type C locations
37	

Type, C Crealco Swift 38 or eq. approved top hung aluminium casement window, per layout. Casement sash 1500 x 1200mm max capacity
Exposure Fixing lugs suitable for fixing to plastered brickwork reveals. Fixed Y- louvre vent panel over casement. Louvres at 30mm cc.
Coating: AAAMSA exposure category: A1. SANS613 - 1500Pa wind load capacity
colour: Class 2 powder coated to SANS 10322:2014; Coatings in accordance with SANS 1796 using powders in accordance with SANS 1578.
Furniture TBC. Provisionally Mat Black
 500mm Stays, 13mm stack, capacity 28Kg. Crealco code STF-TH600S-304 or equal app
 Handles - Per manufacturers specification to suite operation indicated.
Glazing Glazing throughout to be 6,38mm thick normal strength PVB laminated Low E safety glass
 SHGC Req. 0.57 per PG Glass E-Range Solarvue Neutral SHG (or equal approved)
 U-Value Req. 5.8 W/m².K (system) Glazing - 3.7 W/m².K
Mesh security screen: Per Trellidor Clearguard casement window, consisting of: 89x23 box section outer frame .
 s/steel woven mesh screen in 42x33 casement framing . Finish- Powder coated of colour to match window frame.
 Locking with cylinder deadlatch and escutcheon, at max 600mm cc. 100mm sinkless S/steel hinges.
Blinds / Curtains:
 Vertical Louvre blinds, polycotton drape, 127mm width vanes, cord operable. 45x25 Aluminium head rail, per Hospitrack, Hospi-Lux

QUANTITY:	10 x No Blinds+Mesh	1x Incl Blinds+Mesh	26 x Incl Security Mesh
37	WB2 WF3 WF32 WF41 WF1 WF4 WF33 WF2 WF5 WF40	WG9	WG1 WG4 WG7 WG32 WG68 WG71 WG76 WG79 WG82 WG85 WG2 WG5 WG8 WG38 WG69 WG72 WG77 WG80 WG83 WG86 WG3 WG6 WG28 WG67 WG70 WG75 WG78 WG81 WG84

NOTES:	Rev.	Date	REVISIONS	By
1. ALL DIMENSIONS TO BE CHECKED ON SITE PRIOR TO MANUFACTURE.	A	2024.08.06	Description	PD
2. WINDOWS DRAWN AS VIEW FROM EXTERIOR.			Window & description updated.	

PROJECT: PORT SHEPSTONE HOSPITAL NEW PSYCHIATRIC WARD	Architect: ARTEK 4 ARCHITECTS (KZN) CC Durban: 46 Lena Ahrens Road, Glenwood, Durban 4000 tel: 031 201 0445 fax: 031 201 6609 email: admin@artek4.co.za Port Shepstone: 19 Tradewinds, Marine Drive, Shelly Beach tel: 039 682 2447 fax: 039 682 2446 email: adminps@artek4.co.za	
DRAWING DESCRIPTION: WINDOW SCHEDULE WINDOW TYPE C		

Scale	Date	Drawn	Project No.	Drawing No.	Rev.
1:25	14.11.2022	WP	1518	401-3	A