



NEC3 Supply Contract (SC3)

Between **ESKOM HOLDINGS SOC Ltd**
(Reg No. 2002/015527/30)

and **[Insert at award stage]**
(Reg No. _____)

for **Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years**

Contents:	No of pages
Part C1 Agreements & Contract Data	17
Part C2 Pricing Data	05
Part C3 Scope of Work	12

CONTRACT No. [Insert at award stage]

PART C1: AGREEMENTS & CONTRACT DATA

Contents:	No of pages
C1.1 Form of Offer and Acceptance	03
C1.2a Contract Data provided by the <i>Purchaser</i>	12
C1.2b Contract Data provided by the <i>Supplier</i>	02
C1.3 Proforma Guarantees	[N/A]

C1.1 Form of Offer & Acceptance

Offer

The Purchaser, identified in the Acceptance signature block, has solicited offers to enter into a contract for the procurement of:

Kriel Power Station Lighting and Small Power Installation for Once Off basis

The tenderer, identified in the Offer signature block, has

<i>either</i>	examined the documents listed in the Tender Data and addenda thereto as listed in the Returnable Schedules, and by submitting this Offer has accepted the Conditions of Tender.
<i>or</i>	examined the draft contract as listed in the Acceptance section and agreed to provide this Offer.

By the representative of the tenderer, deemed to be duly authorised, signing this part of this Form of Offer and Acceptance the tenderer offers to perform all of the obligations and liabilities of the *Supplier* under the contract including compliance with all its terms and conditions according to their true intent and meaning for an amount to be determined in accordance with the *conditions of contract* identified in the Contract Data.

	The offered total of the Prices exclusive of VAT is	R
	Value Added Tax @ 15% is	R
	The offered total of the amount due inclusive of VAT is ¹	R
	(in words)	

This Offer may be accepted by the Purchaser by signing the Acceptance part of this Form of Offer and Acceptance and returning one copy of this document including the Schedule of Deviations (if any) to the tenderer before the end of the period of validity stated in the Tender Data, or other period as agreed, whereupon the tenderer becomes the party named as the *Supplier* in the *conditions of contract* identified in the Contract Data.

Signature(s)

Name(s) _____

Capacity _____

For the tenderer:

(Insert name and address of organisation)

Name & signature of witness

Date

¹ This total is required by the *Purchaser* for budgeting purposes only. Actual amounts due will be assessed in terms of the *conditions of contract*.

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Acceptance

By signing this part of this Form of Offer and Acceptance, the Purchaser identified below accepts the tenderer’s Offer. In consideration thereof, the Purchaser shall pay the Supplier the amount due in accordance with the *conditions of contract* identified in the Contract Data. Acceptance of the tenderer’s Offer shall form an agreement between the Purchaser and the tenderer upon the terms and conditions contained in this agreement and in the contract that is the subject of this agreement.

The terms of the contract, are contained in:

- Part C1 Agreements and Contract Data, (which includes this Form of Offer and Acceptance)
- Part C2 Pricing Data
- Part C3 Scope of Work: Goods Information including Supply Requirements

and drawings and documents (or parts thereof), which may be incorporated by reference into the above listed Parts.

Deviations from and amendments to the documents listed in the Tender Data and any addenda thereto listed in the Returnable Schedules as well as any changes to the terms of the Offer agreed by the tenderer and the Purchaser during this process of offer and acceptance, are contained in the Schedule of Deviations attached to and forming part of this Form of Offer and Acceptance. No amendments to or deviations from said documents are valid unless contained in this Schedule.

The tenderer shall within two weeks of receiving a completed copy of this agreement, including the Schedule of Deviations (if any), contact the Purchaser’s agent (whose details are given in the Contract Data) to arrange the delivery of any securities, bonds, guarantees, proof of insurance and any other documentation to be provided in terms of the *conditions of contract* identified in the Contract Data at, or just after, the date this agreement comes into effect. Failure to fulfil any of these obligations in accordance with those terms shall constitute a repudiation of this agreement.

Notwithstanding anything contained herein, this agreement comes into effect on the date when the tenderer receives one fully completed and signed original copy of this document, including the Schedule of Deviations (if any).

Signature(s)

Name(s)

Capacity

**for the
Purchaser**

**Eskom Holdings SOC Ltd, Megawatt Park, Maxwell Drive, Sandton, Johannesburg,
2199**

(Insert name and address of organisation)

Name &
signature of
witness

Date

Note: If a tenderer wishes to submit alternative tenders, use another copy of this Form of Offer and Acceptance.

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Schedule of Deviations to be completed by the *Purchaser* prior to contract award

Note:

1. This part of the Offer & Acceptance would not be required if the contract has been developed by negotiation between the Parties and is not the result of a process of competitive tendering.
2. The extent of deviations from the tender documents issued by the Purchaser prior to the tender closing date is limited to those permitted in terms of the Conditions of Tender.
3. A tenderer's covering letter must not be included in the final contract document. Should any matter in such letter, which constitutes a deviation as aforesaid be the subject of agreement reached during the process of Offer and Acceptance, the outcome of such agreement shall be recorded here and the final draft of the contract documents shall be revised to incorporate the effect of it.

No.	Subject	Details
1	[•]	[•]
2	[•]	[•]
3	[•]	[•]
4	[•]	[•]
5	[•]	[•]
6	[•]	[•]
7	[•]	[•]

By the duly authorised representatives signing this Schedule of Deviations below, the Purchaser and the tenderer agree to and accept this Schedule of Deviations as the only deviations from and amendments to the documents listed in the Tender Data and any addenda thereto listed in the Tender Schedules, as well as any confirmation, clarification or changes to the terms of the Offer agreed by the tenderer and the Purchaser during this process of Offer and Acceptance.

It is expressly agreed that no other matter whether in writing, oral communication or implied during the period between the issue of the tender documents and the receipt by the tenderer of a completed signed copy of this Form shall have any meaning or effect in the contract between the parties arising from this Agreement.

For the tenderer:

For the Purchaser

Signature _____

Name _____

Capacity _____

On behalf of *(Insert name and address of organisation)* _____

Eskom Holdings SOC Ltd, Megawatt Park, Maxwell Drive, Sandton, Johannesburg, 2199

Name & signature of witness _____

Date _____

C1.2 SC3 Contract Data

Part one - Data provided by the *Purchaser*

Clause	Statement	Data
1	General	
	The <i>conditions of contract</i> are the core clauses and the clauses for Options	
		X1: Price adjustment for inflation
		X2: Changes in the law
		X7: Delay damages
		X17: Low performance damages
		Z: Additional conditions of contract
	of the NEC3 Supply Contract (April 2013) ¹	(If the December 2009 edition is to be used delete April 2013 and replace by December 2013)
10.1	The <i>Purchaser</i> is (name):	Eskom Holdings SOC Ltd (reg no: 2002/015527/30), a state owned company incorporated in terms of the company laws of the Republic of South Africa
	Address	Registered office at Megawatt Park, Maxwell Drive, Sandton, Johannesburg
	Tel No.	+27 11 871 3706
	Fax No.	N/A
10.1	The <i>Supply Manager</i> is (name):	Samuel Mophuting
	Address	Kriel Power Station
	Tel	014 763 8446
	Fax	N/A
	e-mail	MophutSP@Eskom.co.za
11.2(13)	The <i>goods</i> are	Circuit Breakers
11.2(13)	The <i>services</i> are	Circuit Breakers
11.2(14)	The following matters will be included in the Risk Register	<ul style="list-style-type: none"> - Any matter that has cost implication outside the agreed terms - Any matter that may cause delay in the delivery - Any quality related issues - Any matter that deviates from the

¹ Available from Engineering Contract Strategies Tel 011 803 3008 Fax 086 539 1902, www.ecs.co.za.

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

		specification				
		- Any access issue due to force majeure such as protests, covid restrictions etc				
11.2(15)	The Goods Information is in	Part 3: Scope of Work and all documents and drawings to which it makes reference.				
11.2(15)	The Supply Requirements as part of the Goods Information is in	Annexure A to this Contract Data				
12.2	The <i>law of the contract</i> is the law of	the Republic of South Africa				
13.1	The <i>language of this contract</i> is	English				
13.3	The <i>period for reply</i> is	One (1) weeks				
2	The <i>Supplier's</i> main responsibilities	Data required by this section of the core clauses is provided by the <i>Supplier</i> in Part 2 and terms in italics used in this section are identified elsewhere in this Contract Data.				
3	Time					
30.1	The <i>starting date</i> is.	Contract signature date				
30.1	The <i>delivery date</i> of the <i>goods and services</i> is:	<table border="1"> <thead> <tr> <th><i>goods and services</i></th> <th><i>delivery date</i></th> </tr> </thead> <tbody> <tr> <td>1 Circuit Breakers</td> <td>As per lead time</td> </tr> </tbody> </table>	<i>goods and services</i>	<i>delivery date</i>	1 Circuit Breakers	As per lead time
<i>goods and services</i>	<i>delivery date</i>					
1 Circuit Breakers	As per lead time					
30.2	The <i>Supplier</i> does not bring the <i>goods</i> to the Delivery Place more than one week before the Delivery Date.	[no data required]				
31.1	The <i>Supplier</i> is to submit a first programme for acceptance within	2 days after each Purchase order issuance and in line with agreed delivery lead time per spare				
32.2	The <i>Supplier</i> submits revised programmes at intervals no longer than	2 days after each change from initial programme				
4	Testing and defects					
42	The <i>defects date</i> is	1 weeks after Delivery.				
43.2	The <i>defect correction period</i> is	1 weeks				
	except that the <i>defect correction period</i> for	Purchasers fault is 1 week- (the Supplier does not start correcting the defect until the compensation event is agreed between Parties if the defect is as a result of the Purchaser's fault)				
	and the <i>defect correction period</i> for	Not Applicable				
42.2	The <i>defects access period</i> is	1 day after notification				
	except that the <i>defect access period</i> for	Purchaser's fault is 2 days- (the Supplier does not start correcting the defect until the compensation event is agreed between Parties if the defect is as a result of the Purchaser's fault)				
	and the <i>defect access period</i> for	Not Applicable				

5	Payment	
50.1	The <i>assessment interval</i> is	14 days after delivery took place
51.1	The <i>currency of this contract</i> is the	South African Rand
51.2	The period within which payments are made is	60 Days.
51.4	The <i>interest rate</i> is	<p>the publicly quoted prime rate of interest (calculated on a 365 day year) charged from time to time by the Standard Bank of South Africa Limited (as certified, in the event of any dispute, by any manager of such bank, whose appointment it shall not be necessary to prove) for amounts due in Rands and</p> <p>(ii) the LIBOR rate applicable at the time for amounts due in other currencies. LIBOR is the 6 month London Interbank Offered Rate quoted under the caption “Money Rates” in The Wall Street Journal for the applicable currency or if no rate is quoted for the currency in question then the rate for United States Dollars, and if no such rate appears in The Wall Street Journal then the rate as quoted by the Reuters Monitor Money Rates Service (or such service as may replace the Reuters Monitor Money Rates Service) on the due date for the payment in question, adjusted <i>mutatis mutandis</i> every 6 months thereafter and as certified, in the event of any dispute, by any manager employed in the foreign exchange department of The Standard Bank of South Africa Limited, whose appointment it shall not be necessary to prove.</p>
6	Compensation events	There is no reference to Contract Data in this section of the core clauses and terms in italics used in this section are identified elsewhere in this Contract Data.
7	Title	There is no reference to Contract Data in this section of the core clauses and terms in italics used in this section are identified elsewhere in this Contract Data.
8	Risks, liabilities, indemnities and insurance	
80.1	These are additional <i>Purchaser’s</i> risks	<ol style="list-style-type: none"> 1. Supplier not supplying goods on time can result in extended meantime to repair or plant shut down 2. Supplier not meeting quality requirements can result in financial and production loss 3. Rigging/ lifting equipment and resources unavailability for offloading at Stores 4. Invalid safety file/ un-updated each time the supplier uses different drivers for offloading- also forgetting yearly file auditing 5. Incorrect design and Specifications used can

		result in production losses/ financial loss/PFMA violation and Outage slip or extended meantime to repair
88.1	The <i>Supplier's</i> liability to the <i>Purchaser</i> for indirect or consequential loss, including loss of profit, revenue and goodwill is limited to	R0.0 (zero Rand)
88.2	For any one event, the <i>Supplier's</i> liability to the <i>Purchaser</i> for loss of or damage to the <i>Purchaser's</i> property is limited to	(1) for the <i>Purchaser's</i> existing and surrounding property in the care, custody and control of the <i>Supplier</i> the amount of the deductible (first amount payable) relevant to the event and (2) for all other existing <i>Purchaser's</i> property the applicable deductible as at contract date
88.3	The <i>Supplier's</i> liability for Defects due to his design which are not notified before the last <i>defects date</i> is limited to:	Total of the price
88.4	The <i>Supplier's</i> total liability to the <i>Purchaser</i> , for all matters arising under or in connection with this contract, other than the excluded matters, is limited to	Total of the price
88.5	The <i>end of liability date</i> is	One years after Delivery of the whole of the goods and services.
9	Termination and dispute resolution	
94.1	The <i>Adjudicator</i> is	the person selected from the ICE-SA Division (or its successor body) of the South African Institution of Civil Engineering Panel of Adjudicators by the Party intending to refer a dispute to him. (see www.ice-sa.org.za). If the Parties do not agree on an Adjudicator the Adjudicator will be appointed by the Arbitration Foundation of Southern Africa (AFSA).
	Address	To be known once the dispute arises
	Tel No.	To be known once the dispute arises
	Fax No.	To be known once the dispute arises
	e-mail	To be known once the dispute arises
94.2(3)	The <i>Adjudicator nominating body</i> is:	the Chairman of ICE-SA, a Division of the South African Institution of Civil Engineering, or its successor body (See www.ice-sa.org.za)

94.4(2)	The <i>tribunal</i> is:	arbitration
94.4(5)	The <i>arbitration procedure</i> is	the latest edition of Rules for the Conduct of Arbitrations published by The Association of Arbitrators (Southern Africa) or its successor body.
94.4(5)	The place where arbitration is to be held is The person or organisation who will choose an arbitrator - if the Parties cannot agree a choice or - if the arbitration procedure does not state who selects an arbitrator, is	[•] South Africa the Chairman for the time being or his nominee of the Association of Arbitrators (Southern Africa) or its successor body.

10 Data for Option clauses

X1	Price adjustment for inflation		
X1.1	The <i>base date</i> for indices is	One month prior the tender closing date. (2nd,3rd ,4th and 5th years anniversary are subjected to CPA claim).	
	The proportions used to calculate the Price Adjustment Factor are:	proportion	linked to index for
			Index prepared by
		0.45	Engineering Input Price Index (Table g-1 Electrical) SEIFSA
		0.10	Transport (Table L-2 B) SEIFSA
		0.20	Consumer Price Index(Table D-4) SEIFSA
		[0.15]	non-adjustable
		1.00	
X2	Changes in the law		
X2.1	A change in the law of	South Africa is a compensation event if it occurs after the Contract Date	
X7	Delay damages		
X7.1	Delay damages for Delivery are	Delivery of	amount per day
		All spares	2% of the task order value per day for delay from agreed delivery date per spare

X17	Low performance damages		
X17.1	The amounts for low performance damages are:	<p>amount</p> <p>2% of the spare value will be deducted per day due to spares that failed quality inspection</p> <p>100% of the task order value will be withheld</p>	<p>performance level</p> <p>for picking up that spares failed quality inspection and took more than 2 days to correct the defect</p> <p>For failing to adhere to the agreed Quality requirements</p>
Z	<p>The additional conditions of contract are</p> <p>Z1 to Z15 always apply for Eskom</p>		

Z1 Cession delegation and assignment

- Z1.1 The *Supplier* does not cede, delegate or assign any of its rights or obligations to any person without the written consent of the *Purchaser*.
- Z1.2 Notwithstanding the above, the *Purchaser* may on written notice to the *Supplier* cede and delegate its rights and obligations under this contract to any of its subsidiaries or any of its present divisions or operations which may be converted into separate legal entities as a result of the restructuring of the Electricity Supply Industry.

Z2 Joint ventures

- Z2.1 If the *Supplier* constitutes a joint venture, consortium or other unincorporated grouping of two or more persons or organisations then these persons or organisations are deemed to be jointly and severally liable to the *Purchaser* for the performance of this contract.
- Z2.2 Unless already notified to the *Purchaser*, the persons or organisations notify the *Supply Manager* within two weeks of the Contract Date of the key person who has the authority to bind the *Supplier* on their behalf.
- Z2.3 The *Supplier* does not alter the composition of the joint venture, consortium or other unincorporated grouping of two or more persons without the consent of the *Purchaser* having been given to the *Supplier* in writing.

Z3 Change of Broad Based Black Economic Empowerment (B-BBEE) status

- Z3.1 Where a change in the *Supplier's* legal status, ownership or any other change to his business composition or business dealings results in a change to the *Supplier's* B-BBEE status, the *Supplier* notifies the *Purchaser* within seven days of the change.
- Z3.2 The *Supplier* is required to submit an updated verification certificate and necessary supporting documentation confirming the change in his B-BBEE status to the *Supply Manager* within thirty days of the notification or as otherwise instructed by the *Supply Manager*.
- Z3.3 Where, as a result, the *Supplier's* B-BBEE status has decreased since the Contract Date the

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Purchaser may either re-negotiate this contract or alternatively, terminate the *Supplier's* obligation to Provide the Goods and Services.

- Z3.4 Failure by the *Supplier* to notify the *Purchaser* of a change in its B-BBEE status may constitute a reason for termination. If the *Purchaser* terminates in terms of this clause, the procedures on termination are P1, P2 and P3 as stated in clause 92, and the amount due is A1 and A3 as stated in clause 93.

Z4 Confidentiality

- Z4.1 The *Supplier* does not disclose or make any information arising from or in connection with this contract available to Others. This undertaking does not, however, apply to information which at the time of disclosure or thereafter, without default on the part of the *Supplier*, enters the public domain or to information which was already in the possession of the *Supplier* at the time of disclosure (evidenced by written records in existence at that time). Should the *Supplier* disclose information to Others in terms of clause 23.1, the *Supplier* ensures that the provisions of this clause are complied with by the recipient.
- Z4.2 If the *Supplier* is uncertain about whether any such information is confidential, it is to be regarded as such until notified otherwise by the *Supply Manager*.
- Z4.3 In the event that the *Supplier* is, at any time, required by law to disclose any such information which is required to be kept confidential, the *Supplier*, to the extent permitted by law prior to disclosure, notifies the *Purchaser* so that an appropriate protection order and/or any other action can be taken if possible, prior to any disclosure. In the event that such protective order is not, or cannot, be obtained, then the *Supplier* may disclose that portion of the information which it is required to be disclosed by law and uses reasonable efforts to obtain assurances that confidential treatment will be afforded to the information so disclosed.
- Z4.4 The taking of images (whether photographs, video footage or otherwise) of the *goods* or any portion thereof, in the course of Providing the Goods and Services and after Delivery, requires the prior written consent of the *Supply Manager*. All rights in and to all such images vests exclusively in the *Purchaser*.
- Z4.5 The *Supplier* ensures that all his subcontractors abide by the undertakings in this clause.

Z5 Waiver and estoppel: Add to core clause 12.3:

- Z5.1 Any extension, concession, waiver or relaxation of any action stated in this contract by the Parties, the *Supply Manager* or the *Adjudicator* does not constitute a waiver of rights, and does not give rise to an estoppel unless the Parties agree otherwise and confirm such agreement in writing.

Z6 Health, safety and the environment: Add to core clause 25.4

- Z6.1 The *Supplier* undertakes to take all reasonable precautions to maintain the health and safety of persons in and about the provision of the *goods* and execution of the *services*.

Without limitation the *Supplier*:

- warrants that the total of the Prices as at the Contract Date includes a sufficient amount for proper compliance with all applicable health & safety laws and regulations and the health and safety rules, guidelines and procedures provided for in this contract and generally for the proper maintenance of health & safety in and about the execution of supply and
- undertakes, in and about the execution of the supply, to comply with all applicable health & safety laws and regulations and rules, guidelines and procedures otherwise provided for under this contract and ensures that his Subcontractors, employees and others under the

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Supplier's direction and control, likewise observe and comply with the foregoing.

Z6.2 The *Supplier*, in and about the execution of the supply, complies with all applicable environmental laws and regulations and rules, guidelines and procedures otherwise provided for under this contract and ensures that his Subcontractors, employees and others under the *Supplier's* direction and control, likewise observe and comply with the foregoing.

Z7 Provision of a Tax Invoice and interest. Add to core clause 51

Z7.1 Within one week of receiving a payment certificate from the *Supply Manager* in terms of core clause 51.1, the *Supplier* provides the *Purchaser* with a tax invoice in accordance with the *Purchaser's* procedures stated in the Goods Information, showing the amount due for payment equal to that stated in the payment certificate.

Z7.2 If the *Supplier* does not provide a tax invoice in the form and by the time required by this contract, the time by when the *Purchaser* is to make a payment is extended by a period equal in time to the delayed submission of the correct tax invoice. Interest due by the *Purchaser* in terms of core clause 51.2 is then calculated from the delayed date by when payment is to be made.

Z7.3 The *Supplier* (if registered in South Africa in terms of the companies Act) is required to comply with the requirements of the Value Added Tax Act, no 89 of 1991 (as amended) and to include the *Purchaser's* VAT number 4740101508 on each invoice he submits for payment.

Z8 Notifying compensation events

Z8.1 Delete from the last sentence in core clause 61.3 the words, "unless the event arises from the *Supply Manager* giving an instruction, changing an earlier decision or correcting an assumption".

Z9 Purchaser's limitation of liability

Z9.1 The *Purchaser's* liability to the *Supplier* for the *Supplier's* indirect or consequential loss is limited to R0.00 (zero Rand)

Z9.2 The *Supplier's* entitlement under the indemnity in 83.1 is provided for in 60.1(12) and the *Purchaser's* liability under the indemnity is limited.

Z10 Termination: Add to core clause 91.1, at the second main bullet point, fourth sub-bullet point, after the words "against it":

Z10.1 or had a business rescue order granted against it.

Z11 Addition to secondary Option X7 Delay damages (if applicable in this contract)

Z11.1 If the amount due for the *Supplier's* payment of delay damages reaches the limits stated in this Contract Data for Option X7, the *Purchaser* may terminate the *Supplier's* obligation to Provide the Goods and Services using the same procedures and payment on termination as those applied for reasons R1 to R15 or R18 stated in the Termination Table.

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Z12 Ethics

For the purposes of this Z-clause, the following definitions apply:

Affected Party	means, as the context requires, any party, irrespective of whether it is the <i>Supplier</i> or a third party, such party's employees, agents, or Subcontractors or Subcontractor's employees, or any one or more of all of these parties' relatives or friends,
Coercive Action	means to harm or threaten to harm, directly or indirectly, an Affected Party or the property of an Affected Party, or to otherwise influence or attempt to influence an Affected Party to act unlawfully or illegally,
Collusive Action	means where two or more parties co-operate to achieve an unlawful or illegal purpose, including to influence an Affected Party to act unlawfully or illegally,
Committing Party	means, as the context requires, the <i>Supplier</i> , or any member thereof in the case of a joint venture, or its employees, agents, or Subcontractors or the Subcontractor's employees,
Corrupt Action	means the offering, giving, taking, or soliciting, directly or indirectly, of a good or service to unlawfully or illegally influence the actions of an Affected Party,
Fraudulent Action	means any unlawfully or illegally intentional act or omission that misleads, or attempts to mislead, an Affected Party, in order to obtain a financial or other benefit or to avoid an obligation or incurring an obligation,
Obstructive Action	means a Committing Party unlawfully or illegally destroying, falsifying, altering or concealing information or making false statements to materially impede an investigation into allegations of Prohibited Action, and
Prohibited Action	means any one or more of a Coercive Action, Collusive Action Corrupt Action, Fraudulent Action or Obstructive Action.

- Z12.1 A Committing Party may not take any Prohibited Action during the course of the procurement of this contract or in execution thereof.
- Z12.2 The *Purchaser* may terminate the *Supplier's* obligation to Provide the Services if a Committing Party has taken such Prohibited Action and the *Supplier* did not take timely and appropriate action to prevent or remedy the situation, without limiting any other rights or remedies the *Purchaser* has. It is not required that the Committing Party had to have been found guilty, in court or in any other similar process, of such Prohibited Action before the *Purchaser* can terminate the *Supplier's* obligation to Provide the Services for this reason.
- Z12.3 If the *Purchaser* terminates the *Supplier's* obligation to Provide the Services for this reason, the amounts due on termination are those intended in core clauses 92.1 and 92.2.
- Z12.4 A Committing Party co-operates fully with any investigation pursuant to alleged Prohibited Action. Where the *Purchaser* does not have a contractual bond with the Committing Party, the *Supplier* ensures that the Committing Party co-operates fully with an investigation.

Z13 Insurance

Z 13.1 Replace core clause 84 with the following:

Insurance cover	84	
	84.1	When requested by a Party, the other Party provides certificates from his insurer or broker stating that the insurances required by this contract are in force.
	84.2	The <i>Supplier</i> provides the insurances stated in the Insurance Table A for events which are at the <i>Supplier's</i> risk from the <i>starting date</i> until the last <i>defects date</i> or a termination certificate has been issued.

INSURANCE TABLE A

Insurance against	Minimum amount of cover or minimum limit of indemnity
Loss of or damage to the <i>goods</i> , plant and materials	The replacement cost where not covered by the <i>Purchaser's</i> insurance. The <i>Purchaser's</i> policy deductible as at Contract Date, where covered by the <i>Purchaser's</i> insurance.
Liability for loss of or damage to property (except the <i>goods</i> , plant and materials and equipment) and liability for bodily injury to or death of a person (not an employee of the <i>Supplier</i>) caused by activity in connection with this contract	<u>Loss of or damage to property</u> <i>Purchaser's property</i> The replacement cost where not covered by the <i>Purchaser's</i> insurance. The <i>Purchaser's</i> policy deductible as at Contract Date, where covered by the <i>Purchaser's</i> insurance. <u>Other property</u> The replacement cost <u>Death of or bodily injury</u> The amount required by the applicable law.
Liability for death of or bodily injury to employees of the <i>Supplier</i> arising out of and in the course of their employment in connection with this contract	The amount required by the applicable law

Z 13.2 Replace core clause 87 with the following:

Insurance by the *Purchaser*

87

87.1 The *Purchaser* provides the insurances stated in the Insurance Table B

INSURANCE TABLE B

Insurance against or name of policy	Minimum amount of cover or minimum limit of indemnity
Assets All Risk	Per the insurance policy document
Contract Works insurance	Per the insurance policy document
Environmental Liability	Per the insurance policy document
General and Public Liability	Per the insurance policy document
Transportation (Marine)	Per the insurance policy document
Motor Fleet and Mobile Plant	Per the insurance policy document
Terrorism	Per the insurance policy document
Cyber Liability	Per the insurance policy document
Nuclear Material Damage and Business Interruption	Per the insurance policy document
Nuclear Material Damage Terrorism	Per the insurance policy document

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Z14 Nuclear Liability

- Z14.1 The *Purchaser* is the operator of the Koeberg Nuclear Power Station (KNPS), a nuclear installation, as designated by the National Nuclear Regulator of the Republic of South Africa, and is the holder of a nuclear licence in respect of the KNPS.
- Z14.2 The *Purchaser* is solely responsible for and indemnifies the *Supplier* or any other person against any and all liabilities which the *Supplier* or any person may incur arising out of or resulting from nuclear damage, as defined in Act 47 of 1999, save to the extent that any liabilities are incurred due to the unlawful intent of the *Supplier* or any other person or the presence of the *Supplier* or that person or any property of the *Supplier* or such person at or in the KNPS or on the KNPS site, without the permission of the *Purchaser* or of a person acting on behalf of the *Purchaser*.
- Z14.3 Subject to clause Z14.4 below, the *Purchaser* waives all rights of recourse, arising from the aforesaid, save to the extent that any claims arise or liability is incurred due or attributable to the unlawful intent of the *Supplier* or any other person, or the presence of the *Supplier* or that person or any property of the *Supplier* or such person at or in the KNPS or on the KNPS site, without the permission of the *Purchaser* or of a person acting on behalf of the *Purchaser*.
- Z14.4 The *Purchaser* does not waive its rights provided for in section 30 (7) of Act 47 of 1999, or any replacement section dealing with the same subject matter.
- Z14.5 The protection afforded by the provisions hereof shall be in effect until the KNPS is decommissioned.

Z15 Asbestos

For the purposes of this Z-clause, the following definitions apply:

AAIA	means approved asbestos inspection authority.
ACM	means asbestos containing materials.
AL	means action level, i.e. a level of 50% of the OEL, i.e. 0.1 regulated asbestos fibres per ml of air measured over a 4 hour period. The value at which proactive actions is required in order to control asbestos exposure to prevent exceeding the OEL.
Ambient Air	means breathable air in area of work with specific reference to breathing zone, which is defined to be a virtual area within a radius of approximately 30cm from the nose inlet.
Compliance Monitoring	means compliance sampling used to assess whether or not the personal exposure of workers to regulated asbestos fibres is in compliance with the Standard's requirements for safe processing, handling, storing, disposal and phase-out of asbestos and asbestos containing material, equipment and articles.
OEL	means occupational exposure limit.
Parallel Measurements	means measurements performed in parallel, yet separately, to existing measurements to verify validity of results.
Safe Levels	means airborne asbestos exposure levels conforming to the Standard's requirements for safe processing, handling, storing, disposal and phase-out of asbestos and asbestos containing material, equipment and articles.
Standard	means the <i>Purchaser's</i> Asbestos Standard 32-303: Requirements for Safe Processing, Handling, Storing, Disposal and Phase-out of Asbestos and Asbestos

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Containing Material, Equipment and Articles.

SANAS means the South African National Accreditation System.

TWA means the average exposure, within a given workplace, to airborne asbestos fibres, normalised to the baseline of a 4 hour continuous period, also applicable to short term exposures, i.e. 10-minute TWA.

- Z15.1 The *Purchaser* ensures that the Ambient Air in the area where the *Supplier* will Provide the Services conforms to the acceptable prescribed South African standard for asbestos, as per the regulations published in GNR 155 of 10 February 2002, under the Occupational Health and Safety Act, 1993 (Act 85 of 1993) ("Asbestos Regulations"). The OEL for asbestos is 0.2 regulated asbestos fibres per millilitre of air as a 4-hour TWA, averaged over any continuous period of four hours, and the short term exposure limit of 0.6 regulated asbestos fibres per millilitre of air as a 10-minute TWA, averaged over any 10 minutes, measured in accordance with HSG248 and monitored according to HSG173 and OESSM.
- Z15.2 Upon written request by the *Supplier*, the *Purchaser* certifies that these conditions prevail. All measurements and reporting are effected by an independent, competent, and certified occupational hygiene inspection body, i.e. a SANAS accredited and Department of Employment and Labour approved AAIA. The *Supplier* may perform Parallel Measurements and related control measures at the *Supplier's* expense. For the purposes of compliance the results generated from Parallel Measurements are evaluated only against South African statutory limits as detailed in clause Z15.1. Control measures conform to the requirements stipulated in the AAIA-approved asbestos work plan.
- Z15.3 The *Purchaser* manages asbestos and ACM according to the Standard.
- Z15.4 In the event that any asbestos is identified while Providing the Services, a risk assessment is conducted and if so required, with reference to possible exposure to an airborne concentration of above the AL for asbestos, immediate control measures are implemented and relevant air monitoring conducted in order to declare the area safe.
- Z15.5 The *Supplier's* personnel are entitled to stop working and leave the contaminated area forthwith until such time that the area of concern is declared safe by either Compliance Monitoring or an AAIA approved control measure intervention, for example, per the emergency asbestos work plan, if applicable.
- Z15.6 The *Supplier* continues to Provide the Services, without additional control measures presented, on presentation of Safe Levels. The contractually agreed dates to Provide the Services, including the Completion Date, are adjusted accordingly. The contractually agreed dates are extended by the notification periods required by regulations 3 and 21 of the Asbestos Regulations.
- Z15.7 Any removal and disposal of asbestos, asbestos containing materials and waste, is done by a registered asbestos contractor, instructed by the *Purchaser* at the *Purchaser's* expense, and conducted in line with South African legislation.

Annexure A: Supply Requirements

[Notes: The example given in the NEC3 Supply Contract Guidance Notes pages 15 to 20 inclusive is based on Incoterms 2000. However users will probably wish to use Incoterms 2010 which the details below are based on. Users may need to adjust the information to comply with actual requirements. First decide whether Incoterms will be used or not, then delete the arrangement below which does not apply and delete these notes]

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

The Supply Requirements for this contract are based on the use of INCOTERMS:

The *Supplier* supplies the *goods* in accordance with INCOTERMS 2010² as follows:

[Select the group and then term within the group which applies and state the applicable delivery place. Delete all the other groups and this note]

Group	Category	Term	Delivery Place
E	departure	EXW	
F	main carriage unpaid	FCA, FAS, FOB	
C	main carriage paid	CFR, CIF, CPT, CIP	
D	arrival	DAT, DAP, DDP	

The Parties obligations described in Incoterms for the category and term selected are now incorporated into this contract as part of the Supply Requirements and hence the Goods Information.

The obligations of seller and buyer for the selected Incoterm determine each Party's costs, risks and insurance requirements incidental to the supply and transport of the *goods* from *Supplier* to *Purchaser*.

For each of the thirteen terms, Incoterms set out obligations of the seller (the *Supplier*) in ten paragraphs identified as A1 to A10 and the corresponding obligations of the buyer (the *Purchaser*) in paragraphs B1 to B10. These obligations cover the following subjects:

A	The <i>Supplier's</i> obligations	B	The <i>Purchaser's</i> obligations
A1	Provision of goods in conformity with contract	B1	Payment of the price
A2	Licences, authorisations and formalities	B2	Licences, authorisations and formalities
A3	Contracts of carriage and insurance	B3	Contracts of carriage and insurance
A4	Delivery	B4	Taking delivery
A5	Transfer of risks	B5	Transfer of risks
A6	Division of costs	B6	Division of costs
A7	Notice to the buyer	B7	Notice to the seller
A8	Proof of delivery, transport document or equivalent electronic message	B8	Proof of delivery, transport document or equivalent electronic message
A9	Checking - packing - marking	B9	Inspection of goods
A10	Other obligations	B10	Other obligations

[Should there be a need to amplify any of the published obligations listed above for the chosen INCOTERM, add them here.]

All other information NOT pertinent to the above is given in the balance of the Goods Information

² International Chamber of Commerce, Incoterms 2010, Paris, January 2011

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

The Supply Requirements for this contract are as follows:

[Use these when INCOTERMS do not apply].

1. The requirements for the supply are	[State the constraints on how the <i>Supplier</i> manufactures, prototypes, tests and stores the <i>goods</i> including order and timing]	
2. The requirements for transport are	[State the extent to which the <i>Supplier</i> transports the <i>goods</i> and the mode of transport]	
3. The delivery place is	[State the location where the <i>goods</i> are to be placed by the <i>Supplier</i> , such as whether it is a dispatch department at the <i>Supplier's</i> premises, the <i>Purchaser</i> is to collect or other location the <i>Purchaser</i> may require. If the delivery place for the <i>services</i> is different to the <i>goods</i> state it here]	
4. Actions of the Parties during supply	Action	Party which does it
	Giving notice of Delivery	
	Checking packing and marking before dispatch	
	Contracting for transport	
	Pay costs of transport	
	Arrange access to delivery place	
	Loading the <i>goods</i>	
	Unloading the <i>goods</i>	
For international procurement	Undertake export requirements	
	Undertake import requirements	
5. Information to be provided by the Supplier	Title of document	
	Packing lists for cases and their contents	
	Copy of invoice for the <i>goods</i>	
	Delivery Note	
	Test results and maintenance manuals	
For international procurement	Licences, authorisations and other formalities associated with export of the <i>goods</i>	
	Air Waybill or Bill of Lading with associated landing, delivery and forwarding order	
	The Bill of Entry endorsed by the importation authority	
	Customs work sheets, showing tax, duties and surcharges which the law of the country into which the <i>goods</i> are being imported requires the importer to pay	
	Invoice from the importation clearing agent showing airline fees, landing charges, wharfage and dock dues as applicable	
	Specify other import documents required by authorised officials.	

All other information NOT pertinent to the above is given in the balance of the Goods Information

C1.2 Contract Data

Part two - Data provided by the *Supplier*

[Instructions to the contract compiler: (delete this note before issue to tenderers with an enquiry)

Whenever a cell is shaded in the left hand column it denotes this data is optional and would be required in relation to the option selected. In the event that the option is not required select and delete the whole row.]

Notes to a tendering supplier:

1. Please read both the NEC3 Supply Contract (SC3)¹ and the relevant parts of its Guidance Notes (SC3-GN)² in order to understand the implications of this Data which the tenderer is required to complete.
2. The number of the clause which requires the data is shown in the left hand column for each statement however other clauses may also use the same data
3. Where a form field like this [] appears, data is required to be inserted relevant to the option selected. Click on the form field **once** and type in the data. Otherwise complete by hand and in ink.

Completion of the data in full, according to Options chosen, is essential to create a complete contract.

Clause	Statement	Data				
10.1	The <i>Supplier</i> is (Name): Address Tel No. Fax No.					
11.2(8)	The Goods Information for the <i>Supplier's</i> design is in:					
11.2(11)	The tendered total of the Prices is	R , (in words)				
11.2(12)	The <i>price schedule</i> is in:					
11.2(14)	The following matters will be included in the Risk Register					
25.2	The restrictions to access for the <i>Supply Manager</i> and Others to work being done for this contract are					
30.1	The <i>delivery date</i> of the <i>goods and services</i> is:	<table border="1"> <thead> <tr> <th><i>goods and services</i></th> <th><i>delivery date</i></th> </tr> </thead> <tbody> <tr> <td>1 Circuit Breakers</td> <td>As per lead time</td> </tr> </tbody> </table>	<i>goods and services</i>	<i>delivery date</i>	1 Circuit Breakers	As per lead time
<i>goods and services</i>	<i>delivery date</i>					
1 Circuit Breakers	As per lead time					
31.1	The programme identified in the Contract Data is contained in:					

¹ Either April 2013 or December 2009 Edition as stated by *Purchaser* in Contract Data part 1.

² Available from Engineering Contract Strategies Tel 011 803 3008, Fax 086 539 1902, or www.ecs.co.za

PART 2: PRICING DATA

NEC3 Supply Contract

Document reference	Title	No of pages
C2.1	Pricing assumptions	2
C2.2	The <i>price schedule</i>	2

C2.1 Pricing assumptions

1. How goods and services are priced and assessed for payment

Clause 11 in NEC3 Supply Contract, (SC3) core clauses states:

Identified and defined terms	11 11.2	(11) The Prices are the amounts stated in the price column of the Price Schedule. Where a quantity is stated for an item in the Price Schedule, the Price is calculated by multiplying the quantity by the rate. (12) The Price Schedule is the <i>price schedule</i> unless later changed in accordance with this contract.
Assessing the amount due	50.2	The amount due is <ul style="list-style-type: none"> • the Price for each lump sum item in the Price Schedule which the <i>Supplier</i> has completed, • where a quantity is stated for an item in the Price Schedule, an amount calculated by multiplying the quantity which the <i>Supplier</i> has completed by the rate, • plus other amounts to be paid to the <i>Supplier</i>, • less amounts to be paid by or retained from the <i>Supplier</i>. <p>Any tax which the law requires the <i>Purchaser</i> to pay to the <i>Supplier</i> is included in the amount due.</p>

This confirms that the Supply Contract is a priced contract where the Prices are derived from a list of items of *goods* and *services* which can be priced as lump sums or as expected quantities of *goods* and *services* multiplied by a rate, or a mix of both.

2. Function of the Price Schedule

Clause 53.1 states: "Information in the Price Schedule is not Goods Information". This confirms that instructions to do work or how it is to be done are not included in the Price Schedule but in the Goods Information. This is further confirmed by Clause 20.1 which states, "The *Supplier* Provides the Goods and Services in accordance with the Goods Information". Hence the *Supplier* does **not** Provide the Goods and Services in accordance with the Price Schedule. The Price Schedule is only a pricing document.

3. Preparing the *price schedule*

Items in the *price schedule* may have been inserted by the *Purchaser* and the tendering supplier should insert any additional items which he considers necessary. Whichever party provides the items in the *price schedule* the total of the Prices is assumed to be fully inclusive of everything necessary to Provide the Goods and Services as described at the time of entering into this contract.

It will be assumed that the tendering supplier has

- Read Pages 8, 11, 12 and Appendix 5 of the SC3 Guidance Notes before preparing the *price schedule*;

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

- Included in his Prices and rates for correction of Defects (core clause 43.1) as there is no compensation event for this unless the Defect is due to a *Supplier's* risk;
- Spread the cost of doing work he chooses not to list as separate items in the *price schedule* across other Prices and rates in order to fulfil the obligation to Provide the Goods and Services for the tendered total of the Prices;
- Understood that there is no adjustment to lump sum prices in the *price schedule* if the amount, or quantity, of work within that lump sum item later turns out to be different to that which the *Supplier* estimated at time of tender. The only basis for a change to the Prices is as a result of a compensation event per clause 60.1;
- Understood that the *Supplier* does not have to allow in his Prices and rates for matters that may arise as a result of a compensation event.

3.1. Format of the *price schedule*

Entries in the first four columns in the *price schedule* in section C2.2 are made either by the *Purchaser* or the tendering supplier.

If the *Supplier* is to be paid an amount for the item which is not adjusted if the quantity of work in the item changes, the tendering supplier enters the amount in the Price column only, the Unit, Quantity and Rate columns being left blank.

If the *Supplier* is to be paid an amount for the item which is the rate for the item multiplied by the quantity completed, the tendering *Supplier* enters the rate which is then multiplied by the Quantity to produce the Price, which is also entered.

If the *Supplier* is to be paid an amount for an item proportional to the length of time for which the *goods* and *services* are provided, a unit of time is stated in the Unit column and the length of time (as a quantity of the stated units of time) is stated in the Quantity column.

C2.2 the price schedule

Supply and Delivery of Circuit Breakers on an as and when required basis for period of five (5) years

Item No	Material	Description	Unit	Qty
VD4 CIRCUIT BREAKER 17.20.32 P210				
1	706411	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 2000 AMP; SHORT TIME CURRENT: 315 (3SEC) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 11KV UNIT BOARD A&B; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 475 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 210 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VCF337123R0552; VD4 CB 17 20 32 P150	Each	6
VD4 CIRCUIT BREAKER 17.06.32 P150				
2	706419	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 12 KV; CURRENT: 630 AMP; SHORT TIME CURRENT: 31.5 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTRONIC CARD; POLLUTION CLASS: IP2X; APPLICATION: FEEDERS; SPECIFICATION: IEC 62771-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 475 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 31.5 KA; MANUF P/N: 1VCF337123R0552; VD4/P CB 17.06 32 P150	Each	15
VD4 CIRCUIT BREAKER 17.12.32 P150				
3	706418	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 1250 AMP; SHORT TIME CURRENT: 31.5 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS C&D FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 450 MM; LENGTH: 424 MM; HEIGHT: 461 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VCF337123R0552; VD4/P CB 17.12 32 P150	Each	15
VM1 CIRCUIT BREAKER 17.06.32 P150				
4	706404	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 630 AMP; SHORT TIME CURRENT: 315 (3 SEC) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS C&D FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 450 MM; LENGTH: 424 MM; HEIGHT: 589 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 31.5 KA; MANUF P/N: 1VCF336123R0151; VM1 CB 17 06 32 P150	Each	30
VD4EL CIRCUIT BREAKER 17.12.40 P210				
5	706413	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 1250 AMP; SHORT TIME CURRENT: 40 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 555 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS A&B FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 589 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 210 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VB7002617R1136; VD4/P CB 17.12 40 P210	Each	20

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

VD4EL CIRCUIT BREAKER 17.25.40 P210				
6	706410	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 2500 AMP; SHORT TIME CURRENT: 40 (3SEC) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 555 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS A&C INCOMERS AND BUS SECTION; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 700 MM; LENGTH: 424 MM; HEIGHT: 616 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 275 MM; INTERRUPT CAPACITY: 40 KA; MANUF P/N: 1VB7002617R1136; VD4/P CB 17 25 40 P275	Each	20
VD4-1212-25ZSIM CIRCUIT BREAKER				
7	183680	BREAKER, CIRCUIT: POTENTIAL: 3.3-6.6 KV; CURRENT: 1.25 KA; TYPE: VACUUM; INTERRUPT CAPACITY: 25 KA; REFERENCE NO: GCE7002612R0193; ABB, TYPE VD4-1212-25ZS1M, SHORT CIRCUIT BREAKING SYMM 27.3KA, SHORT CIRCUIT MAKING CURRENT (PEAK) 63KA, SHORT CIRCUIT DURATION 3S, ALL CONTROL EQUIPMENT IS 110V DC	Each	15
V7-ZC CONTACTOR				
8	716878	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: UNIFLEX; POTENTIAL: 7.2 KV; CURRENT: 400 A; SHORT TIME CURRENT: 31.5 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTRONIC CARD; POLLUTION CLASS: IP2X; APPLICATION: 3.3 KV; SERVICE BOARD C&D; SPECIFICATION: IEC62771-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 475 MM; COLOR: WHITE; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 31.5 KA; MANUF P/N: AB00030226; IVCF68140850075; CONTACTOR V5C7/P	Each	15
VMAL CB 17 12 32 P150 CIRCUIT BREAKER				
9	716878	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1 (550); POTENTIAL: 17.5 KV; CURRENT: 1250 AMP; SHORT TIME CURRENT: 315 KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: INCOMERS; FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 461 MM; LENGTH: 416 MM; HEIGHT: 665 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VCF327133R052; VMAL CB 17 12 32 P150	Each	25

PART 3: SCOPE OF WORK

Document reference	Title	No of pages
	This cover page	1
C3.1	<i>Purchaser's</i> Goods Information	10
C3.2	<i>Supplier's</i> Goods Information	1
	Total number of pages	12

C3.1: PURCHASER’S GOODS INFORMATION

Contents

Part 3: Scope of Work	1
C3.1: Purchaser’s Goods Information	2
1 Overview and purpose of the goods and services	4
2 Specification and description of the goods	4
2.1 Purchaser’s design.....	6
2.2 Procedure for submission and acceptance of Supplier’s design	6
2.3 Other requirements of the Supplier’s design.....	6
2.4 Use of Supplier’s design	6
2.5 Manufacture & fabrication	6
2.6 Factory acceptance testing (FAT).....	6
2.7 Other tests and inspections and commissioning in place of use	6
2.8 Operating manuals and maintenance schedules.....	6
3 Supply Requirements	7
4 Specification of the services to be provided	7
5 Constraints on how the Supplier Provides the Goods	7
5.1 Programming constraints	7
5.2 Work to be done by the Delivery Date	8
5.3 Marking the goods.....	8
5.4 Constraints at the delivery place and place of use	8
5.5 Cooperating with Others	8
5.6 Services & other things to be provided by the Purchaser or Supplier	8
5.7 Management meetings.....	8
5.8 Documentation control	9
5.9 Health and safety risk management	9
5.10 Environmental constraints and management.....	9
5.11 Quality	10
5.12 Invoicing and payment	10
5.13 Insurance provided by the Purchaser	10
5.14 Contract change management.....	10
5.15 Provision of bonds and guarantees	10
5.16 Records of Defined Cost, payments & assessments of compensation events to be kept by the Supplier.....	10

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

6 Procurement 11

6.1 Subcontracting 11

6.1.1 Preferred subcontractors 11

6.1.2 Limitations on subcontracting 11

6.1.3 Spares and consumables 11

6.1.4 Other requirements related to procurement 11

6.1.5 Cataloguing requirements 11

7 List of drawings 11

7.1 Drawings issued by the *Purchaser* 11

C3.2 Supplier's Goods Information 12

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

1 Overview and purpose of the goods and services

A Power plant operates with various types of lighting products. The purpose of this contract/transaction is to make provision for the supply of various lighting products to be used urgently due to plant darkness.

2 Specification and description of the goods

Item No	Material	Full Description	Quantity
1	183680	BREAKER, CIRCUIT: POTENTIAL: 3.3-6.6 KV; CURRENT: 1.25 KA; TYPE: VACUUM; INTERRUPT CAPACITY: 25 KA; REFERENCE NO: GCE7002612R0193; ABB, TYPE VD4-1212-25ZS1M, SHORT CIRCUIT BREAKING SYMM 27.3KA, SHORT CIRCUIT MAKING CURRENT (PEAK) 63KA, SHORT CIRCUIT DURATION 3S, ALL CONTROL EQUIPMENT IS 110V DC	15
2	706404	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 630 AMP; SHORT TIME CURRENT: 315 (3 SEC) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS C&D FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 450 MM; LENGTH: 424 MM; HEIGHT: 589 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 31.5 KA; MANUF P/N: 1VCF336123R0151; VM1 CB 17 06 32 P150	30
3	706410	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 2500 AMP; SHORT TIME CURRENT: 40 (3SEC) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 555 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS A&C INCOMERS AND BUS SECTION; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 700 MM; LENGTH: 424 MM; HEIGHT: 616 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 275 MM; INTERRUPT CAPACITY: 40 KA; MANUF P/N: 1VB7002617R1136; VD4/P CB 17 25 40 P275	20
4	706411	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 2000 AMP; SHORT TIME CURRENT: 315 (3SEC) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 11KV UNIT BOARD A&B; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 475 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 210 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VCF337123R0552; VD4 CB 17 20 32 P150	6
5	706413	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 1250 AMP; SHORT TIME CURRENT: 40 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 555 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING	20

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

		CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS A&B FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 589 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 210 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VB7002617R1136; VD4/P CB 17.12 40 P210	
6	706418	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 175 KV; CURRENT: 1250 AMP; SHORT TIME CURRENT: 31.5 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: 33KV SERVICE BRDS C&D FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 450 MM; LENGTH: 424 MM; HEIGHT: 461 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VCF337123R0552; VD4/P CB 17.12 32 P150	15
7	706419	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1; POTENTIAL: 12 KV; CURRENT: 630 AMP; SHORT TIME CURRENT: 31.5 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTRONIC CARD; POLLUTION CLASS: IP2X; APPLICATION: FEEDERS; SPECIFICATION: IEC 62771-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 475 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 31.5 KA; MANUF P/N: 1VCF337123R0552; VD4/P CB 17.06 32 P150	15
8	716878	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: UNIFLEX; POTENTIAL: 7.2 KV; CURRENT: 400 A; SHORT TIME CURRENT: 31.5 (3SECS) KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTRONIC CARD; POLLUTION CLASS: IP2X; APPLICATION: 3.3 KV; SERVICE BOARD C&D; SPECIFICATION: IEC62771-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 570 MM; LENGTH: 424 MM; HEIGHT: 475 MM; COLOR: WHITE; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 31.5 KA; MANUF P/N: AB00030226; IVCF68140850075; CONTACTOR V5C7/P	15
9	716878	BREAKER, CIRCUIT: SWITCHGEAR DESIGN: ZS1 (550); POTENTIAL: 17.5 KV; CURRENT: 1250 AMP; SHORT TIME CURRENT: 315 KA; POLE: 3; CONTROL VOLTAGE: 110 V; CREEPAGE: 455 MM; BASIC INSULATION LEVEL: 95 KV; INSULATION MATERIAL: VACUUM; OPERATING CONTROL TYPE: ELECTROMAGNETIC; POLLUTION CLASS: IP2X; APPLICATION: INCOMERS; FEEDERS; SPECIFICATION: IEC 62271-100; TEMPERATURE RATING: -5 TO +40 DEG C; WIDTH: 461 MM; LENGTH: 416 MM; HEIGHT: 665 MM; COLOR: WHITE; TYPE: VACUUM; MOUNT: WITHDRAWABLE; PHASE SPACING: 150 MM; INTERRUPT CAPACITY: 315 KA; MANUF P/N: 1VCF327133R052; VMAL CB 17 12 32 P150	25

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

2.1 Purchaser's design

Not applicable to this contract

2.2 Procedure for submission and acceptance of Supplier's design

- a) For All material with a special code that require AIA intervention, The *Supplier* submits the Project quality (PQP/ Contract quality plan) plan for approval prior to commencement with any manufacturing or fabrication
- b) All *goods* or material are designed and manufactured in accordance with an accepted design standard and as per heading 2 the long item description table above
- c) All *goods* or material technical documents are accepted by the *Employer* prior to commencement with manufacturing or fabrication
- d) All *goods* supplied shall include material certification in line with the design code and standard
- e) The *Supplier* issues the data pack/Certificates for all *goods* supplied if applicable
- f) The data book of *goods* supplied includes but not limited NDT results, welding procedures where applicable
- g) All *goods* are delivered with relevant material certificate in line with the PQP/ Contract quality plan and metallurgical relevant tests

The *Supplier* submits particulars of the design of an item of *goods* to the *Supplier Manager* for acceptance when the instructed to do so. A reason for not accepting is that the design of the *goods* will not allow the *Supplier* to provide the *service* in accordance with the *Purchaser's* Goods Information, accepted plan or the applicable law.

2.3 Other requirements of the Supplier's design

Not applicable to this contract

2.4 Use of Supplier's design

The *Purchaser* is allowed to use the designs, drawings and documents for the purpose of verifying goods supplied and the fulfilment of PQP/ CQP/QCP

2.5 Manufacture & fabrication

As per heading 2.2 above

2.6 Factory acceptance testing (FAT)

As per heading 2.2 above

2.7 Other tests and inspections and commissioning in place of use

Not applicable to this contract

2.8 Operating manuals and maintenance schedules

Material data sheets and or certificates shall include storage procedure as well as maintenance philosophies and to be submitted upon delivery of all goods

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

3 Supply Requirements

- a) *Supplier* to deliver goods in line with lead times prescribed on Part C2 (Data by the Purchaser) upon receipt of order
- b) All purchased goods must be delivered at Kriel Power Station stores.
- c) The *Supplier* to ensure the goods are delivered during working hours and reasonable time must be allocated for gate access, off-loading, paperwork processing. Working Hours for Kriel Power Station are as follows: Monday to Thursday – 07h00 to 16h15 and Friday 07h00 to 12h00.
- d) Where deliveries are to be made outside the working hours, the *Supplier* need to confirm the availability of Kriel Power Station Stores Receiving personnel before dispatching the items
- e) The *Supplier* to be prepared and always ready to provide goods within an acceptable delivery period when urgently required.
- f) Supply and deliver order according to specification as per the SOW and handle defective material and premature failure of components.
- g) Perform quality verification.
- h) Provide onsite and offsite material storage procedure as per the equipment manufacturer requirements.
- i) Perform safe stock handling and transportation of critical components.
- j) Provide technical support to the Employer on delivered filters as per the SOW in liaising with respective equipment manufacturer.
- k) Transport goods and provide technical support
- l) All *goods* are packaged such that inadvertent mechanical damage to components is not possible
- m) Damaged *goods* due to the fault of the *Supplier* are corrected at *Supplier's* cost
- n) All intervention points and data books are supplied for all goods as signed off in line with PQP/ Contract quality plan and QCPs

Mandatory requirements

- a) The *Supplier* will always supply the Material with a minimum of a 3.1 Material Certificate
- b) Material certs are delivered with the material at receiving
- c) The *Supplier* complies with the technical evaluation strategy requirements through the duration of the contract ref no 555-EBP2072
- d) The *Supplier* will always obtain a signed declaration form from manufacturer, confirming that all the requirements of material preservation specifications according to any EN Code (e.g., EN 10204:2004) and/or local accreditation body will be met.
- e) Quality certification that the *Supplier* has been audited and authorized having a quality assurance system for material manufacture in accordance with an ISO standard to produce/Sell the material grades and dimension ranges tendered for.
 - Both the ISO 9001 Valid Certification and *Supplier's* Signed QMS

4 Specification of the services to be provided

As per Table on heading 2

5 Constraints on how the *Supplier* Provides the Goods

5.1 Programming constraints

- a) The *Supplier* submits a program to the *Supply Manager* as per the agreed lead times during negotiations which covers all milestones of the manufacturing process up to delivery to site.
- b) The *Supplier* shares the program two (2) days after placement of each order to the *Supply Manager* for acceptance
- c) The early warning as per clause 16.1 is used to communicate the changes on agreed delivery schedule/ programme

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

delivery date
As per agreed lead time and or stated on purchase order issuance

5.2 Work to be done by the Delivery Date

The agreed delivery date of the goods is the date after all the Quality Control Processes and correction of defects.

5.3 Marking the goods

All deliveries to be marked with purchase order number, Unit of measure, quantity, and date of delivery.

5.4 Constraints at the delivery place and place of use

- a) All deliveries should be arranged to be within Kriel Power Station normal working hours as stipulated in section 3 of this document.
- b) Kriel Power Station site access will be adhered to. The *Supplier* informs the Purchaser timeously to make all necessary arrangement.

5.5 Cooperating with Others

- a) The *Supplier* cooperates with the stores personnel during delivery.
- b) The *Supplier* cooperates with the Purchasers team in ensuring that the goods are delivered in accordance with all requirements

5.6 Services & other things to be provided by the Purchaser or Supplier

- a) As per Heading 3 (Supply requirements)
- b) As per Heading 4 (Specification of the service to be provided)
- c) The availability of rigging equipment, cranes or forklift and the relevant operators must be confirmed with the Kriel Power Station (*Supply manager*) before dispatching the *goods*.
- d) The Supplier provides offloading people to assist with offloading at receiving. NB: The Supplier offloading team names must be part of the valid approved safety file

5.7 Management meetings

Regular meetings of a general nature may be convened and chaired by the *Supply Manager* as follows:

Title and purpose	Approximate time & interval	Location	Attendance by:
Risk register and compensation events	Quarterly or as and when urgent need arises	either face to face or virtual at a convenient venue	<i>Purchaser, Supplier, and Cross functional team members</i>
Overall contract progress and feedback	Quarterly or as and when urgent need arises	Teams/Kriel/Suppliers Premises	<i>Purchaser, Supplier, and ____</i>

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Meetings of a specialist nature may be convened as specified elsewhere in this Goods Information or if not so specified by persons and at times and locations to suit the Parties, the nature and the progress of the manufacture of the *goods*. Records of these meetings shall be submitted to the *Supply Manager* by the person convening the meeting within five days of the meeting.

All meetings shall be recorded using minutes or a register prepared and circulated by the person who convened the meeting. Such minutes or register shall not be used for the purpose of confirming actions or instructions under the contract as these shall be done separately by the person identified in the *conditions of contract* to carry out such actions or instructions.

5.8 Documentation control

All contractual communications will be in the form of properly compiled letters or forms attached to e-mails and not as a message in the email itself.

The manufacturing data books shall be submitted in hardcopy and soft copy format. The following documentation shall form part of the manufacturing data book:

- a. Material Certificates 3.1 certification
- b. Manufacturing QCP's (All fully signed) All goods are accepted and signed off by Employer's QC
- c. Storage procedures
- d. Material data sheets

5.9 Health and safety risk management

- a) The *Supplier* complies with Section 10 of Occupational Health and Safety Act (Act No.85 of 1993) when manufacturing any *goods* for this contract.
- b) The *Supplier* shall comply with site health and safety requirements for Kriel Power Station when delivering *goods*.
- c) Site delivery safety requirements to be adhered to - And can be obtained through the *Purchaser's Manager* In line with the SHE specification
- d) The *Supplier* submits safety file for approval before access is granted
- e) The *Supplier* maintains the safety file validity in line with site requirements
- f) The mode of transport for delivery should comply with site requirement in line with issued SHE specification.
- g) Supplier to update their safety file yearly and each time they make changes on their staff or personnel
- h) The Supplier ensures that when changing a team member, the new team gets inducted and all process of safety file approval is adhered to- before gaining access to site
- i) The *Supplier* shall comply with the health and safety requirements contained in Annexure A to this Goods Information.
- j) The *Supplier* shall comply with the health and safety requirements [stated here or contained in Annexure A to this Goods Information.

The *Supplier* shall comply with the health and safety requirements contained in Annexure A of the Invitation to Tender

5.10 Environmental constraints and management

The *Supplier* shall comply with the environmental criteria and constraints when doing deliveries at Kriel Power Station premises regarding:

- a) The vehicle used for delivery; by ensuring that there are no oil spillages, and the vehicle emission is not emitting beyond limits.
- b) The material used for supporting the *goods* being delivered are correctly disposed and are without harm to environment. The *Supplier* must comply with site Environmental management plan (EMP) and other requirement.
- c) The *Supplier* complies with Environmental aspect and impact register.
- d) The Supplier complies with all site's environmental management procedures, especially the waste management and oil spillages

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

The *Supplier* shall comply with the environmental criteria and constraints contained in Annexure B of the Invitation to Tender

5.11 Quality

- a) The Supplier compiles the baseline Quality Control plan
- b) Quality Control Plan (QCP) must be approved by both the *Suppliers*, Eskom engineer and QC inspector before commencing with any deliveries at the beginning of the contract
- c) Material certificates, mechanical testing certificate and NDT certificates should be part of the data package accompanying the QCPs.
- d) All delivered goods will be subjected to QC verification by an Employer's Quality personnel at receiving at per detailed item description found in heading 2 table
- e) The *Supplier* must comply with Eskom's Supply Quality Management Specification (Document No: 240-105658000) and ISO 9001:2015 requirements.
- f) The *Employer* will on frequent basis conduct the *Supplier's* performance/ compliance in accordance to QM 58 and ISO 9001 and NCR will be raised for non-compliance

The *Supplier* shall comply with the quality criteria and constraints contained in Annexure C of the Invitation to Tender

5.12 Invoicing and payment

Within one week of receiving a payment certificate from the *Supply Manager* in terms of core clause 51.1, the *Supplier* provides the *Purchaser* with a tax invoice showing the amount due for payment equal to that stated in the *Supply Manager's* certificate.

The *Supplier* shall address the tax invoice to *Purchaser* and include on each invoice the following information:

- Name and address of the *Supplier* and the *Supply Manager*;
- The contract number and title;
- *Supplier's* VAT registration number;
- The *Purchaser's* VAT registration number.
- Description of *goods* and *services* provided for each item invoiced based on the Price Schedule;
- Total amount invoiced excluding VAT, the VAT and the invoiced amount including VAT;
- (add other as required)

5.13 Insurance provided by the *Purchaser*

Not applicable to this contract

5.14 Contract change management

The change management process to be followed as per the core clause 16.1. Any verbal instruction/communication must be backed with a written instruction; the use of minutes, letters or emails is accepted. Any communication must go through the purchaser's manager.

5.15 Provision of bonds and guarantees

Not Applicable to this contract

5.16 Records of Defined Cost, payments & assessments of compensation events to be kept by the *Supplier*

CONTRACT TITLE: Kriel Power Station Supply and Delivery of Medium Voltage Circuit Breakers on an as and when required basis for the period of five (5) years

Early warning to be given by any of the parties as soon either becomes aware of matters that could increase the total of total prices, delay completion etc. All the compensation events will be implemented through the raising of an early warning. See NEC Core clause 16.1 and 63.1 and 63.2

6 Procurement

6.1 Subcontracting

6.1.1 Preferred subcontractors

Not applicable to this contract.

6.1.2 Limitations on subcontracting

Not applicable to this contract.

6.1.3 Spares and consumables

Not Applicable to this Contract

6.1.4 Other requirements related to procurement

The Following is SD&L/ CSI Requirement:

- The CSI target for this tender is 3%
- Local content target is 100%
- Skills development target:

Skills type	Intake	Outcome
Bursary to learners at the university of technology	1 st or 2 nd year	National Diploma

6.1.5 Cataloguing requirements by the *Supplier*

Not Applicable to this Contract (All items are stock items)

7 List of drawings

7.1 Drawings issued by the *Purchaser*

This is the list of drawings issued by the *Purchaser* at or before the Contract Date and which apply to this contract.

Drawing number	Revision	Title

C3.2 *SUPPLIER'S* GOODS INFORMATION

This section could also be compiled as a separate file.
