

## Clarification Nr 1 (30.07.2025)

**TENDER MPKRI11494GX:** Procurement of outage Mechanical spares for Kriel Power Station on a once-off basis.

Item No.	Material No.	Qty	Description	Clarification request	Response
31.	22754	40	NOZZLE: TYPE: AIR EJECTOR; SIZE: 60 MM; CONNECTION: NPT; MATERIAL: BRASS; REFERENCE NO: 405; FOR CONDENSER AND AIR EXTRACTION APPARATUS BOILER FEED PUMP. COMPLIANCE TO 3.1 INSPECTION CERTIFICATION IN ACCORDANCE WITH EN 10204:2004 (FOR PER COMPONENTS) AS REQUIRED AND SHALL BE ISSUED AT THE PLANT OF MANUFACTURE, PRIOR TO DISPATCH TO ESKOM – KRIEL POWER STATION	Please provide us with details of the pump including the Brand; serial number; and a picture of the nameplate.	We are not promoting any brand. Please provide as per the specification.
32.	25006	7	BREATHER: TYPE: FILTER; MATERIAL: STL; CONNECTION: 26 MM FNPT; SUPPL P/N: FH2615; COMPLETE WITH ELEMENT, NOTE - ITEM MUST BE PROTECTIVE PACKED AND SEALED	The part number provided does not assist us with any information. Please provide us with the brand, drawing or datasheet..	Kindly submit any brand you have if it meets what is been specified on the description
58.	48191	6	PUMP: CAPACITY: 450 L/MIN; SPEED: 1450 RPM; RATING: 3.7 BAR; DRIVER: MOTORIZED; REFERENCE NO: GG495RV; KULGG495RV; RATING 0.75 BAR; FOR USE ON HOWDEN PA FANS, SUPPLIER NOTE: THE ITEM MUST BE PROTECTIVE PACKED. COMPLIANCE TO 3.1 INSPECTION CERTIFICATION IN ACCORDANCE WITH EN 10204:2004 (FOR PER COMPONENTS) AS REQUIRED AND SHALL BE ISSUED AT THE PLANT OF MANUFACTURE, PRIOR TO DISPATCH TO ESKOM – KRIEL POWER STATION.	Please provide us with additional information including the brand, part number and a drawing.	Kindly submit any brand you have if it meets what is been specified on the description.

61.	50842	80	TIP, NOZZLE: TYPE: PF BURNER; SIZE: ID 500 X OD 740 X THK 10 MM; MATERIAL: SICRO SI23-20; DRAWING NO: F3E31665 REV 1; COMPLETE WITH 6 CENTRALISING PLATES SIZE: SQ 150MM X 10MM; COMPLIANCE TO 3.1 INSPECTION CERTIFICATION IN ACCORDANCE WITH EN 10204:2004 (FOR PER COMPONENTS) AS REQUIRED AND SHALL BE ISSUED AT THE PLANT OF MANUFACTURE, PRIOR TO DISPATCH TO ESKOM – KRIEL POWER STATION.	Kindly confirm Where will the nozzle be used. Please provide us the brand of the item, the serial number and a picture of the nameplate.	It is used in the boiler, and it forms part of the boiler auxiliary parts. So, if you are familiar with the boiler, you should know. It does not have specific brand.
66.	54221	28	TIP: TYPE: BURNER TUBE; DIMENSIONS: ID 386 X OD 406 X LG 460 MM; MATERIAL: SICRO 23/20; DRAWING NO: F3G29792A REV 1; STEINMULLER F3G29792A REV 1; FOR AIR CORE.	Kindly confirm where will the burner tube tip be used. Please provide a drawing or any other additional information you may have.	It is used in the boiler, and it forms part of the boiler auxiliary parts. So, if you are familiar with the boiler, you should know. It does not have specific brand. Unfortunately, the drawing is Steinmüller property not Eskom.
102.	73622	4	BUSH: TYPE: LEAK OFF; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 95MM; LENGTH: 25 MM; MATERIAL: BRZ PHOSPHOR; DRAWING NO: 0.42092-EB REV 1	Please provide us with the brand, part number and a drawing or picture.	It does not have specific brand. Unfortunately, the drawing is Steinmüller property not Eskom. Please consult with them.
153	92715	300	PIN, GROOVED HEADLESS: LENGTH: 150 MM; DIAMETER: 25 MM; BURNER CENTRALISING, SICRO 23/20; MATERIAL: SS 310;	Please provide us with additional information including a drawing of the pin, brand and part number.	Material number is given and dimensions for the pin. If you're familiar with the burner components then this is won't be the problem for you.