


DETAIL - AIR VALVE WITH CHAMBER  
SCALE 1 : 10



SCOUR VALVE DETAIL  
SCALE 1 : 10

No.	DESCRIPTION
1	1 250 x 1000 CI SCOUR T
2	2 1000 Ø ISOLATING VALVE PN16
3	3 1000 Ø CI FLANGE ADAPTOR
4	4 110mm Ø uPVC SCOUR OUTLET WITH 45° BEND AND 2m LONG

DISCLAIMER:

"Should these drawings and Project Specifications be used or relied upon for any other purpose other than what they were intended for on this specific site, without G Seal Consulting' prior knowledge and written consent, then the user shall indemnify the copyright holder against all liabilities, claims, damages, losses, fines and/or penalties (either in contract or delict) instituted by the user or any other party as result of their re-use of or reliance on these drawings and project specifications."

NOTES:


0	19-10-23	BK	AK	ISSUED FOR TENDER PURPOSES
---	----------	----	----	----------------------------

REV	DATE	DRAWN	CHECK	DESCRIPTION
-----	------	-------	-------	-------------

DRAWING No	GS-185527-W-303	REVISION	0
------------	-----------------	----------	---

CONSULTANT



G SEAL CONSULTING  
Reg. No: 2016/300584/07

Unit No.3  
36 Van Rensburg Street  
P.O.Box 19692  
The Village, 1218  
Tel: 27 81 542 9422  
Fax: 27 86 273 1687  
e-mail: info@gseal.co.za

CLIENT



NKANGALA DISTRICT MUNICIPALITY

PROJECT

BULK WATER SUPPLY AND STORAGE AT HLALANIKHALE EXTENSION 5

DRAWING

AIR VALVE SCOUR VALVE CHAMBER

FOR TENDER

	SIGNATURE	DATE
DESIGNED	BK	08-10-2023
DRAWN	RB	08-10-2023
CHECKED	BK	08-10-2023
APPROVED	AK	08-10-2023

SCALE	AS SHOWN
-------	----------

PROJECT No.	DISCPL	DRG. NUMBER	STAGE	SHEET SIZE	REVISION
-------------	--------	-------------	-------	------------	----------

GS-185527	W	303	T	A1	0
-----------	---	-----	---	----	---

COPYRIGHT RESERVED