


NOTES

- (1) ALL NUTS & BOLTS TO BE BRASS OR STAINLESS STEEL. FLAT & SPRING WASHERS TO BE INCLUDED.
- (2) ALL SPARE TERMINALS TO BE INCLUDED.
- (3) ALL TERMINALS TO BE NUMBERED AS SHOWN.
- (4) MCB'S TO BE CURVE 1 ORANGE TOGGLE COMPLETE WITH SHROUDS AND CLIPS.
- (5) KIOSKS TO BE WIRED AS FOLLOWS –
- A) – WIRED FROM MAIN BUSBARS TO MCB LINE SIDE.
- B) – WIRED FROM METER'S LOAD SIDE TO METERS LINE SIDE.
- C) – METERS WILL NOT BE SUPPLIED WITH KIOSKS. SLACK ON CABLES SHALL BE PROVIDED FOR TERMINATIONS ONTO THE METERS.
- (6) THE THREE POINT LOCKING MECHANISM SHALL FIRMLY SECURE THE DOOR AND NOT ALLOW LEVERAGE FOR VANDALISM.

MANUFACTURING DRAWING

THE COPYRIGHT OF THIS PLAN AND DESIGN RESIDES WITH THE CITY OF CAPE TOWN AND MAY NOT BE REPRODUCED OR USED FOR ANY PURPOSE OTHER THAN IT WAS INTENDED FOR ORIGINALLY



CITY OF CAPE TOWN
ISIXEXO SASAKAPA
SIYAD KAPSTAD

C.C.T ELECTRICITY
SERVICES
DRAWING & RECORD CENTRE
ARCHITECTURAL/MECHANICAL SECTION
HEAD OFFICE BLOEMHOF ROAD
BELLVILLE, PRIVATE BAG 144 7535

DIRECTOR: ELECTRICITY	DR. L. RENCKOMRE
HEAD: ENGINEERING	E. CAPES
MANAGER: DRAWING & RECORD CENTRE	A. M. VAN ZYL
PROJECT TITLE	METER KIOSK, 12-WAY SPLIT METER (STEEL) (SAP: 200020452)
DIRECTOR: ELECTRICITY	DR. L. RENCKOMRE
HEAD: ENGINEERING	E. CAPES
MANAGER: DRAWING & RECORD CENTRE	A. M. VAN ZYL
PROJECT TITLE	METER KIOSK, 12-WAY SPLIT METER (STEEL) (SAP: 200020452)

APPROVED BY:	CHECKED	SHEET	REVISION No.	SHEET SIZE
COMPILED: A. HALL		09/03/2016		A1
SCALE: AS SHOWN				
DRAWING No.				
DR 3360		1 OF 2		