



NOTES

- (1) ALL NUTS & BOLTS TO BE BRASS OR STAINLESS STEEL. FLAT & SPRING WASHERS TO BE INCLUDED.
- (2) ALL SPARE TERMINALS TO BE INCLUDED.
- (3) ALL TERMINALS TO BE NUMBERED AS SHOWN.
- (4) MCB'S TO BE CURVE 1 ORANGE TOGGLE COMPLETE WITH SHROUDS AND CLIPS.
- (5) KIOSKS TO BE WIRED AS FOLLOWS –
A)– WIRED FROM MAIN BUSBARS TO MCB LINE SIDE.
B)– WIRED FROM MCB'S LOAD SIDE TO METERS LINE SIDE.
C)– WIRED FROM METER'S LOAD SIDE TO TERMINAL BLOCKS.
D)– COMMUNICATIONS CABLE WIRED FROM METER TO TERMINAL BLOCK.
E)– METERS WILL NOT BE SUPPLIED WITH KIOSKS. SUFFICIENT SLACK ON CABLES SHALL BE PROVIDED FOR TERMINATIONS ONTO THE METERS.
F)– METER CONNECTION CONDUCTORS & COMMUNICATIONS CABLE MUST BE LABELLED AS PER INSERT 'A'
- (6) THE THREE POINT LOCKING MECHANISM SHALL FIRMLY SECURE THE DOOR AND NOT ALLOW LEVERAGE FOR VANDALISM.




METER BOARD LAYOUT

SCALE 1:4




BUSBAR LAYOUT

SCALE 1:2



NEUTRAL & EARTH BAR DETAILS

SCALE 1:1



INSERT 'A' METER CONNECTION DETAIL

SCALE N.T.S

MANUFACTURING DRAWING

THE COPYRIGHT OF THIS PLAN AND DESIGN RESIDES WITH THE CITY OF CAPE TOWN AND MAY NOT BE REPRODUCE ISSUED OR USED FOR ANY PURPOSE OTHER THAN IT WAS INTENDED FOR ORIGINALLY



C.C.T ELECTRICITY SERVICES

DRAWING & RECORD CENTRE
ARCHITECTURAL/MECHANICAL SECTION
HEAD OFFICE BLOEMHOF ROAD
BELLVILLE, PRIVATE BAG X44 7535

DIRECTOR: ELECTRICITY	Dr. L. RENCONTRE
HEAD: ENGINEERING	E. CAPES
MANAGER: DRAWING & RECORD CENTRE	A. M. VAN ZYL PH (021) 444 8339

PROJECT TITLE	METER KIOSK, 4-WAY THREE PHASE METER (STEEL) (SAP: 200020414)
---------------	---

APPROVED BY:	CHECKED	
COMPILED: A. HALL		
SCALE: AS SHOWN	DATE: 06/04/2016	
DRAWING No. DR 3363	SHEET 2 OF 2	REVISION No.
		SHEET SIZE A1