



22 August 2025

NOTICE TO TENDERERS NO: 15

TENDER NUMBER: 277Q/2024/25

DESCRIPTION: Construction of a 300Ml Reservoir, Bulk Pipelines and Associated Infrastructure near Muldersvlei

EXTENDED CLOSING DATE: 23 September 2025 at 10:00am

BOX NUMBER: 209

Dear Sir/Madam

In terms of Clause **C.3.2: Issue Addenda** in the Tender Data, the City of Cape Town may if necessary, issue addenda in writing that may amend or amplify the tender documents to each tenderer during the period from the date the tender documents are available until one week before the tender closing time stated in the Tender Data. The Employer reserves its rights to issue addenda **less than one week before the tender closing time in exceptional circumstances**.

Your attention is specifically drawn to the amendments, which are to be made to the tender document for the above in terms of this addendum, which is issued in terms of Clause 3.2 of the tender document.

This notice to tenderers is an integral part of the Tender. This notice/addendum is to be signed by the tenderer and attached and/or included to the tender document submission and recorded on Schedule 22: Record of Addenda to tender documents.

This notice contains the following:

- 1) Clarifications

Tenderers should take note of the following:

1. CLARIFICATIONS

Requests for clarifications received since the issuing of Addendum number 14, and which don't require an addendum to the tender documentation, are addressed hereunder for the benefit of all tenderers.

Query 1:

Q: Can you please provide a clarification for the following:

Specified

External Glass:

Single Glazing - PG Smartglass - X1 Elite Low-E, as per SANS10400 and AAMSA. Glass thickness in accordance with TABLE 1 (PART N: GLAZING) of SANS10400.

From Glazing manufacturers:

According to AAAMSA regulations Low E single glaze glass is illegal in this region. Could you please let us know what your alternative will be?

A: To ensure AAMSA compliance, the following alternative must be used: PG SMARTGLASSX2, CLEAR, DOUBLE GLAZING AS PER SANS10400 AND AAMSA. GLASS THICKNESS IN ACCORDANCE WITH TABLE 1 (PART N: GLAZING) OF SANS10400 (OR EQUIVALENT).

Query 2:

Q: Could you please clarify:

Items B2.60 to B2.64 Concrete Casing (reinforced) - please forward a typical detail, or reference to a current drawing, for the concrete encasement of the pipes.

A: The tendered rates for all concrete encasement to ensure compliance with Subclause 4.3.7.1 of SPE-CC-7003 (incl. project specific amendments). See below drawing references relevant for each item:

B2.60 – Refer to drawings 1001757-2000-DRG-CC-2541 and 2544.

B2.61 - Refer to drawing 1001757-2000-DRG-CC-2544.

B2.62 - Refer to drawings 1001757-2000-DRG-CC-2577.

B2.63 - Refer to drawings 1001757-2000-DRG-CC-2541 and 2543.

B2.64 - Refer to drawings 1001757-2000-DRG-CC-2450.

Note, as per Subclause 4.3.7.1 of SPE-CC-7003: "Where no encasing width or height is given on the drawings, the encasement shall extend 300 mm above and below the pipe and 300 mm on both sides of the pipe."

TENDERERS ARE THEREFORE REQUESTED TO:

1. Record receipt of this Notice on Schedule 22: Record of Addenda to Tender Documents.

2. Tenderers must sign and return this Notice (append to the relevant returnable schedule) together with their completed tender document.

Failure to return a signed copy of the Addendum may result in the Tender being declared Non-Responsive.

Yours faithfully,

p.p. *SCM.Tender7*

.....

For: Director: Supply Chain Management

ACKNOWLEDGEMENT OF RECEIPT FOR AND ON BEHALF OF THE TENDERER: TENDER NO 277Q/2024/25

At.....on this.....Day of2024

Signature:.....

Name of Signatory:.....
(in ink and capitals)

TENDERER:.....
(Name of firm in ink and capitals)