

Clarification No. 6 (24.03.2025)

TENDER MPKRI11468GX: The Procurement and Installation Of 3x LP Heaters 4 For A Period Of 5 Years on An as and When Required Basis at Kriel Power Station.

Query

With reference to “474-12769 Tender Technical Evaluation Strategy for Kriel LP Heater 4 Replacement Project (Rev 1)”, Section 3 - Specific Requirements relative to the scope of work,

3.5 – Manufacturing conformity assessment module to be at least Module G as per SAMS 347 edition 3 Table 2...

- Please can you confirm the returnable that is required for this point 3.5. Will a nameplate photo be acceptable for this request?

Eskom Response

Only nameplate photo with information/particulars listed in PER Regulation 9 will be acceptable where name of the Contractor reflects as a name of manufacturer.

NB: A reminder that the communication platform is the Eskom e-tender portal and that of National Treasury and the responsibility of the tenderer to visit regularly for possible updates. Any revised documents after site meeting, clarification information and minutes will be uploaded as such.