

DESCRIPTION: THE RENTAL OF SEVEN (7) 500KVA GENERATORS FOR A (3.5) MONTHS PERIOD FOR TRANSNET SOC LTD (REG NO. 1990/000900/30) OPERATING AS TRANSNET PORT TERMINALS (HEREINAFTER REFERRED AS "TPT") FOR NGQURA CONTAINER TERMINAL (NCT) FOR A PERIOD OF THREE-HALF (3.5) MONTHS



Description		Scoring Criteria	Weighting	Score	Evidence	Comments
Eligibility Criteria						
Trade Test	The Service Provider shall submit a Trade test certificate for the artisan (Diesel Mechanic or Millwright), that is not less than 2 years qualified.	Yes: Trade test (Millwright or Diesel Mechanic) provided not less than 2 years qualified No: No Trade test (Millwright or Diesel Mechanic) supplied or certificate less than 2 years qualified.	Yes/No		Trade test certificate	
Technical Evaluation Criteria						
Company Experience	The Service Provider shall submit proof of past-experience in supply and rental of generators or similar previous executed works. The references shall include the following: company name, contact person, contract number, value and project description executed in the last five (5) years. The Service Provider to complete Returnable Schedule T1.	(5) or more references provided = 30 (4) reference provided = 20 (3) reference provided = 15 (2) reference provided = 10 (1) reference provided = 5 (0) reference provided = 0	30		Reference	
Technical Datasheet	The Service Provider shall submit seven (7) datasheets of the generators proposed to be used during the contract in line to the scope of work requirements. These must be attached to Returnable Schedule T2.	Submit (7) Technical Datasheet for each generator = 30 No submission of the technical datasheet = 0	30		Datasheets	
Maintenance Records	The Service Provider shall submit a full-service record of all mobile diesel generators with their various serial numbers, indicating that they have been maintained as per the particular OEM requirements. NB! In the event that the Mobile Diesel Generator is not yet due for its first maintenance intervention, proof in this regard to be send. *Note: Service Provider to submit a letter from the OEM or OEM Maintenance Manuals stipulating the maintenance requirements of the Mobile Diesel Generators being supplied. The maintenance records must be attached to Returnable Schedule T3.	Submit (5) Full Maintenance Record for each generator = 15 points No submission maintenance records or less than seven maintenance records = 0	15		Maintenance Records	
Technician CV and Experience	The Service Provider shall submit CV of the technician or artisan and qualifications having a minimum experience of two (2) years in generator or similar equipment. The CV must be attached to Returnable Schedule T4.	CV provided having an experience of (2) years = 10 No CV or CV submitted having an experience less than (2) years = 0	10		CV	
Generator Running Hour	The Service Provider to submit the manufactures or original manufacture equipment (OEM) certificate of each mobile generator that shows the year of manufacture of the generator. Furthermore, to provide generator running hours in a table form stating generator serial number and hours. The OEM generator certificates and running hours not exceeding 6000 hours must be attached to Returnable Schedule T5.	Submit (7) (OEM) certificate for each generator and running hours = 15 points No submission (OEM) certificate and running hours. Or running hours above 6000 hours or certificate above (5) years = 0 points	15		Certificate	

Minimum threshold = 70%

100

Compiled by:

Portia Ngqozo: Technical Manager

Date: 26.03.2026

Approved by:

Khulisa Mbenya: Engineering Manager

Date: 26.03.2026