

	Clarification questions E1184GXPOU SUPPLY AND DELIVERY OF TOP COVER BRONZE WEARING COMPONENTS AT DRAKENSBERG PUMPED STORAGE SCHEME	Unique Identifier	240-55105891
		Revision	1
		Revision Date	Once off issue
		Group Technology & Commercial	

All Tenderers

DESCRIPTION: Supply and delivery of top cover bronze wearing components at Drakensberg Pumped Storage Scheme

Question	Response
1. For the technical drawings supplied, will CAD files (Solid models) be made available for the company that wins the Tender?	No, the only drawings available is the Confidential drawings supplied after the signing of the NDA. No CAD files to be sent, even after Contract Award as control will not be possible.
2. Please confirm the material specification of the twist off bolt // Drawing No.: 18.48/U1/6235 is CuSn11P as per BS EN 1982:2024.	Yes. All information on all drawings is correct.
3. One of the mandatory requirements is the inspection by an AIA amongst other i.e. material certification 3.1, Material certificates from the Mill, radiographic tests etc. The AIA must be any certified Independent Inspection Authority or must be an Eskom pre-approved AIA?	When a contractor employs an AIA, they should be able to prove that the AIA's accreditation is still valid. This will be sufficient.
4. Kindly provide clarification regarding the material type specified for the bronze spares listed under Enquiry No: E1184GXPOU. Could you please confirm the exact bronze grade or standard required (e.g., LG2, SAE 660, PB1, PB2 or any other specification) to ensure compliance with your requirements?	Please refer technical specification that was provided with the tender publication.