









PALMIET PUMPED STORAGE
260MVA
16,5/400 kV
COOLING ONAN/ONAF
VECTOR GROUP YNd1

FLANGES AND VALVES DRILLED TO BS 4504 1969

ESCOM NUMBER 0.48/21903 rev 3

Palmiet 19-9-?1

SCANNED

3	Masses updated				
2	Holes on bus-duct flange added 0.ms 2920, 1450, 2890, 9138 1725, 2745, 5295, 4150, 9915 were 2875, 1325, 2795, 9070 1660, 2170, 5170, 3840, 9775	E.H	85	14
1	MARSH. KIOSK REPOSITIONED	L.D	85	06
		L.D	85	40

Accepted by dual control
Accepted for prod by
Design checked by
Drawing checked by
Drawn by A.L. D'arch
Iss by Dual TTM Year 85 Week 32
Description (English): OUTLINE DRAWING
Description (own language)
PR4713 8153
Revised
Sheet 1
Cont 2