

Supplier name:

Date of evaluation:

Evaluator name:

Substation metering cabinets and modules

The technical requirements for these items are based on the requirements as stipulated in 240-65292589

Clause	DESCRIPTION	Score	Comments
1	Cabinets		
1.1	Swing frame cabinet 2400(H) x 800(W) x 600(D)		
1.1.1	Manufactured to the requirements of 240-60725641: Specification for standard (19 inch) equipment cabinets		
1.1.2	Cabinets shall be sourced from Eskom accepted / contracted suppliers		
2	Metering modules - manufactured according to 240-65292589 and D-DT-5084		
2.2	Meter module – surface mount 4-way		
	Front plate:		
	· PK2 - 4 way test blocks		
	· Terminals		
	· Trunking		
	· Wiring		
	Horizontal Back plate:		
	· MCBs AC		
	· MCBs DC		
	· Terminals		
	· Trunking		
	· Wiring		
2.5	Meter module – 19" rack mount 6-way		
	Front plate:		
	· 19" rack for the fitment of two meters		
	· Essallec connector blocks		
	· PK2 - 4 & 6 way test blocks		
	· Terminals		
	· Trunking		
	· Wiring		
	Back plate:		
	· MCBs AC		
	· MCBs DC		
	· Terminals		
	· Trunking		
	· Wiring		
3	Voltage selection module D		
3.4	Voltage selection module D complete with:		
	· MCBs AC		
	· MCBs DC		
	· Voltage failure relays		
	· 3-way Latching relay		
	· Terminals		
	· Trunking		
	· Wiring		