

SECTION 2.1 SPECIFICATIONS**MINIMUM STANDARD TECHNICAL SPECIFICATIONS**

The Hessequa Municipality requires the successful Bidder to supply the following:

Four (4) New 600 litre Diesel Bowsers

The Diesel Bowsers mentioned above shall comply with the requirements of the Standard Technical Specification, as detailed in the tables below. Each item has its own specification table and should be filled in accordingly.

It must be noted that Schedule A of the table lays down the detailed minimum requirements of this Specification while Schedule B must be completed by the Tenderer providing guarantees and technical particulars of the equipment and materials offered. Failure by the Tenderer to complete Schedule B could invalidate the tender.

SCHEDULE A		SCHEDULE B	
1. 600L Plastic Diesel Bowser		Comply YES / NO	Page to Reference
1.1. Tank & Trailer			
1.1.1)	600 Litre Capacity Tank		
1.1.2)	Polyethylene Tank		
1.1.3)	Wheels: 195/14 Tyre Size		
1.1.4)	Spare wheel must be fitted on Trailer		
1.1.5)	Chassis Finish: Galvanised		
1.1.6)	Registered, Roadworthy and Microdotted		
1.1.7)	Fitted with number plate		
1.1.8)	Fitted with Hose brackets		
1.1.9)	Warning Diesel & Flammable Plates/Stickers Included		
1.2. Guarantee			
1.2.1)	Guarantee for at least 12 Months		
1.2.2)	All guarantees must be stipulated in the tender.		
1.3. Vehicle to be equipped with the following:			
1.3.1)	12V Electric Pump		
1.3.2)	Inline Filter		
1.3.3)	Durable Flow meter		
1.3.4)	Aluminium Diesel Pump Nozzle		
1.3.5)	3 meter (minimum) Fuel outlet Hose		
1.3.6)	Nozzle locking mechanism		
1.3.7)	4.5Kg Dry Chemical Powder Fire Extinguisher fitted with brackets.		

CONDITIONS OF THE TENDER

1. The Diesel Browsers must be licensed and registered to Hessequa Municipality with number plate fitted before delivery.
2. All guarantees must be stipulated in the tender. Details of the guaranteed must be supplied. (**Attach proof**).
3. The Diesel Browsers must be delivered within **FOUR (4) weeks or 20 Working Days** from date of appointment. The delivery period here stipulated shall form part of the contract and no delivery shall be accepted after the due date.
Delivery shall be at the following address:

Power Station
No.1 Hospital Street
Riversdale
6670

Failure to adhere to the above, may result in your tender being declared non-responsive.

DECLARATION,

I, THE UNDERSIGNED (NAME)
CERTIFY THAT THE INFORMATION FURNISHED ABOVE IS CORRECT. I ACCEPT THAT THE MUNICIPALITY
MAY ACT AGAINST ME SHOULD THIS DECLARATION PROVE TO BE FALSE.

AUTHORISED SIGNATURE:

NAME:

CAPACITY:DATE:

Initials of Service Provider's Authority: