

Description of procurement: Battery room Refurbishment**Enquiry Number:****Date:****Technical Evaluation criteria**

Criteria	Measurements Scoring	Returnable	Scoring
Accredited Battery plant installer /. refurbish	Yes = 1 No = 0	Provide prove	
Years' experience in the Battery plant operations field	Ten years or more = 5 Up to five years = 3 Less than one year = 1 None = 0	Provide prove	
Fire rating of the paint to be used	Minimum standard is 1 hour 2 hours or more =2 1 hour= 1 Less than 1 hour =0	Provide datasheet	
Cement screed fall	Fall of 1 :200 Yes = 1 No =0	As per schedule	
Screed color	Light Grey Yes =1 No =0	Provide datasheet	
Epoxy resistance to chemicals specifically : Sulphuric acid Potassium hydroxide	35 % Sulphuric acid resist 35 % Potassium hydroxide resist Yes = 1 No = 0	Provide datasheet	1
Epoxy thickness when dry	More than 5 mm = 1 Less than 5 mm =0	Provide data sheet or the proposed amount of layers that will be applied	1
	MAX is 12 and pass is 9 points	Pass rate of	75 %

Recommendation:**Evaluators:**