

LIST OF TEL. and DATA AUXILIARY FITTINGS	
SYMBOL	TYPE DESCRIPTION
	MAIN TELEPHONE DISTRIBUTION FRAME
	TELEPHONE OUTLET POINT
	MAIN TELEPHONE DRAWBOX
	TELEPHONE CONDUIT RUNS
	DRAWBOXES GENERALLY FOR BOTH SERVICES
	DATA HUB FOR COMPUTER SERVER
	COMPUTER DATA OUTLET POINT
	COMPUTER DATA CONDUIT RUNS
	POWER SNAKING RUNS
	COMPUTER CABLE BASKET RUNS

NOTES FOR COMPUTER and TELEPHONE RUNS

1. ALL COMPUTER CONDUIT RUNS to be
Minimum 25mm Diam.
2. TELEPHONE CONDUIT RUNS to be 20mm
Diam. unless otherwise indicated

CLIENT DEPARTMENT SIGNATURES		
FACILITY STAMP		
FACILITY MANAGER		
INFRASTRUCTURE MANAGER		
GENERAL MANAGER		
OFFICER OF PROFESSIONAL COMPLAINT		
Name	TILMAN PEI	12 November 2023
Signature	T J PEI	Date

T
CONSULTING ENGINEERS

TJNEL

CONSULTING ELECTRICAL ENGINEERS

PORT EDWARD

4295



WIMS NI: 044044 SOUTHERN REGION
PORT SHEPSTONE DEPARTMENT OF HEALTH
PORT SHEPSTONE PROVINCIAL HOSPITAL
NEW PSYCHIATRIC WARD

Drawing Description
**GROUND FLOOR
COMPUTER/IT and TELEPHONE
LAYOUT DRAWING**

Drawn: JN	Date: 12 November 2023
Scales: 	Revision:
Drawing number	SL 231 - CT2
DDPW Drawing number	WIMS ND 0000000/AD1
Stamped by Plans Approval Committee	

