

RFP 20/2025A: MAINTENANCE OF DIESEL GENERATORS IN SARS DATA CENTERS

QUESTIONS AND ANSWERS

#	QUESTION	SARS RESPONSE
1.	Kindly assist with detailed scope for maintenance of the generators.	<p>Kindly visit the SARS website and the National Treasury e-tender to access the published documents. The detailed specification is contained in Annexure A - Business Requirements Specification.</p> <p>RFP20/2025: Inspection, Maintenance, Break-fix, Upgrade and enhancement of SARS ICT Facilities Equipment South African Revenue Service</p>
2.	Kindly assist with the serial number of the generators.	<p>An official erratum containing this additional information will be issued on SARS website and e-tender:</p> <p>Lehae la SARS</p> <p>Gen A Engine make = Mitsubishi Type = S16R -PTA S/N = S1302</p> <p>Gen B Engine make = Mitsubishi Type = S16R -PTA2 S/N = S0815</p> <p>Gen C Engine make = Mitsubishi Type = S16R -PTA S/N = S0907</p> <p>Alberton Campus</p> <p>Gen 1 Engine make = MTU Type = 12V4000G23 S/N = 526106149</p> <p>Gen 2 Engine make = MTU Type = 12V4000G23 S/N= 526106147</p>