

## DESIGN AND BUILD OF THE FREIGHT WAREHOUSE REFURBISHMENT PROJECT FOR A PERIOD OF 16 MONTHS AT O.R. TAMBO INTERNATIONAL AIRPORT

### CLARIFICATION 3

**Tender Reference Number: ORTIA7818/2025/RFP**

Item No.	Query	Response
1.	Please can images and information be shared relating to fire pumps, fire pump room and fire tank systems	This will be part of the new works; a new fire water pump station and tanks are part of the new works.
2.	Is it possible to conduct an inspection of the existing Generator/s? Or, can the specifications and photographs of the installation be provided?	The second site inspection took place 25 <sup>th</sup> April 2025. See attached pictures. There is one existing generator servicing both the warehouses and the Cargo Agents building.
3.	Please can pictures of the roof be forwarded to us so we can assess the condition of roof ventilators?	See attached pictures. Bidders are also reminded that access to the roof is through the airside.
4.	We require access to the incoming water line and booster connection to the property.	The second site inspection took place 25 <sup>th</sup> April 2025. See attached pictures.