

**SUPPLY AND DELIVERY OF ELECTRICAL CABLES FOR METRORAL
GAUTENG REGION (GERMISTON)**

Name of the Bidder:

RFQ Number:



COMPLIANCE SPECIFICATION SHEET

1 SPECIFICATIONS OF THE WORK OR PRODUCTS OR SERVICES REQUIRED

| No. | Specification Description | Bidder's Compliance Response: (Yes/No) |
|-----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------|
| | ELECTRICAL CABLES MATERIAL | |
| 1.1 | CABLE, JUMPER; CLAMP TYPE RAIL AND LINE; TRANSMISSION 11 KV TO CLAUSES 8.0 AND 10.1.1.1 OF THE SPECIFICATION.COMPLETE WITH TO CLAUSE 10.3 AND THREE TO CLAUSE 10.2 ATTACHED TO EACH END. SPECIFICATION BBB 1679 VERSION 1, EQUIPMENT USED ON OHTE. | |
| 1.2 | CABLE, JUMPER; OVERALL LENGTH 15 M; LINE TO RAIL. TO CLAUSE 10.1.1.2 OF THE SPECIFICATION.COMPLETE WITH LINE CLAMP TO CLAUSE 10.2 AND RAIL CLAMP TO CLAUSE 10.3 ATTACHED TO EACH END.SPECIFICATION BBB 1679 VERSION 1, EQUIPMENT USED ON SUBSTATIONS. | |
| 1.3 | CABLE, JUMPER; OVERALL LENGTH 15 M; LINE TO RAIL. TO CLAUSE 10.1.1.2 OF THE SPECIFICATION.COMPLETE WITH LINE CLAMP TO CLAUSE 10.2 AND RAIL CLAMP TO CLAUSE 10.3 ATTACHED TO EACH END.SPECIFICATION BBB 1679 VERSION 1, EQUIPMENT USED ON SUBSTATIONS. | |
| 1.4 | CABLE, JUMPER; OVERALL LENGTH 15 M; LINE TO RAIL. TO CLAUSE 10.1.1.2 OF THE SPECIFICATION.COMPLETE WITH LINE CLAMP TO CLAUSE 10.2 AND RAIL CLAMP TO CLAUSE 10.3 ATTACHED TO EACH END.SPECIFICATION BBB 1679 VERSION 1, EQUIPMENT USED ON SUBSTATIONS. | |
| 1.5 | CABLE, POWER, ELECTRICAL; CONDUCTOR SIZE 50-95 MM2, FEATURES XLPE OUTDOOR, VOLTAGE RATING 11 KV, CORE QUANTITY 3; P/N: 1002HC SCOTCH 3M; SHRINK-SEAL; SWA, COMPLETE WITH COMPONENTS FOR TAIL LENTHS 380MM, LUGS NOT INCLUDED, TO QUOTED PART#, EQUIPMENT USED ON: EL AND P TERMINATION KIT. | |

**SUPPLY AND DELIVERY OF ELECTRICAL CABLES FOR METRORAL
GAUTENG REGION (GERMISTON)**



Name of the Bidder:

RFQ Number:

| | | |
|------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| 1.6 | CABLE, POWER, ELECTRICAL; CONDUCTOR SIZE 16 MM ² , FEATURES STRANDED COPPER CONDUCTORS, PVC INSULATED, VOLTAGE RATING 600/1000 V, CORE QUANTITY 4; PVC BEDDED. ECC/SWA PVC SHEATHED. 061012338 EQUIPMENT USED ON EL&P SPECIFICATION NUMBER SABS 1507. | |
| 1.7 | CABLE, POWER, ELECTRICAL; CONDUCTOR SIZE 25 MM ² , FEATURES STRANDED COPPER CONDUCTORS, PVC INSULATED, VOLTAGE RATING 600/1000 V, CORE QUANTITY 4; PVC INSULATED, PVC BEDDED. ECC/SWA, PVC SHEATHED. EQUIPMENT USED ON EL&P SPECIFICATION NUMBER SABS 1507. | |
| 1.8 | CABLE; TYPE AERIAL BUNDLE, DIAMETER 50MM SQ, SPECIFICATION VOLTAGE RATING 11KV, 3 CORE, 35MM SQ, MATERIAL G.S.W CATENARY XLPE INSULATED ON STANDARD WOODEN DRUMS RETICULATION UNDER BRIDGES ETC SABS 1339, LENGTH 500M. | |
| 1.9 | CABLE, POWER, ELECTRICAL; CONDUCTOR SIZE 35 MM ² , FEATURES XLPE-INSULATED, INDIVIDUALLY SCREENED CORES, STEEL GALV WIRE ARMoured, VOLTAGE RATING 6.35/11 KV, CORE QUANTITY 3; GRADE PVC AND GRAPHITE COATED STRANDED COPPER CONDUCTORS, EXTRUDED BEDDING, OUTER SHEATH TO BE INSULATED. | |
| 1.10 | CABLE, FIBER OPTIC; TYPE AERIAL SINGLE COATED MODE, FEATURES (OS2)9/25 MICRON ITU G652D, CABLE TYPE LOOSE TUBE, CORE QUANTITY 24. | |
| 1.11 | CABLE, FIBER OPTIC; TYPE AERIAL COATED SINGLE MODE, FEATURES (OS2) 9/25 MICRON ITU G652D, CABLE TYPE LOOSE TUBE, CORE QUANTITY 48. | |

SIGNED at _____ on this _____ day of _____ 2023.

Name: _____ Designation _____