

	<h2>Clarification Response</h2>	<p>Doc Ref: PSEV-16 Version Date: Sept 2019 Revision: 1 Page 1 of 2</p>
---	---------------------------------	--

TENDER CLARIFICATION

REQUEST FOR QUOTATION MOOKODI EXTENSION & 1ST 500MVA TRANSFORMER STRINGING & CABLING

Clarification 07	Request For Proposal No. E2621NTCSAMWP,
------------------	---

The following clarification is needed in response to queries and questions raised by Tenderers.

Clarification Request in **BLACK** and Clarification Response in **RED**

Items	Clarification / Discussion
01	<p>Section 3.1.2 in the Scope of Work, listed below, implies that the Employer shall free issue Conductors and clamps related to stringing for the 400kV & 132kV primary plant. However the BOQ BILL NO. 5 - STRINGING & CABLING & BILL NO. 6 - SUPPLY AND INSTALLATION OF CLAMPS & SPACERS do list the same equipment as to be supplied by the Contractor. Please kindly clarify this apparent conflict and if bidders should exclude the supply of these two sets of major materials.</p> <p>3.1.2. PRIMARY PLANT REQUIREMENTS</p> <p>Erection, earthing and Stringing of 400kV & 132kV Primary plant equipment are:</p> <p>Once the new foundation and the steel are erected by the civil contractor and suppliers of equipment has erected their equipment per bay, contractor will be required to do the stringing of all the primary plant equipment. All work must be carried out under dead conditions, will be on a scheduled outage. The contractor will install free issued the Post Insulators, Surge arresters and Auxiliary. <u>The contractor will be free issued with Conductors and clamps.</u> The contractor will find installed primary plant equipment (Current Transformers (CTs), Voltage Transformers (VTs), Isolators, Circuit breakers (CBs), Post Insulators (PIs) and line-trap) in the HV yards as per drawings. Stringing per bays will be as follows per bays according to drawings:</p> <ul style="list-style-type: none"> • Contractor to do earthing with flat copper (50x50mm) to all primary plant equipment and secondary plant equipment according to drawings and specifications. • Overhead wire to be installed to cover the new 132kV Tubular busbar. • Erection, Earthing and string of following:
01	<p>Cost all items on BOQ. Where is supply and install cost for all that. Where is install only cost for that.</p>

Items	Clarification / Discussion
02	<p>I hope this email finds you well. I have an enquiry regarding the tender number in the subject line above and the evaluation criteria. I cannot see where the evaluation criteria for this bid are in any of the attachments.</p> <ul style="list-style-type: none"> • Please clarify where to find information regarding the CVs and qualifications that we need to attach <ul style="list-style-type: none"> • The amount of references we need to include • Any other important compliance documents that need to be attached • Whether we need to attach all the drawings etc.
02	<p>For primary plant, the information is included in the attached documents. Was this part of the tender package</p>
03	<p>May you kindly advise on the correct closing date for this enquiry.</p> <p>We have noticed 2 dates: 29 May 2026 and 29 June 2026</p>
	<p>Please note that there was an error on the CIDB regarding the tender closing date, as two different closing dates were reflected. The issue has since been corrected, and the tender closing date has been extended to 05 June 2026.</p>