SPEC SHEET

SAP MATERIAL No.:	0180230
SHORT DESCRIPTION:	FUSEHOLDER,VERTICAL 3P 400A 440V D3409

TECH. DESCRIPTION:

FUSEHOLDER/BASE * VERTICAL *
TRIPLE POLE FOR DIN FUSE LINKS OF SIZE NH 02 *
SUITABLE FOR MOUNTING ONTO BUSBAR WITH 185mm BUSBAR SPACING *
RATED OPERATIONAL VOLTAGE : MIN. 440 V *
RATED INSULATION VOLTAGE : MIN. 690 V *
RATED IMPULSE WITHSTAND VOLTAGE : MIN. 8kV *
CONVENTIONAL ENCLOSED THERMAL CURRENT : MIN. 400A *
RATED OPERATIONAL CURRENT : MIN. 400A *
RATED UNINTERRUPTED CURRENT : MIN. 400A *
KIND OF CURRENT : 3 PHASE AC 50 Hz *
RATED DUTY : UNINTERRUPTED *
NUMBER OF POLES THREE *
NUMBER OF POSITIONS OF MAIN CONTACTS : 2 * IP 20 *
SUITABLE FOR ISOLATION *
DEPENDANT MANUAL OPERATION *
UTILISATION CATEGORY : AC-22B *
FULLY SHROUDED LIVE PARTS TO PREVENT ACCIDENTAL CONTACT
ON FUSES AND CABLE CONNECTION * CABLE CONNECTION : BOLTED *
LOAD BREAK * GANG OPERATED * INTEGRATED OPERATING HANDLE *
ESKOM DRAWING No. D-DT-3409 *

ITEM	:-	FUSEHOLDER,VERTICAL 3P 440V				
MATERIAL SPECIFICATION	:-					
CORROSION SPECIFICATION	:-					
STANDARD SPECIFICATION	:-	IEC 60947-3				
ESKOM SPECIFICATION	:-					
TEST & CERTIFICATION REQUIREMENTS	:-					
INSPECTION	Yes	No	ESKOM RELEASE NOTE	Yes	No	

IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS

REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	REF. DWGS
6	LOGO CHANGED AS PER NEW CORPORATE I.D.	D.D.N.	P.A.V.	P.A.V.	05.11.04	
5	800A FUSEHOLDER REMOVED AND REPOSITIONED TO D-DT-2409	P.A.V.	T.GILLARD	G.WHYTE	07.08.02	
4	160A FUSEHOLDER REMOVED AND TECHNICAL DESCRIPTIONS EXTENDED	P.A.V.	G.STANFORD	A. BEKKER	09.05.02	

AUTH:	P. CROWDY	DATE:	12.08.1999	SCALE NTS	Eskom Distribution	SAP No: 0180230	
CHKD:	A. ABROSIE	DATE:	12.08.1999	CAD REF:			
DRAWN:	P.A. VERMAAK	DATE:	11.03.1999	SERIES 3000 FILE No: 3409	**D-DT- 3409**	SET: 1	SHEET: 1 / REV: 6