



- NOTES:**
- 1) Concrete marker posts to be placed at an offset of 1m from centre line of pipe.
  - 2) When looking in the direction of water flow, concrete marker posts to be placed on the left hand side.
  - 3) Concrete marker posts must be placed at bends and tees on the pipeline.
  - 4) Concrete marker posts must be placed in line of site, so that the next marker post is visible from the previous marker post.

THIS DRAWING IS THE PROPERTY OF SDM CONSULTING ENGINEERS (Pty) Ltd.  
AND MAY NOT BE COPIED OR REPRODUCED EITHER WHOLLY OR IN PART  
WITHOUT THE WRITTEN PERMISSION OF THE AFOREMENTIONED COMPANY

THIS DRAWING IS NOT TO BE SCALED. FIGURED DIMENSIONS ONLY ARE TO BE FOLLOWED. ADDITIONAL DIMENSIONS, WHEN REQUIRED, WILL BE PROVIDED UPON REQUEST. CONTRACTORS ARE TO CHECK ALL DIMENSIONS BEFORE WORK COMMENCES AND REFER ANY DISCREPANCY TO THE ENGINEER FOR ADJUSTMENTS.

DRAWING No.		REFERENCE DRAWINGS :	

  

A	FEB 2023	ISSUED FOR INFORMATION	G.S
NO.	DATE	REVISION	DRAWN

ISSUED FOR TENDER

CLIENT



MHLATHUZE WATER  
CORNER BATTERY BANK, S CENTRAL ARTERIAL  
RICHARDS BAY  
TEL: (035) 902 1000  
FAX: (035) 902 1111



UMKHANYAKUDE DISTRICT MUNICIPALITY  
STAND 13433, KINGFISHER RD PORTION 7  
REMAINDER OF HARLINGEN FARM  
RICHARDS BAY  
3900  
TEL: (035) 573 8600  
FAX: (035) 573 1094

CONSULTING ENGINEERS



SUITE 306 GRANADA SQUARE  
16 CHARTWELL DRIVE  
UMHLANGA ROCKS  
4320  
TEL: +27 (0) 31 561 1431

PROJECT

# REFURBISHMENT AND AUGMENTATION OF WATER SUPPLY SCHEMES WITHIN JOZINI LOCAL MUNICIPALITY

DRAWING TITLE
---------------

STANDARD DRAWINGS PIPE MARKER

		SIGNATURE FOR FLUX/SDM	DATE	PR.No.	SHEET SIZE <b>A0</b>  SCALE AS SHOWN  DWG STATUS P P = PRELIMINARY C = CONSTRUCTION
DESIGNED	M.T		FEB 2023		
DRAWN	C.S		FEB 2023		
CHECKED	N.N		FEB 2023		
APPROVED					
CO-ORDINATOR					

FLUX/S.D.M. DRAWING NUMBER

UKDM/0044/01/K

REVISION No  
**A**

SDM-DRAWING No.  
COPYRIGHT RESERVED