

SULPHURIC ACID LINE
DRAWING No. 0.84/4740

DEMIN WATER LINE
DRAWING No. 0.84/4740

0 OGDE04
BR003

0 OGDK45
BR047

0 OGDE08/0 OGDE09 CF501
CALIBRATION COLUMN : 2 OFF

0 OGDE08 AP011/AP021
SULPHURIC ACID DOSING PUMP : 2 OFF
CAPACITY : 0-50 l/h
PRESSURE : 200 kPa
MOTOR : 0,18 kW
WET PARTS M.O.C. : PTFE DIAPHRAGM

0 OGDE09 AP011/AP021
SULPHURIC ACID DOSING PUMP : 2 OFF
CAPACITY : 0-500 l/h
PRESSURE : 200 kPa
MOTOR : 0,75 kW
WET PARTS : PTFE DIAPHRAGM

0 OGDE08 AA635/0 OGDE09 AA651
PULSATION DAMPNER : 2 OFF

AS BUILT
Signed *Adarsh* Date 15/2/2018

SOUTH AFRICAN WATER TECHNOLOGY GROUP

Linkview
260 Kent Avenue
Randburg
P.O.Box 3597
Randburg
2125

Tel.: +27 11 886-0266
Fax.: +27 11 886-0294
E-Mail: info@aquas.co.za

D.O.	REV	DATE	INDEX REFERENCE	REV BY	CHD BY	APP BY	KKS APP	REFERENCE DRAWINGS
	11	13.02.18	AS BUILT	N.A.S.	N.M.	J.P.	J.V.	
	10	22.08.12	KKS NUMBERS CHANGED.	TPS	J.C.	P.M.	J.V.	
	9	28.11.11	UPDATED TO SUIT LAYOUT	S.M.	J.P.	P.M.	J.V.	
	8	15.09.11	PIPE MATERIAL SPECS CHANGED	S.E.	J.O.G.	P.M.	J.V.	
	7	09.06.11	PREVIOUS REV. INDICATED AS REQUESTED	Mega	B.R.	P.M.	J.V.	
	6	09.05.11	GENERAL UPDATE	R.H.	P.M.	F.F.	J.V.	
			** REVISION **					

DRG REGISTER	25.05.09	J.V.		DATE
DESIGN APPROVED	25.05.09	F.F.		
KKS APP	25.05.09	J.V.		
DO AUTH	25.05.09	J.H.		
CHD BY	25.05.09	Y.K.		
DRAWN BY	25.05.09	S.M.		
SCALE	NTS			

MEDUPI POWER STATION
WTP ~ SYSTEM 5
SULPHURIC ACID DOSING SYSTEM 1
P. & I. DIAGRAM

C048-51011

0.84 / 4739

SHEET	SHEET	REV
		11