

Type	Image	Description	Installation	Lamps		Qty	Location	Comments
				Type	Colour			
A / Ae		LED Highbay fitting (IP66) complete with marine grade high pressure die-cast aluminium and acrylic PMMA, polycarbonate clear (159 lumens per watt and CRI 70+). Complete with 6amp plug top and 3m cordset. 5 year warantee. - Optic 4140	Suspended	203W LED	4000K		Warehouse	BEKA ECOBAY or equal and approved
B / Be		Surface mounted bulkhead fitting. (1 hour self contained emergency version where indicated. Supplied complete with 3m cordset and 5A plugtop.) Complete with 5 year warantee	Surface Mounted	17W LED	4000K		External	BEKA SERIES 30 or equal and approved
C		LED Linear vapour proof fitting (IP65), with poly carbonate UV protected diffuser and stainless clips. (160 - 180 lumens per watt and CRI 80+). Complete with 5 year warantee	Surface Mounted	46W LED	4000K		Strong Room / Service Ducts etc	BEKA VAPOUR LINE or equal and approved

Notes

Samples of all luminaires are to be presented for approval before orders are placed.
Quantities are to be confirmed by contractor
Lamps to be Osram ,Phillips or equal and approved. Control gear to be Osram, Phillips, Tridonic, V&S or equal and approved . Full details to be submitted with sample.

A 0	GENERAL REVISION	KS KS	28/01/26 15/01/26	MK MK	ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE: DPWI Ulundi Legislative Building Luminaire Schedule	 <small>IBUYA Consulting Engineers</small> <small>POWERING DEVELOPMENT</small> <small>ESSEX PARK 46 ESSEX TERRACE WESTVILLE P.O. BOX 1692 WANDBECK 3631</small> <small>TEL: +27 (031) 2667831 FAX: +27 (031) 2667831 E-mail: ibuya@ibuya.co.za</small>
	ORIGINAL ISSUE				PROJ No.:	DWG No	REV	SCALE			
REV	DESCRIPTION	BY	DATE	CHKD	FILE NAME:	25024_601_A	SHEET:	1 of 1			