



#### Type. A

Crealco Swift 38 or eq. approved side hung aluminium casement window, per layout. Casement sash 700 x 1500mm max size. Fixing lugs suitable for fixing to plastered brickwork reveals.

#### Exposure

AAAMSA exposure category: A3. SANS613 - 2000Pa wind load capacity

#### Coating:

Class 2 powder coated to SANS 10322:2014; Coatings in accordance with SANS 1796 using powders in accordance with SANS 1578.

#### colour:

TBC. Provisionally Mat Black

#### Furniture

500mm Stays, 13mm stack, capacity 26Kg. Crealco code STF-TH500DE-304 Defender Stay or equal app

Handles - Per manufacturers specification to suite operation indicated.

#### Glazing

Glazing throughout to be 6,38mm thick normal strength PVB laminated Low E safety glass

#### SHGC

Req. 0.57 per PG Glass E-Range Solarvue Neutral SHG (or equal approved)

#### U-Value

Req. 5.8 W/m².K (system) Glazing - 3.7 W/m².K

**Mesh security screen:** NIL

Blinds / Curtains: NIL

QUANTITY:	No Blinds / Mesh	Incl Blinds	Incl Security Mesh	Incl Mesh and Blinds
1	WB1			
	-			

#### NOTES:

- ALL DIMENSIONS TO BE CHECKED ON SITE PRIOR TO MANUFACTURE.
- WINDOWS DRAWN AS VIEW FROM EXTERIOR.

#### REVISIONS

Rev.	Date	Description	By
A	2024.08.06	Window & description updated.	PD

#### PROJECT:

PORT SHEPSTONE HOSPITAL  
NEW PSYCHIATRIC WARD

#### Architect:

ARTEK 4 ARCHITECTS (KZN) CC

Durban: 46 Lena Ahrens Road, Glenwood, Durban 4000

tel: 031 201 0445 fax: 031 201 6609 email: admin@artek4.co.za

Port Shepstone: 19 Tradewinds, Marine Drive, Shelly Beach

tel: 039 682 2447 fax: 039 682 2446 email: admin@artek4.co.za



#### DRAWING DESCRIPTION:

WINDOW SCHEDULE  
WINDOW TYPE A

Scale	Date	Drawn	Project No.	Drawing No.	Rev.
1:25	14.11.2022	WP	1518	401-1	A