



- Note:
- 1)Concrete grade 35/13
  - 2)All smooth finish
  - 3)Letter "V" embossed 5mm deep in position indicated (Letter width 10mm)
  - 4)Letter size for distance and type of of watermain to be 4 cm high and 8mm thick and positioned as shown.
  - 5)Blue band to be painted on marker as shown to indicate a RSV.
  - 6)The inside of No. 5 valve cover to be painted blue. (For RSV)

## ETHEKWINI WATER & SANITATION

Drawn by:

Checked by:

Date: Nov 2004

Manager(WD):

PRECAST CONCRETE

VALVE MARKER

Exec. Dir. (Water & Waste)

27

Plan No. ....