	SOW	Camden Power Station
---	------------	-----------------------------

Title: **BOILER AUXILIARIES
MAINTENANCE CONTRACT
SCOPE OF WORK**

Document Identifier: **229-T2540**

HBS / Functional Location (Technical Docs): **BOILER**

Area of Applicability: **Boiler**





Functional Area: **Maintenance and Engineering**

Revision: **00**

Total Pages: **23**

Next Review Date: **(Once-off doc)**

Disclosure Classification: **Controlled Disclosure**

Compiled / Originator	Supported by	Functional Responsibility	Authorized by
			
K Chanda Engineer	P. Mthombeni Boiler Engineering Manager	M Mathabatha Engineering Manager	D Nyathikazi Boiler maintenance Manager
Date: 13/02/2024	Date: 13/02/2024	Date: 20/02/2024	Date:

Content

	Page
1. Introduction.....	3
2. Supporting Clause	3
2.1 Definitions and acronyms	3
2.2 Scope.....	3
2.3 Purpose.....	3
2.4 Effective date	4
2.5 Normative References.....	4
3. Document Content.....	4
3.1 Valve Recommendations.....	4
3.1.1 Boiler Plant Valve	5
3.2 Sootblower Maintenance	6
3.2.1 On-line inspections	6
3.2.2 Reporting.....	7
3.3 Sealing Trough	7
3.4 Pulverized Fuel Burners	8
3.5 Boiler Drum	11
3.6 Boiler Chemical dosing/sampling system.....	11
4. Development Team	11
5. Revisions.....	11
Appendix A1: Recommendations for Boiler Valves	12
Appendix A2: Sootblower and Sealing Trough Maintenance Recommendations	22

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/**30**

1. Introduction

The document serves as a Scope of Work (SOW) for boiler valve auxiliaries maintenance contract, therefore contains the recommendations of the Boiler Auxiliaries SE. The content covered in this document includes all Control Valves, Isolation Valves, Transmitter Valves, Sootblowers, Boiler Drum, Pulverized fuel burners and the sealing trough. Critical valves such as Control Valves (Feed Regulating and De-superheating Control Valves) and Boiler Drain valves are expected to require overhaul and therefore should be planned accordingly.

2. Supporting Clause

2.1 Definitions and acronyms

Acronyms

SE:	System Engineer
AIA:	Approved Inspection Authority
SOW:	Scope of Work
KKS:	Function Location
OEM:	Original Equipment Manufacturer
QC:	Quality Controller

Definitions

Good Engineering practise:	Scientific process by which a design, installation, operation/maintenance, or safety problem is systematically evaluated.
Boiler Auxiliaries:	Boiler Drum, Pulverized fuel burners, sealing trough, etc.

2.2 Scope

This specification outlines the maintenance requirements for boiler valve auxiliaries at the South African power station. It covers Control Valves, Isolation Valves, Transmitter Valves, Sootblowers, Boiler Drum, Pulverized fuel burners, and the sealing trough.

2.3 Purpose

This document provides detailed recommendations for maintenance activities concerning the boiler plant and its auxiliary components.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

2.4 Effective date

Date of signing

2.5 Normative References

240-126446767	Sootblower System Dry Run
240-65378602	Camden Stuck Sootblower Response Procedure
229-12303	Sootblower Operational Philosophy
004/9217	Operating Technical Specification – Boiler Plant

3. Document Content

3.1 Valve Recommendations

Good engineering judgement taking into account of safety must be exercised all the time. The Table 2 in **Appendix A1: Recommendations for Boiler Valves** presents the recommendations of the SE on Boiler Valves. The table contains the component name, the KKS and what need to be carried out on that component, i.e., inspection, repair, or overhaul. Lapping/packing and overhaul will dominate on the work to be carried out of the valves and these terms are defined below:

Overhaul

1. Remove the valve from position.
2. Dismantle valve.
3. Clean exterior of valve.
4. Clean interior of valve.
5. Clean components.
6. Inspect components.
7. Lap valve body seats / spindle seats. At least 80% sealing area is to be achieved across the seat before Eskom Engineering inspection.
8. Provide engineer with inspection report per valve (unless otherwise agreed upon), detailing all damaged components, pictures, repair recommendations, and external QC Name and Signature.
9. Repair or replace, if necessary, all damaged components as per engineering instruction in reference to above inspection report.
10. Reassemble valve using new consumables, if necessary
 - Lubricate valve.

Lapping / packing

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

1. Lapping to be done in accordance with the OEM guidelines
2. Only gland packing accepted and inspected by the SE and QC may be used.
3. No asbestos packing shall be used.
4. Graphite packing shall have anti-extrusion properties.
5. Pre-formed packing rings are the preferred option.
6. The valve refurbishment company must ensure that the gland packing rings are of the correct tolerance for the valve stuffing box and spindle. Any anomalies are to be discussed with the SE, AIA, and QC.
7. Correct packing methods must be used and approved by QC and SE.
8. A maximum of six (6) rings to be used per valve. If the desired compression is not obtained on the packing rings, Korute blocks, or carbon bushes are to be used within the bottom portion of the stuffing box to ensure that the correct radial forces are obtained on the valve spindle and stuffing box.

Good engineering practise to be always adhered to.

3.1.1 Boiler Plant Valve

A. Control Valves

- CCI drag valves are operated on the Attenuator Spraywater lines, as well as the feedwater regulator lines.
- On the Main Steam Warming lines, the control valves installed are Mitech valves.

B. Isolation Valves

- Spraywater Isolation valves should be cut out and sent for refurbishment during an outage or whenever necessary due to necessity on the plant.
- Isolation valves are found on the Attenuating Spraywater station, Feed regulating station, economizer ring, boiler drain valves and the main steam warming lines.
- Table 2 found in **Appendix A1: Recommendations for Boiler Valves** presents the recommendations of the SE on boiler valves. The recommendation must be executed during the period of an outage or as and when required.


C. Drain Valves

- Drain valves comprise of various sized globe valves (15mm, 25mm, and 50mm)
- It is essential that these valves be installed after refurbishment with the pressure boundary acting on the top of the valve seat to ensure tight isolation.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30



D. Air Heater Sootblower valves

- Each unit is equipped with 12 motorised globe valves.
- These valves are usually susceptible to steam cuts on the seat/plug and should be inspected and NDT's conducted on outage opportunity.

E. Other Valves

- Valves not discussed above do not require special consideration and should be maintained as per Table 2 in **Appendix A1: Recommendations for Boiler Valves**.

3.2 Sootblower Maintenance

The furnace Sootblower plant is expected to be monitored closely on a daily basis by the contractor in order to ensure correct operation and availability of the equipment.

3.2.1 On-line inspections

The contractor is expected to execute the following on the furnace sootblowers installed on each unit at least once monthly:

- On-line inspections for lance availability, oil leaks, misaligned support rollers etc.
- Perform/ oversee fault finding with the assistance of the Electrical Maintenance Department, and Control and Instrumentation Maintenance Department when Sootblower defect notification is loaded.
- Adjust blowing pressures when deemed necessary by SE.
- Perform any required mechanical repairs on the sootblowers.
- Conduct a dry run before commissioning of a unit after an outage as per 240-126446767.
- Retracting a stuck Sootblower.
- Fully commission sootblowers back into operation.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

- Any other work deemed necessary by SE within the SOW for sootblowers.

NB: In depth scope for sootblowers is attached on Table 3 found in Appendix A2: Sootblower and Sealing Trough Maintenance Recommendations

3.2.2 Reporting

Reporting shall form a crucial part of monitoring Sootblower daily performance and early identification of defect notifications. The contractor is required to send a report at least once weekly, detailing the below:

- Sootblower availability for each Sootblower on each unit as a percentage of available hours.
- Reasons for any permits taken on a Sootblower.
- Status of spares for the week
- All corrected defects for the week

3.3 Sealing Trough

Inspection of the sealing trough is required, and a detailed report should be handed to engineering at least once a month. All required repairs are to be done by the contractor.

Further detailed recommendations for the maintenance of the sootblowers and the sealing trough are listed in Table 3 found in Appendix A2: Sootblower and Sealing Trough Maintenance Recommendations

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

3.4 Pulverized Fuel Burners

Inspections of pulverized fuel burners are required, and any repairs should be conducted.

Table 1 PF Burner Activities

SUBSYSTEM		COMPONENT ACTIVITIES	
NO.	COMPONENT FLOC (KKS CODE)	TASK	ACTIVITY TYPE (INSPECTION / TEST / REFURBISH / REPLACE/OTHER)
1.		List of defects to be compiled and to be submitted to SE	
2.	HLA	Clean windbox of any accumulated ash – A to E row	
3.	HHA, HLA	Conduct the following inspections on the burners and windboxes, record and report to SE:	
1.1	HHA	Visually inspect PF nozzle and PF nozzle tip for any damage or high wear/erosive areas.	
1.2	HHA	In the event of indistinct visual inspections, conduct wall thickness tests on PF nozzle and PF nozzle tip to determine estimated operable hours.	
1.3	HHA	Visually inspect core air tube for any damage.	
1.4	HHA	Visually inspect secondary air rings for any damage/cracks or deformation.	
1.5	HHA	Visually inspect air registers for any damage.	
1.6	HHA	Visually inspect air register covering plate for any damage.	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

1.7	HHA	Visually inspect sliding sleeve damper for any damage.	
1.8	HHA	Visually inspect burner box around tube nest for any damage.	
1.9	HHA	Visually inspect burner scroll for any damage or high wear areas.	
1.10	HLA	Inspect windbox floor, roof and walls for any damage. Wall thickness measurements will be required in critical areas around burner flanges. Special attention to be given to expansion joints as well as plate covers on windbox floor.	
1.11	HHA	Inspect burner support brackets for any damage or deformation.	
1.12	HLA	Visually inspect windbox dampers for any damage or high wear areas. Defected dampers are to be repaired/replaced. Dampers are to seal completely and move without restriction when conducting stroke checking.	
1.13	HLA	Ensure that all windbox damper actuators are in the upright position, such that C&I have access to stroke check.	
4.	HHA	Replace or repair burner components as per engineering instruction	
5.	HHA	All PF scrolls to be lined with Ceramite	
6.	HHA	All core air swirlers to be cleaned.	
7.	HHA	All swirler directions to be verified before reinstallation (clockwise or anti-clockwise).	
8.	HHA	All swirler orientations to be verified before reinstallation. Flame scanner slot to be on the RHS (as seen from burner front), and slanted in the correct position “\”.	
9.	HHA	Set all burner sliding sleeve damper as follows:	
8.1	HHA	Sliding sleeve damper to be set and fixed at position 5 (Fully open)	
8.2	HHA	QC to verify that all sliding sleeve dampers are set at 40mm	
10.	HHA	Set all air register vanes as follows:	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

9.1	HHA	Air register vanes to be set in the 70% open position ~ 210mm ±10mm from heel of vane to tip of the next vane, in the correct direction.	
9.2	HHA	QC to verify that all air register vanes are set in the 70% open position and in the correct direction.	
11.	HLA	Stroke check windbox dampers as follows:	
10.1	HLA	Confirm the fully open limit and close limit by witnessing the dampers inside the windbox.	
10.2	HLA	Verify that indication on operator desk confirms the fully open and close limit from the plant.	
12.	HLA	All windbox pressure transmitter impulse lines to be blown through.	
13.	HBK	All furnace pressure transmitter impulse lines to be blown through.	
14.		Conduct final repair inspections from boiler front and from within the boiler.	
15.		Replace or repair components as per engineering instruction	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

3.5 Boiler Drum

The contractor will inspect and conduct repairs based on inspection findings and attend to any defects loaded. This includes executing outage scope of work.

3.6 Boiler Chemical dosing/sampling system.

The contractor will inspect and conduct repairs based on inspection findings and attend to any defects loaded. This includes executing outage scope of work.

4. Development Team

The following people were involved in the development of this document:

- Kampamba Chanda – Boiler SE
- Velaphi Vilakazi – Boiler SE

5. Revisions

Date	Rev	Remark	Compiler
13 February 2024	00	Original Issue	Kampamba Chanda

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Appendix A1: Recommendations for Boiler Valves

Table 2 Recommendations for Boiler Valves

No.	KKS Code	Description	Scope / Recommendations
DESUPERHEATING SYSTEM VALVES			
1	LAE31AA001	Left Hand Spraywater Control Valve	1. The valve linear drives must be checked for leak, the grease must be changed, and Engineer involved. 2. The valve must be striped and inspected by the engineer. new seal must be installed
2	LAE31AA002	Left Hand Spraywater By-Pass Control Valve	Inspect and Overhaul
3	LAE31AA101	Left Hand Spraywater Control Isolating Valve 1	1. Cut out & overhaul the valve. 2. Replace parallel slide spring. - Material: F22 - Design P:19.3 MPa - Design T: 218°C - Test P: 15 MPa
4	LAE31AA102	Left Hand Spraywater Control Isolating Valve 2	1. Cut out & overhaul the valve. 2. Replace parallel slide spring. - Material: F22 - Design P:19.3 MPa - Design T: 218°C - Test P: 15 MPa
5	LAE31AA103	Left Hand Spraywater To By-Pass Control Isolating Valve	1. Cut out & overhaul the valve. 2. Replace parallel slide spring. - Material: F22 - Design P:19.3 MPa - Design T: 218°C - Test P: 15 MPa
6	LAE31AA302	Left Hand Spraywater Flow Indicator Transmitter Isolating Valve 2	Inspect and Overhaul
7	LAE31AA303	Left Hand Spraywater Flow Indicator Transmitter Isolating Valve 1	Inspect and Overhaul
8	LAE31AA401	Left Hand Spraywater Station Air Release Valve	Inspect and Overhaul
9	LAE32AA001	Right Hand Spraywater Control Valve	1. The valve linear drives must be checked for leak, the grease must be changed, and Engineer involved.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
			2. The valve must be striped and inspected by the engineer. new seal must be installed
10	LAE32AA002	Right Hand Spraywater By-Pass Control Valve 2	Refurbish
11	LAE32AA101	Right Hand Spraywater Control Isolating Valve 1	- Refurbish valve. - Replace parallel slide springs
12	LAE32AA102	Right Hand Spraywater Control Isolating Valve 2	- Refurbish valve. - Replace parallel slide springs
13	LAE32AA103	Right Hand Spraywater To By-Pass Control Isolating Valve 3	- Refurbish valve. - Replace parallel slide springs
14	LAE32AA302	Right Hand Spraywater Flow Indicator Transmitter Isolating Valve 2	Refurbish
15	LAE32AA303	Right Hand Spraywater Flow Indicator Transmitter Isolating Valve 1	Refurbish
16	LAE32AA401	Right Hand Spraywater Station Air Release Valve	Refurbish
17	LAE32AA301	Right Hand Spraywater Pressure Indicator Transmitter Upstream To Spraywater Ring Isolating Valve	Refurbish
STEAM TRAP SYSTEM			
1	HAN21AA401	Left Hand Steam Trap Inlet Isolating Valve	Inspect and Overhaul per inspection findings.
2	HAN21AA402	Left Hand Steam Trap Outlet Isolating Valve	Inspect and Overhaul per inspection findings.
3	HAN21BZ001	Boiler Left Hand Steam Trap	Inspect and Overhaul per inspection findings.
4	HAN21AA403	Boiler Left Hand Steam Trap Drain Valve	Inspect and Overhaul per inspection findings.
5	HAN22BZ001	Boiler Right Hand Steam Trap	Inspect and Overhaul per inspection findings.
6	HAN22AA401	Boiler Right Hand Steam Trap Inlet Isolating Valve	Inspect and Overhaul per inspection findings.
7	HAN22AA402	Boiler Right Hand Steam Trap Outlet Isolating Valve	Inspect and Overhaul per inspection findings.
8	HAN22AA403	Boiler Right Hand Steam Trap Drain Valve	Inspect and Overhaul
FEEDWATER VALVES			
1	LAB50AA101	Feed Water Master Isolating Valve	Inspect and Overhaul
2	LAB50AA102	Feed Water Master Isolating Valve By-Pass Valve	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
3	LAB50AA301	Feed Water Flow Indicator Transmitter 3 After Orifice Isolating Valve	Inspect and Overhaul
4	LAB50AA302	Feed Water Flow Indicator Transmitter 3 Before Orifice Isolating Valve	Inspect and Overhaul
5	LAB50AA303	Feed Water Flow Indicator Transmitter 2 After Orifice Isolating Valve	Inspect and Overhaul
6	LAB50AA304	Feed Water Flow Indicator Transmitter 2 Before Orifice Isolating Valve	Inspect and Overhaul
7	LAB50AA305	Feed Water Flow Indicator Transmitter 1 After Orifice Isolating Valve	Inspect and Overhaul
8	LAB50AA306	Feed Water Flow Indicator Transmitter 1 Before Orifice Isolating Valve	Inspect and Overhaul
9	LAB50AA307	Feed Water Pressure Indicator Transmitter 1 Isolating Valve	Inspect and Overhaul
10	LAB51AA001	Feed Water Regulating Valve A	<u>Overhaul</u>
			- Material: A105
			- Design P:19.3 MPa
			- Working T: 218°C
			- Working P: 14.7 MPa
11	LAB51AA101	Feed Water Hydraulic Isolating Valve A By-Pass Valve	Inspect and Overhaul
12	LAB51AA102	Feed Water Air Release Valve 1A	Inspect and Overhaul
13	LAB51AA103	Feed Water Air Release Valve A	Inspect and Overhaul
14	LAB51AA201	Feed Water Hydraulic Valve A	Inspect and Overhaul
15	LAB51AA501	Feed Water Hand Isolating Valve A	Inspect and Overhaul
16	LAB52AA001	Feed Water Regulating Valve B	<u>Overhaul</u>
			- Material: A105
			- Design P:19.3 MPa
			- Working T: 218°C
			- Working P: 14.7 MPa
17	LAB52AA101	Feed Water Hydraulic Valve B By-Pass Valve	Inspect and Overhaul
18	LAB52AA102	Feed Water Air Release Valve 1B	Inspect and Overhaul
19	LAB52AA103	Feed Water Air Release Valve 2B	Inspect and Overhaul
20	LAB52AA201	Feed Water Hydraulic Valve B	Inspect and Overhaul
21	LAB52AA501	Feed Water Hand Isolating Valve B	Inspect and Overhaul
22	LAB52AA502	Feed Water Hand Isolating Valve B By-Pass Valve	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
23	LAE30AA101	Spraywater Direct Current Master Isolation Valve	Inspect and Overhaul
MAINSTEAM VALVES			
1	HAH41AA101	Boiler Left Hand Crown Valve	- The Valves must be overhauled. - The parallel slide springs must be replaced with new ones.
2	HAH42AA101	Boiler Right Hand Crown Valve	- The Valves must be overhauled. - The parallel slide springs must be replaced with new ones.
3	HAH41AA102	Boiler Left Hand Crown Valve By-Pass Valve 1	Inspect and Overhaul
4	HAH41AA501	Boiler Left Hand Crown Valve By-Pass Hand Isolating Valve	Inspect and Overhaul
5	HAH42AA102	Boiler Right Hand Crown Valve By-Pass Valve 1	Inspect and Overhaul
6	HAH42AA501	Boiler Right Hand Crown Valve By-Pass Hand Isolating Valve	Inspect and Overhaul
7	HAH42AA307	Boiler Right Hand Main Steam Flow Indicator Transmitter 3 Isolating Valve	Inspect and Overhaul
8	HAH42AA311	Boiler Right Hand Main Steam Flow Indicator Transmitter 1 First Isolating Valve	Inspect and Overhaul
9	HAH42AA312	Boiler Right Hand Main Steam Flow Indicator Transmitter 1 Isolating Valve	Inspect and Overhaul
10	HAH42AA314	Boiler Right Hand Main Steam Flow Second Local Pressure Indicator Transmitter	Inspect and Overhaul
11	LCQ13AA001	Main Steam Warming Control Valve L/H	Inspect and Overhaul
12	LCQ13AA101	Main Steam Warming Isolating Valve L/H	Refurbish
13	LCQ14AA001	Main Steam Warming Control Valve R/H	Inspect and Overhaul
14	LCQ14AA101	Main Steam Warming Line Isolating Valve	Refurbish
15	HAH41AA306	Boiler Left Hand Boiler Main Flow Indicator Transmitter 3 First Isolating Valve	Inspect and Overhaul
16	HAH41AA307	Boiler Left Hand Boiler Main Flow Indicator Transmitter 3 Second Isolating Valve	Inspect and Overhaul
17	HAH42AA301	Boiler Right Hand Steam Pressure Indicator Transmitter Isolating Valve 1	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
18	HAH42AA302	Boiler Superheater Pressure Indicator Main Isolating Valve	Inspect and Overhaul
19	HAH42AA303	Boiler Right Hand Steam Pressure Indicator Transmitter Isolating Valve 2	Inspect and Overhaul
20	HAH42AA304	Boiler Right Hand Steam Local Pressure Indicator Transmitter Isolating Valve	Inspect and Overhaul
21	HAH42AA305	Boiler Right Hand Steam Flow To Safety Valve Isolating Valve	Inspect and Overhaul
22	HAH42AA308	Boiler Right Hand Boiler Main Flow Indicator Transmitter 3 Isolating Valve	Inspect and Overhaul
23	HAH42AA309	Boiler Right Hand Boiler Main Flow Indicator Transmitter 2 Isolating Valve	Inspect and Overhaul
24	HAH42AA310	Boiler Right Hand Boiler Main Flow Indicator Transmitter 2 Isolating Valve	Inspect and Overhaul
25	HAH40AA101	Boiler 4Th Stage Superheater Outlet Vent Valve 1	Inspect and Overhaul
26	HAH40AA102	Boiler 4Th Stage Superheater Outlet Vent Valve 2	Inspect and Overhaul
27	HAH41AA301	Boiler Left Hand Steam Pressure Indicator Transmitter Isolating Valve	Inspect and Overhaul
28	HAH41AA302	Boiler Left Hand Boiler Main Flow Indicator Transmitter 1 First Isolating Valve	Inspect and Overhaul
29	HAH41AA303	Boiler Left Hand Boiler Main Flow Indicator Transmitter 1 Second Isolating Valve	Inspect and Overhaul
30	HAH41AA304	Boiler Left Hand Boiler Main Flow Indicator Transmitter 2 First Isolating Valve	Inspect and Overhaul
31	HAH41AA305	Boiler Left Hand Boiler Main Flow Indicator Transmitter 2 Second Isolating Valve	Inspect and Overhaul
32	LCQ14AA102	Steam Leg Drain To Hp Drain Vessel lv	Refurbish
33	LBA11AA101	Main Steam Leg Drain Valve 12	Inspect and Overhaul
BOILER DRUM			
1	HAD20AA101	Boiler Drum Air Release Isolating Valve	Inspect and Overhaul
2	HAD20AA301	Boiler Local Bi-Colour Water Isolating Valve	Inspect and Overhaul
3	HAD20AA302	Boiler Local Bi-Colour Steam Isolating Valve	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
4	HAD20AA303	Boiler Local Bi-Colour Condensating Pot Drain Valve	Inspect and Overhaul
5	HAD20AA304	Boiler Water Level Indicator Isolating Valve 1	Inspect and Overhaul
6	HAD20AA305	Boiler Steam Level Indicator Isolating Valve 1	Inspect and Overhaul
7	HAD20AA306	Boiler High Level Steam Main Isolating Valve 4	Inspect and Overhaul
8	HAD20AA307	Boiler High Level Low Pressure Isolating Valve 4	Inspect and Overhaul
9	HAD20AA308	Boiler Water Level Indicator Isolating Valve 2	Inspect and Overhaul
10	HAD20AA309	Boiler Steam Level Indicator Isolating Valve 2	Inspect and Overhaul
11	HAD20AA310	Boiler Water Level Indicator Isolating Valve 5	Inspect and Overhaul
12	HAD20AA311	Boiler Steam Level Indicator Isolating Valve 5	Inspect and Overhaul
13	HAD20AA312	Boiler Water Level Indicator Isolating Valve 3	Inspect and Overhaul
14	HAD20AA313	Boiler Steam Level Indicator Isolating Valve 3	Inspect and Overhaul
15	HAD20AA314	Boiler Drum Local Pressure Main Isolating Valve	Inspect and Overhaul
16	HAD20AA315	Boiler Drum Pressure Indicator Transmitter 1 Isolating Valve	Inspect and Overhaul
17	HAD20AA316	Boiler Drum Pressure Indicator Transmitter 3 Isolating Valve	Inspect and Overhaul
18	HAD20AA317	Boiler Drum Pressure Indicator Transmitter 2 Isolating Valve	Inspect and Overhaul
19	HAD20CL501	Boiler Local Bi-Colour Indicator	Inspect and Overhaul
20	HAN31AA401	Boiler Local Bi-Colour Drain Valve	Inspect and Overhaul
21	HAN31AA601	Boiler Local Bi-Colour Drain Non-Return Valve	Inspect and Overhaul
SOOTBLOWER VALVES			
1	HCB20AA101	Boiler Furnace Sootblowers Steam Supply Isolating Valve	Inspect and Overhaul
2	HCB20AA102	Boiler Furnace Sootblowers Steam Drain Valve	Inspect and Overhaul
3	HCB20AA301	Boiler Furnace Sootblower Drain Valve Pressure Indicator Transmitter Isolating Valve	Inspect and Overhaul
4	HCB10AA101	Boiler Air Heater Sootblowers Steam Supply Motorised Valve	Inspect and Overhaul
5	HCB41AA101	Boiler Left Hand Air Heater Sootblower 1 Steam Isolating Valve	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
6	HCB41AA102	Boiler Left Hand Air Heater Sootblower 2 Steam Isolating Valve	Inspect and Overhaul
7	HCB41AA103	Boiler Left Hand Air Heater Sootblower 3 Steam Isolating Valve	Inspect and Overhaul
8	HCB41AA104	Boiler Left Hand Air Heater Sootblower 4 Steam Isolating Valve	Inspect and Overhaul
9	HCB41AA105	Boiler Left Hand Air Heater Sootblower 5 Steam Isolating Valve	Inspect and Overhaul
10	HCB41AA106	Boiler Left Hand Air Heater Sootblower 6 Steam Isolating Valve	Inspect and Overhaul
11	HCB42AA101	Boiler Right Hand Air Heater Sootblower 7 Steam Isolating Valve	Inspect and Overhaul
12	HCB42AA102	Boiler Right Hand Air Heater Sootblower 8 Steam Isolating Valve	Inspect and Overhaul
13	HCB42AA103	Boiler Right Hand Air Heater Sootblower 9 Steam Isolating Valve	Inspect and Overhaul
14	HCB42AA104	Boiler Right Hand Air Heater Sootblower 10 Steam Isolating Valve	Inspect and Overhaul
15	HCB42AA105	Boiler Right Hand Air Heater Sootblower 11 Steam Isolating Valve	Inspect and Overhaul
16	HCB42AA106	Boiler Right Hand Air Heater Sootblower 12 Steam Isolating Valve	Inspect and Overhaul
17	HCB43AA101	Boiler Air Heater Sootblowers Steam Drain Valve	Inspect and Overhaul
18	HCB43AA301	Boiler Air Heater Sootblower Drain Pressure Isolating Valve	Inspect and Overhaul
19	HCB50AA601	Boiler Air Heater Sootblower Drains Non-Return Valve	Inspect and Overhaul
20	HCB51AA601	Boiler Furnace Sootblower Drain Non-Return Valve	Inspect and Overhaul
21	HCB10AA501	Boiler First Hand Master Isolating Valve	- Refurbish valve. - Replace parallel slide springs
22	HCB10AA502	Boiler Second Hand Master Isolating Valve	- Refurbish valve. - Replace parallel slide springs
AIRHEATER			
1	HCB41AA301	Boiler Left Hand Air Heater Steam Pressure After Reducer Pressure Indicator Transmitter Isolating Valve 1	Inspect and Overhaul
2	HCB41AA302	Boiler Left Hand Air Heater Steam Pressure After Reducer Pressure Indicator Transmitter Isolating Valve 2	Inspect and Overhaul
ECONOMIZER			
1	HAN11AA101	Boiler Economiser Left Hand Drain Valve	- Change parallel slide springs

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
2	HAN12AA101	Boiler Economiser Right Hand Drain Valve	Inspect and Overhaul
3	LAB60AA401	Economiser Ring Drain Valve 1	Inspect and Overhaul
4	LAB60AA402	Economiser Ring Drain Valve 2	Inspect and Overhaul
5	HAD20AA105	Boiler Economiser Recirculating Valve	- Cut out valves and refurbish. - Change parallel slide springs
6	LAB60AA602	Economiser Ring Non-Return Valve 2	Cut out valves and refurbish
7	LAB60AA601	Economiser Ring Non-Return Valve 1	Cut out valves and refurbish
CHEMICAL SERVICES VALVES			
1	LFN10AA501	Boiler Chemical Dosing Supply Line To Boiler Drum Main Isolating Valve	Refurbish
2	LFN10AA502	Boiler Chemical Dosing Supply Line To Boiler Drum Second Isolating Valve	Refurbish
3	LFN10AA503	Boiler Chemical Dosing Supply Line To Boiler Drum Third Isolating Valve	Refurbish
HEADER DRAINS			
1	HAN60AA401	Boiler Front Bottom Header Drain Valve 1	Inspect and Overhaul
2	HAN60AA402	Boiler Front Bottom Header Drain Valve 2	Inspect and Overhaul
3	HAN60AA403	Boiler Front Bottom Header Drain Valve 3	Inspect and Overhaul
4	HAN60AA404	Boiler Front Bottom Header Drain Valve 4	Inspect and Overhaul
5	HAN60AA405	Boiler Front Bottom Header Drain Valve 5	Inspect and Overhaul
6	HAN60AA406	Boiler Front Bottom Header Drain Valve 6	Inspect and Overhaul
7	HAN60AA407	Boiler Rear Bottom Header Drain Valve 7	Inspect and Overhaul
8	HAN60AA408	Boiler Rear Bottom Header Drain Valve 8	Inspect and Overhaul
9	HAN60AA409	Boiler Rear Bottom Header Drain Valve 9	Inspect and Overhaul
10	HAN60AA410	Boiler Rear Bottom Header Drain Valve 10	Inspect and Overhaul
11	HAN60AA411	Boiler Rear Bottom Header Drain Valve 11	Inspect and Overhaul
12	HAN60AA412	Boiler Rear Bottom Header Drain Valve 12	Inspect and Overhaul
13	HAN60AA413	Boiler Left Hand Bottom Header Drain Valve 13	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
14	HAN60AA414	Boiler Left Hand Bottom Header Drain Valve 14	Inspect and Overhaul
15	HAN60AA415	Boiler Left Hand Bottom Header Drain Valve 15	Inspect and Overhaul
16	HAN60AA416	Boiler Left Hand Bottom Header Drain Valve 16	Inspect and Overhaul
17	HAN60AA417	Boiler Right Hand Bottom Header Drain Valve 17	Inspect and Overhaul
18	HAN60AA418	Boiler Right Hand Bottom Header Drain Valve 18	Inspect and Overhaul
19	HAN60AA419	Boiler Right Hand Bottom Header Drain Valve 19	Inspect and Overhaul
20	HAN60AA420	Boiler Right Hand Bottom Header Drain Valve 20	Inspect and Overhaul
21	HAN60AA601	Boiler Water Wall Headers Non-Return Valve	Inspect and Overhaul
22	HAN70AA401	Boiler Blowdown Vessel Drain To A Station Drain Isolating Valve	Inspect and Overhaul
BLOWDOWN DRAINS			
1	HAN33AA101	Boiler Drum Blowdown Isolating Valve 1	Inspect and Overhaul
2	HAN33AA102	Boiler Drum Blowdown Regulating Valve 1	Inspect and Overhaul
3	HAN33AA401	Boiler Left Hand Drum Blowdown Main Isolating Valve	Inspect and Overhaul
4	HAN34AA101	Boiler Right Hand Drum Blowdown Isolating Valve 1	Inspect and Overhaul
5	HAN34AA102	Boiler Right Hand Drum Blowdown Regulating Valve 2	Inspect and Overhaul
6	HAN34AA401	Boiler Right Hand Drum Blowdown Main Isolating Valve	Inspect and Overhaul
7	HAN34AA402	Boiler Right Hand Drum Blowdown Main Isolating Valve	Inspect and Overhaul
SUPERHEATER DRAINS			
1	HAN41AA101	Boiler Left Hand Superheater Circulation Drain Valve 1	Inspect and Overhaul
2	HAN41AA102	Boiler Left Hand Superheater Circulating Drain Valve 2	Inspect and Overhaul
3	HAN42AA101	Boiler Right Hand Superheater Circulation Drain Valve 1	Inspect and Overhaul
4	HAN42AA102	Boiler Right Hand Superheater Circulating Drain Valve 2	Inspect and Overhaul
5	HAN42AA401	Boiler Right Hand Superheater Circulating Main Drain Valve	Inspect and Overhaul
6	HAN51AA101	Boiler Left Hand Primary Superheater Drain Valve 1	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

No.	KKS Code	Description	Scope / Recommendations
7	HAN51AA102	Boiler Left Hand Primary Superheater Regulating Drain Valve	Inspect and Overhaul
8	HAN51AA403	Boiler Left Hand Primary Superheater Main Drain Valve	Inspect and Overhaul
9	HAN52AA101	Boiler Right Hand Primary Superheater Drain Valve 1	Inspect and Overhaul
10	HAN52AA102	Boiler Right Hand Primary Superheater Regulating Drain Valve	Inspect and Overhaul
11	HAN52AA401	Boiler Right Hand Primary Superheater Drain Valve	Inspect and Overhaul
12	HAN52AA402	Boiler Right Hand Primary Superheater Drain Valve	Inspect and Overhaul
ATTEMPERATOR DRAINS			
1	HAN21AA101	Boiler Left Hand Attemperator Drain Valve 1	Inspect and Overhaul
2	HAN21AA102	Boiler Left Hand Attemperator By-Pass Drain Valve 2	Inspect and Overhaul
3	HAN21AA103	Boiler Left Hand Attemperator Vent Valve	Inspect and Overhaul
4	HAN22AA101	Boiler Right Hand Attemperator Drain Valve 1	Inspect and Overhaul
5	HAN22AA102	Boiler Right Hand Attemperator By-Pass Drain Valve 2	Inspect and Overhaul
6	HAN22AA103	Boiler Right Hand Attemperator Vent Valve	Inspect and Overhaul

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Appendix A2: Sootblower and Sealing Trough Maintenance Recommendations

Table 3 Sootblower and Sealing Trough Maintenance Recommendations

Plant Description		
1.	Coarse Ash Hopper/Sealing Trough	Remarks
1.1	Inspect target and hopper nozzles	
1.1.1	Clean blocked target and hopper nozzles	
1.2	Inspect external surface of hopper near seal trough to prevent ingress air intake, record, and report to ENG weekly	
1.2.1	Weld CS material to cracked and leaking external surface of hopper near seal trough	
1.3	Repair dipper plate to ensure proper sealing	
1.4	Clean sealing trough of any debris, drain/flush boiler sealing trough and fill up with water after flushing	
1.5	Refurbish ash hopper	
1.6	Perform any further work instruction as agreed between ENG and outage	
2.	Soot blowers	Remarks
2.1	Lance wall thickness measurements to be taken and report to Engineering.	
2.1.1	Replace worn lances	
2.2	Do dry run on each lance during commissioning to check for alignment INSIDE boiler	Lance to be checked from inside boiler to see if it's aligning and not scrapping or touching from both outside & inside boiler
2.22	Do dry run on each lance during commissioning to check for alignment OUTSIDE boiler	
2.23	Conduct soot blower lance travel test	
2.23.1	Verify that the pivot block and cam assemblies are correctly setup to ensure that the poppet valve only opens once the lance is through the boiler wall	
2.24	Verify the condition of the wall boxes	
2.24.1	Inspect wall sleeves and boxes for correct length, damage and condition of refractory and rectify	
2.24.2	Replace all missing and worn wall sleeves	
2.25	Monitor sootblower performance by doing on-load inspections and off-load inspections.	Issue report weekly to engineering.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Plant Description		
2.26	Poppet valve links to be adjusted to correct position	
2.27	Replace all pressure switches and limit switches ensuring positioning and timing is correct	
2.28	Replace all worn soot blower front support rollers	
2.27	Record soot blower poppet pressures:	
2.27.1	Install pressure gauges as per sketch 1	As per mod- BLR-023
2.27.2	Ensure that elbow of Air relief vent is not facing walkways	
2.28	Visually inspect drain system valves and pipework, record defects	
2.28.1	Replace passing poppet valves according to defect system and submitted SOW	
2.29	Repair all defects as per on SAP system	Draw latest defects list and report to boiler engineering
2.3	Perform any further work instruction as agreed between Eng and maintenance	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd, Reg No 2002/015527/30