

RECORD OF ADDENDA TO BID DOCUMENTS

BID DESCRIPTION	REQUEST FOR QUOTATION FOR THE APPOINTMENT OF A SERVICE PROVIDER FOR MINOR REPAIRS AND MAINTENANCE TO PLUMESTEAD CLINIC (INTSIKA YETHU SUB-DISTRICT))) IN CHRIS HANI DISTRICT		
SCMU NUMBER	SCMU3-P25/26-0719-IYL		
I / We confirm that the following communications received from the Department of Health before the submission of this tender offer, amending the tender documents, have been taken into account in this bid offer: (Attach additional pages if more space is required)			
Item	Date	Title or Details	No. of Pages
1	03/06/2026	CEILINGS -CHANGE OF UNIT OF MEASUREMENT	01
2	03/06/2026	FLOOR COVERINGS -REVISION OF MATERIAL DESCRIPTION (VINYL SHEETING TO VINYL TILE)	01
3			
4			
5			
6			
7			
8			
9			
10			

Attach additional pages if more space is required.

Signed _____ Date _____

Name _____ Position _____

Bidder Name _____

Item	Description	Uom	Quantity	Rate	Amount
	<u>SECTION NO. 2 : Building Work</u> <u>BILL NO.3 : CEILINGS PARTITIONS AND ACCESS FLOORING</u> <u>PREAMBLES</u> <u>For Preambles refer to " Department of Public Works & Infrastructure: Specification of materials and methods to be used-PW371"</u> <u>SUPPLEMENTARY PREAMBLES</u> <u>Proprietary products in descriptions</u> <u>Proprietary products shall be used as specified. Substitute products of similar quality and specification may only be used with prior approval by the Principal Agent.</u> <u>Ceilings</u> Unless otherwise described ceilings shall be deemed to be horizontal <u>Fixing</u> Items described as nailed shall be deemed to be fixed with hardened steel nails or pins, or to be shot-pinned, to brickwork or concrete Items described as plugged shall be deemed to include screwing to fibre, plastic or metal plugs at not exceeding 500mm centres, and where described as bolted, the bolts have been given elsewhere <u>CEILING CONSTRUCTION, CORNICES, ETC.</u> <u>6.4 mm thick gypsum ceiling boards (to comply with SABS 266-1982 or later revision) installed with longer lengths to suit room configurations with pre-painted "H" profile cover strips and fixed at right angles to timber branderling with all necessary accessories to strict manufacturer's specifications.</u>				
1	Ceilings including 38 x 50mm sawn softwood branderling at 400mm centres with cross branderling at joints, ends of sheets and at light fittings, etc.	m2	80,00	R	-
2	Extra over for hinged trap door size 600 x 600mm.	No	1,00	R	-
3	75mm Wide 'Gypsum" coved cornice plugged to walls including mitres, etc.	m	60,00	R	-
Carried to Section Summary 2					R -

Item	Description	Uom	Quantity	Rate	Amount
	<u>SECTION NO. 2 : Building Work</u>				
	<u>BILL NO.4 : FLOOR COVERINGS</u>				
	<u>PREAMBLES</u>				
	For Preambles refer to "Department of Public Works & Infrastructure: Specification of materials and methods to be used-PW371"				
	<u>SUPPLEMENTARY PREAMBLES</u>				
	<u>Proprietary products in descriptions</u>				
	Proprietary products shall be used as specified. Substitute products of similar quality and specification may only be used with prior approval by the Principal Agent.				
	<u>Semi flexible vinyl tiles</u>				
	Standard heavy-duty flexible vinyl floor tiles, 300 mm × 300 mm × 2 mm thick, manufactured in accordance with EN 649, laid in acrylic adhesive spread with a trowel on suitably prepared subfloor in accordance with SANS 10070,				
1	On floors	m2	10,00	R	-
	<u>POLISH, SEALERS, ETC</u>				
	Thoroughly clean and clear existing vinyl floor cover by removing dirt, stains, wax build up and contaminants using approved cleaning agents and scrubbers. Rinse and allow to dry completely. Apply three coats water based copolymer emulsion or other approved sealer				
2	on vinyl flooring	m2	400,00	R	-
Carried to Section Summary 2					R -