

# SPEC SHEET

SAP MATERIAL No.:	0400391						
SHORT DESCRIPTION:	S/ARR S/CL 22kV MCOV 24kV 31 D6215						
TECH. DESCRIPTION:  SURGE ARRESTER * STATION CLASS GAPLESS METAL OXIDE * FOR APPLICATION ON 22kV NON-EFFECTIVELY EARTHED SYSTEMS IN CORROSIVE ENVIRONMENTS * POLYMER HOUSED * MINIMUM MCOV : 24kV * MAXIMUM RESIDUAL VOLTAGE : 85kV * DISCHARGE CURRENT : 10kA * IEC - LINE DISCHARGE CLASS 2 * CREEPAGE : 31mm/kV * ESKOM DRAWING No. D-DT-6215 *							
SAP MATERIAL No.:	0187065						
SHORT DESCRIPTION:	S/ARR S/CL 22kV MCOV 24kV 20 D6215						
TECH. DESCRIPTION:  SURGE ARRESTER * STATION CLASS GAPLESS METAL OXIDE * FOR APPLICATION ON 22kV NON-EFFECTIVELY EARTHED SYSTEMS IN NON-CORROSIVE ENVIRONMENTS * POLYMER HOUSED * MINIMUM MCOV : 24kV * MAXIMUM RESIDUAL VOLTAGE : 85kV * DISCHARGE CURRENT : 10kA * IEC - LINE DISCHARGE CLASS 2 * CREEPAGE : 20mm/kV * ESKOM DRAWING No. D-DT-6215 *							
ITEM	:- S/ARR S/CL 22kV MCOV 24kV 31 D6215						
MATERIAL SPECIFICATION	:- DSP 34-419						
CORROSION SPECIFICATION	:- DSP 34-419						
STANDARD SPECIFICATION	:- IEC 60099-4						
ESKOM SPECIFICATION	:- DSP 34-419						
TEST & CERTIFICATION REQUIREMENTS :- DSP 34-419							
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No
IDENTIFICATION:- DSP 34-419							
10	SAP 0004627 CORRECTED			P.A.T.	D.RAMJASS	D.RAMJASS	25.01.2017
9	ALL SPEC'S CHANGED			P.A.T.	R.THERON	A.le ROUX	03.11.09
8	SPEC SCSSCAA00 CHANGED TO DISSCAA00			VvZ	C.B.C.	C.CLARK	23/06/2006
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
						REF. DRAWINGS	
AUTH:	PHIL CROWDY	DATE:	06/97	SCALE NTS		SAP No:	
CHKD:	C.B. CLARK	DATE:	06/97	CAD REF:		0400391	
				SERIES 6000		0187065	
DRAWN:	J.F.SCHOLTZ	DATE:	10/96	FILE No:		SET	
				6215		1	
				 <b>D-DT-6215</b>		SHE ET	
						REV	
						10	