

CLARIFICATION No. 8

Date: 10.04.2024

Ref: Clarification 8

Enquiries: Thabile Sibiya

Tel: 031 710 5396

Email: sibiyaTh@eskom.co.za

RE: KZN113

The Manufacture, Test and Supply of various Medium and Low Voltage Cable Accessories on an “as and when” required basis for various Regional Distribution Centres located in the Central East Cluster (KwaZulu Natal and Free State Operating Units) over a period of thirty-six (36) months. Rotek will be responsible for transportation of the goods.

ITEM	Supplier Query	ESKOM response to clarification query
1	I need to know who is supplying the cable and material, e.g., joints and terminations for the training because that will influence the pricing.	<p>Eskom will supply the cable. Tenderers are to supply the accessories as stated in the TECHNICAL EVALUATION CRITERIA (Dated 17 November 2023)</p> <p>ADDENDUM FOR CENTRAL EAST CLUSTER MV AND LV CABLE ACCESSORIES point p) Clause 3.2.g of Eskom 240-56030619 Rev 3 states: “The supplier shall include a jointer training proposal or offer as part of any tender submission.” This clause shall be interpreted as follows:</p> <p>Each successful tenderer shall be required to perform a full practical demonstration of the application of the following MV cable accessories:</p> <ol style="list-style-type: none">1. A Transition joint.2. A type 4 termination; and3. A Trifurcating joint. <p>These sessions shall be used to ensure that all MV jointers used in the cluster are familiarized with the installation instructions and any product</p>

		<p>specific detail required to install the accessories correctly. Each session shall accommodate thirty (30) jointers who will actively participate in the demonstration under the supervision of the original equipment manufacturer (OEM).</p> <p>The tenderer shall supply the accessories as part of the demonstration. The smallest range taking accessory shall be used for the demonstration;</p>				
2	<p>Where exactly will the training take place, for accommodation purposes?</p> <p>Where will the Home Centre be?</p>	<p>a) For KZN the Eskom Home Center will be Eskom offices in New Germany, 25 Valley View Road, KZN(GPS coordinates - 29.802493136795977, 30.88112586725587) and the training site will be Eskom training center Mersey, New Hanover KZN (GPS coordinates - 29.39419187492646, 30.47890426724022)</p> <p>b) For Free State OU the Eskom Home Center will be Eskom Bloemfontein 120 Henry Street, Free state (GPS coordinates - 29.111309999058477, 26.20528853839354) and the training site will be Eskom Alma, Welkom, Free State (GPS coordinates - - 27.930081728150547, 26.750478462601794)</p> <p>The rate payable by Eskom will be from the Eskom home centers to the Eskom training sites for the training in KZN and the Freestate.</p>				
3	<p>Under the qty column do we leave it blank and just put in a rate per KM ect?</p> <table border="1" data-bbox="150 1400 799 1473"> <tr> <td data-bbox="150 1400 309 1473"></td> <td data-bbox="309 1400 480 1473">Sedan/LDV</td> <td data-bbox="480 1400 639 1473">Rate per km</td> <td data-bbox="639 1400 799 1473"></td> </tr> </table> <p>Kilometres will be claimed from the allocated Eskom home centre to the relevant site. Kilometres from the Suppliers office to the allocated Eskom home centre cannot be claimed</p>		Sedan/LDV	Rate per km		<p>Under the qty column do we leave it blank leave it blank – Yes leave it blank and just put in the rate per km</p>
	Sedan/LDV	Rate per km				
4	<p>What exactly is required for the training, will the trainees do practical themselves on all the different material that is tendered for?</p>	<p>Each successful tenderer shall be required to perform a full practical demonstration of the application of the following MV cable accessories:</p> <ol style="list-style-type: none"> 1. A Transition joint. 2. A type 4 termination; and 3. A Trifurcating joint. 				

