

- NOTE: CONTRACTOR TO ALLOW FOR TEMPORARY STORM WATER DRAINAGE FROM THE EXISTING OUTLETS DURING CONSTRUCTION.

—FINAL COMPACTED LEVEL AFTER
VIBRO COMPACTION.

INITIAL PLACEMENT LEVEL.
CONTRACTOR TO MAKE ALLOWANCE FOR
SETTLEMENT DUE TO VIBRO COMPACTION

▼2.885 m CDP

HYDRAULIC SUBGRADE
WITH A MINIMUM E VALUE
OF 50 MPa VIBRO COMPACTED
UP TO A HEIGHT OF 2.885m CDP

EXISTING

1:500

1:500

- ### STEP 3

- COMPLETE CAPPING BEAM.
- BACKFILL BEHIND CAPPING BEAM AND COMPACT CONVENTIONALLY.
- COMPLETE LAYERWORKS AND PAVEMENT.

— CONVENTIONAL COMPACTION OF FILL MATERIAL.

NEW COPELINE

EXISTING COPPELINE

1:500

