

 Eskom	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2031		

To whom it may concern	Date	22 July 2026
	Enquiries	Tebogo Seyama / Ngimphiwe Mathenjwa
	E-mail address	MolotsTM@eskom.co.za / MathenNG@eskom.co.za

Dear Sir/Madam

Request for Enquiry Number	E3048GXMPDUV
Description / Project Title	Design, Manufacture, Installation and Commissioning of the new Sulphuric Acid Bulk Tank at Duvha Power Station for a period of 10 months

Item	Questions	Answers	Clarity Published Dates
1.	Transmitters and C&I equipment: Will suppliers be expected to replace items on a like-for-like basis, or will they be required to upgrade to newer technology? Technology has advanced significantly over the years, and some of the original equipment is no longer available on the market.	It will be like-for-like basis as per the scope	22 July 2026
2.	Substation wiring: The scope does not appear to include the substation wiring. Will the wiring be refurbished as part of the project?	No, it is not part of the scope.	22 July 2026
3.	Battery backup: Is it expected that suppliers provide and install a battery backup solution in the event of a DCS failure (e.g. rectifiers and UPS systems)?	No, it is not required.	22 July 2026

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2031		

4.	Civil works: With regard to the pipes extending from the dump wall and underground pipelines, are suppliers expected to replace the entire pipe section and carry out new welding, or should they only cut out the damaged section and re-weld it in the same location?	The Suppliers are expected to quote as per the bill of quantities, the amount of work or pipe replacement will be determined after the inspection. The Bill of quantities have made provision for a full replacement as a worse case scenario. Please also note the pipe is a durapipe (PVC) not steel	22 July 2026
----	---	--	--------------

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30