

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 19 of 39

Annex A – Schedule A: Schedule of technical compliance

This must be completed by providing technical details of tendered equipment and Tenderer's statement of compliance or non-compliance. The Tenderers statement of compliance (Schedule B) must be supported by additional information of a concise reference to the relevant submitted documents (e.g., file number, section number, page number, paragraph number). A failure to support the clause with the relevant reference will result in non-compliance.

Table A.1: Schedule of technical compliance

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3	Requirements			
3.1	Material			
3.1.1	All metals brackets shall be of corrosion-resistant materials. (Stainless steel or hot-dipped galvanized.)	State Compliance & Provide Evidence		
3.1.2	Mounting hardware shall be stainless steel.	State Compliance & Provide Evidence		
3.2	Cable			
3.2.1	Cable: RG58 5 mm 50 Ω			
3.2.1.1	Military specification M-17.	State Compliance & Provide Evidence		
3.2.1.2	Solid Polyethylene Dielectric.	State Compliance & Provide Evidence		
3.2.1.3	Impedance: 50 $\Omega \pm 2 \Omega$.	State Compliance & Provide Evidence		
3.2.1.4	Attenuation: tenderer to state attenuation of frequency per metre.	State Compliance & Provide Evidence		
3.2.2	Cable: RG223 5.5 mm 50 Ω			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 20 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.2.2.1	Solid Polyethylene Dielectric.	State Compliance & Provide Evidence		
3.2.2.2	Impedance: $50 \Omega \pm 2 \Omega$.	State Compliance & Provide Evidence		
3.2.2.3	Attenuation: tenderer to state attenuation of frequency per metre.	State Compliance & Provide Evidence		
3.2.3	Cable: RG213 10 mm 50Ω braided			
3.2.3.1	Military specification M-17.	State Compliance & Provide Evidence		
3.2.3.2	Solid Polyethylene Dielectric.	State Compliance & Provide Evidence		
3.2.3.3	Impedance: $50 \Omega \pm 2 \Omega$.	State Compliance & Provide Evidence		
3.2.3.4	Attenuation: tenderer to state attenuation of frequency per metre.	State Compliance & Provide Evidence		
3.2.4	Cable: RG214 10.8 mm 50Ω			
3.2.4.1	Military specification M-17.	State Compliance & Provide Evidence		
3.2.4.2	Solid Polyethylene Dielectric.	State Compliance & Provide Evidence		
3.2.4.3	Impedance: $50 \Omega \pm 2 \Omega$.	State Compliance & Provide Evidence		
3.2.4.4	Attenuation: tenderer to state attenuation of frequency per metre.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 21 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.2.5	Cable: RG400 5 mm 50 Ω Teflon			
3.2.5.1	Double braided.	State Compliance & Provide Evidence		
3.2.5.2	Solid polyethylene dielectric.	State Compliance & Provide Evidence		
3.2.5.3	Impedance: 50 $\Omega \pm 2 \Omega$.	State Compliance & Provide Evidence		
3.2.5.4	Attenuation: tenderer to state attenuation of frequency per metre.	State Compliance & Provide Evidence		
3.2.6	Cable: LMR195 5 mm 50 Ω DB PE			
3.2.6.1	Times Microwave.	State Compliance & Provide Evidence		
3.2.7	Cable: LMR195 5 mm 50 Ω ultra			
3.2.7.1	Times Microwave.	State Compliance & Provide Evidence		
3.2.8	Cable: LMR240 6.1 mm 50 Ω			
3.2.8.1	Times Microwave.	State Compliance & Provide Evidence		
3.2.9	Cable: LMR240 ultra 6.1 mm 50 Ω			
3.2.9.1	Times Microwave.	State Compliance & Provide Evidence		
3.2.10	Cable: LMR400 10.2 mm 50 Ω			
3.2.10.1	Times Microwave.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 22 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.2.11	Cable: LMR400 10.2 ultra mm 50 Ω			
3.2.11.1	Times Microwave.	State Compliance & Provide Evidence		
3.2.12	Cable: 1/2" (EC4-50) Eupen 5128			
3.2.12.1	Eupen.	State Compliance & Provide Evidence		
3.2.13	Cable: CXEC5-50, 7/8" (EC5-50) Eupen 5228A			
3.2.13.1	Eupen.	State Compliance & Provide Evidence		
3.2.14	Cable: Coaxial 7/8"			
3.2.14.1	Shield/Outer conductor: Aluminium	State Compliance & Provide Evidence		
3.2.14.2	Centre conductor: Copper	State Compliance & Provide Evidence		
3.2.14.3	Dielectric: Foamed Polyethylene Impedance: 50 Ω	State Compliance & Provide Evidence		
3.2.14.4	Impedance: 50 Ω	State Compliance & Provide Evidence		
3.3	Boot			
3.3.1	Boot: strain relief LMR240			
3.3.1.1	Clamping dimensions: 6 mm (for LMR 240 cable).	State Compliance & Provide Evidence		
3.3.1.2	Colour: black.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 23 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.3.2	Boot: strain relief LMR240			
3.3.2.1	Clamping dimensions: 6 mm (for LMR 240 cable).	State Compliance & Provide Evidence		
3.3.2.2	Colour: red.	State Compliance & Provide Evidence		
3.3.3	Boot: strain relief for RG58/LMR 195			
3.3.3.1	Clamping dimensions: 5 mm (for RG58/LMR195 cable).	State Compliance & Provide Evidence		
3.3.3.2	Colour: Black.	State Compliance & Provide Evidence		
3.3.4	Boot: strain relief for RG214/LMR 400			
3.3.4.1	Clamping dimensions: 11 mm (for RG214/LMR400 cable).	State Compliance & Provide Evidence		
3.3.4.2	Colour: black.	State Compliance & Provide Evidence		
3.4	Tool			
3.4.1	Tool: cable prep 1/2"			
3.4.1.1	For SIMFix 1/2" connector and corrugated coax.	State Compliance & Provide Evidence		
3.4.2	Tool: cable prep 7/8"			
3.4.2.1	For SIMFix 1/2" connector and corrugated coax.	State Compliance & Provide Evidence		
3.4.3	Tool: cable stripping 10 mm			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 24 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.4.3.1	LMR 10 mm stripping tool.	State Compliance & Provide Evidence		
3.4.4	Tool kit: cable crimp metal			
3.4.4.1	HT 300K stripping tool in case with dies.	State Compliance & Provide Evidence		
3.4.5	Tool: Tensioner tool			
3.4.5.1	Tensioner tool for stainless steel cable ties.	State Compliance & Provide Evidence		
3.5	Connector			
3.5.1	Connector: BNC STR male crimp RG58/LMR195			
3.5.1.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.2	Connector: BNC STR male solder RG223			
3.5.2.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.3	Connector: BNC STR male crimp LMR240			
3.5.3.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.4	Connector: BNC STR male crimp LMR400			
3.5.4.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.5	Connector: N-male STR crimp RG58/LMR195			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 25 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.5.5.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.6	Connector: N-male STR crimp RG223/RG400			
3.5.6.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.7	Connector: N-male STR crimp RG213			
3.5.7.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.8	Connector: N-male STR solder RG213/RG214			
3.5.8.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.9	Connector: N-male STR crimp RG214			
3.5.9.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.10	Connector: N-male STR crimp LMR240			
3.5.10.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.11	Connector: N-male R/A crimp LMR240			
3.5.11.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.12	Connector: N-male STR crimp LMR400			
3.5.12.1	Telegartner/Suhner.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 26 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.5.13	Connector: N-male R/A crimp LMR400			
3.5.13.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.14	Connector: N-male STR 7/8" (EC5-50) IP68			
3.5.14.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.15	Connector: N-female STR crimp RG213			
3.5.15.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.16	Connector: N-female STR crimp RG214			
3.5.16.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.17	Connector: N-female STR crimp LMR400			
3.5.17.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.18	Connector: N-female STR 1/2" HF (EC450HF)			
3.5.18.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.19	Connector: N-female STR 7/8" (E5-50) IP68			
3.5.19.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.20	Connector: SMA-male STR crimp RG58/LMR195			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: **240-64013506**

Revision: **3**

Page: **27 of 39**

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.5.20.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.21	Connector: SMA-female STR crimp RG58/LMR195			
3.5.21.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.22	Connector: TNC-male STR crimp RG58/LMR195			
3.5.22.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.23	Connector: TNC-male STR solder RG58/LMR195			
3.5.23.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.24	Connector: UHF-male STR crimp RG58/LMR195			
3.5.24.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.25	Connector: TNC-male STR crimp LMR400			
3.5.25.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.5.26	Connector: bulkhead N type			
3.5.26.1	Telegartner/Suhner N type bulkhead.	State Compliance & Provide Evidence		
3.6	Adaptor			
3.6.1	Adaptor: BNC-female to SMA-female			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 28 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.6.1.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.6.2	Adaptor: BNC-male to UHF-female			
3.6.2.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.6.3	Adaptor: BNC-male to N-female			
3.6.3.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.6.4	Adaptor: BNC-female to N-male			
3.6.4.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.6.5	Adaptor: N-female to N-female			
3.6.5.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.6.6	Adaptor: R/A N-male to N-female			
3.6.6.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.6.7	Adaptor: R/A TNC-male to TNC-female			
3.6.7.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.6.8	Adaptor: TNC-male to BNC-female			
3.6.8.1	Telegartner/Suhner.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 29 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.6.9	Adaptor: TNC-male to N-female			
3.6.9.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.7	Flylead			
3.7.1	Flylead: BNC male to N male			
3.7.1.1	RG58 cable 1 m in length.	State Compliance & Provide Evidence		
3.7.2	Flylead: BNC male - N male			
3.7.2.1	LMR195 cable 1 m in length.	State Compliance & Provide Evidence		
3.7.3	Flylead: N female bulkhead – N male			
3.7.3.1	LMR195 cable 1 m in length.	State Compliance & Provide Evidence		
3.7.4	Flylead: N female bulkhead – SMA male			
3.7.4.1	LMR195 cable 1 m in length.	State Compliance & Provide Evidence		
3.7.5	Flylead: N male – TNC male			
3.7.5.1	LMR195DB ultra cable 1 m in length.	State Compliance & Provide Evidence		
3.7.6	Flylead: N male – N male			
3.7.6.1	LMR195DB ultra cable 5 m in length.	State Compliance & Provide Evidence		
3.7.7	Flylead: N female– N male			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 30 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.7.7.1	LMR400 ultra cable 5 m in length.	State Compliance & Provide Evidence		
3.7.7.2	LMR400 ultra cable 2,5 m in length.	State Compliance & Provide Evidence		
3.7.8	Flylead: N male – N male			
3.7.8.1	LMR400 ultra cable 5 m in length.	State Compliance & Provide Evidence		
3.8	Clamp			
3.8.1	Clamp: Cumfy dual cable and clip			
3.8.1.1	Dimensions: 2 × 7 mm diameter.	State Compliance & Provide Evidence		
3.8.2	Clamp: Cumfy single cable and clip			
3.8.2.1	Dimensions: 1 × 13 mm diameter.	State Compliance & Provide Evidence		
3.8.3	Clamp: Cumfy dual RG8 and clip			
3.8.3.1	Dimensions: 2 × 10 mm diameter.	State Compliance & Provide Evidence		
3.8.4	Clamp: Cumfy G-clamp dual assy			
3.8.4.1	Complete G Clamp with 2 × 6 mm diameter.	State Compliance & Provide Evidence		
3.8.5	Clamp: Cumfy 3 way + clip			
3.8.5.1	Complete clamp with 3 × 7/8" and locking clip.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 31 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.8.6	Clamp: Cumfy G-clamp single assy			
3.8.6.1	Complete G-clamp with 1 × 10 mm diameter.	State Compliance & Provide Evidence		
3.8.7	Clamp: Cumfy G-clamp dual assy			
3.8.7.1	Complete G-clamp with 2 × 10 mm diameter.	State Compliance & Provide Evidence		
3.8.8	Clamp: Cumfy G-clamp triple assy			
3.8.8.1	Complete G-clamp with 3 × 10 mm diameter.	State Compliance & Provide Evidence		
3.8.9	Clamp: Cumfy G-clamp quad assy			
3.8.9.1	Complete G-clamp with 4 × 10 mm diameter.	State Compliance & Provide Evidence		
3.8.10	Clamp: Cumfy G-clamp single assy			
3.8.10.1	Complete G-clamp with 1 × 16 mm diameter.	State Compliance & Provide Evidence		
3.8.11	Clamp: Cumfy G-clamp dual assy			
3.8.11.1	Complete G-clamp with 2 × 16 mm diameter.	State Compliance & Provide Evidence		
3.8.12	Clamp: Cumfy G-clamp triple assy			
3.8.12.1	Complete G-clamp with 3 × 16 mm diameter.	State Compliance & Provide Evidence		
3.8.13	Clamp: Cumfy G-clamp quad assy			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 32 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.8.13.1	Complete G-clamp with 4 × 16 mm diameter.	State Compliance & Provide Evidence		
3.8.14	Clamp: Cumfy G-clamp single assy			
3.8.14.1	Complete G-clamp with 1 × 7/8" diameter.	State Compliance & Provide Evidence		
3.8.15	Clamp: Cumfy G-clamp dual assy			
3.8.15.1	Complete G-clamp with 2 × 7/8" diameter.	State Compliance & Provide Evidence		
3.8.16	Clamp: Cumfy G-clamp triple assy			
3.8.16.1	Complete G-clamp with 3 × 7/8" diameter.	State Compliance & Provide Evidence		
3.8.17	Clamp: Cumfy G-clamp quad assy			
3.8.17.1	Complete G-clamp with 4 × 7/8" diameter.	State Compliance & Provide Evidence		
3.8.18	Clamp: Polyprop			
3.8.18.1	1 × 1/2".	State Compliance & Provide Evidence		
3.8.19	Clamp: Polyprop			
3.8.19.1	1 × 7/8".	State Compliance & Provide Evidence		
3.8.20	Clamp: Polyprop			
3.8.20.1	1 × 10 mm.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 33 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.8.21	Clamp: grounding kit 10 mm coax cable			
3.8.21.1	16 mm black GP cable.	State Compliance & Provide Evidence		
3.8.21.2	Fixing clamps and necessary hardware (lugs, etc.).	State Compliance & Provide Evidence		
3.8.22	Clamp: grounding kit 1/2" coax cable			
3.8.22.1	16 mm black GP cable.	State Compliance & Provide Evidence		
3.8.22.2	Fixing clamps and necessary hardware (lugs, etc.).	State Compliance & Provide Evidence		
3.8.23	Clamp: grounding 1/2"			
3.8.23.1	Grounding kit with parallel outlet.	State Compliance & Provide Evidence		
3.8.23.2	Fixing clamps and necessary hardware (lugs, etc.).	State Compliance & Provide Evidence		
3.8.23.3	Weatherproofing kit.	State Compliance & Provide Evidence		
3.8.24	Clamp: grounding 7/8"			
3.8.24.1	Grounding kit with parallel outlet.	State Compliance & Provide Evidence		
3.8.24.2	Fixing clamps and necessary hardware (lugs, etc.).	State Compliance & Provide Evidence		
3.8.24.3	Weatherproofing kit	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 34 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.8.25	Clamp: BAND-IT strap 12 mm 30 m			
3.8.25.1	Stainless steel band (30 m x 12 mm).	State Compliance & Provide Evidence		
3.8.26	Clamp: BAND-IT buckle 12 mm			
3.8.26.1	12 mm Stainless steel.	State Compliance & Provide Evidence		
3.8.27	Clamp: Stainless steel cable ties 7.9 mm			
3.8.27.1	Stainless steel cable ties 259mm X 7.9mm packet.	State Compliance & Provide Evidence		
3.8.28	Clamp: 7/8" 1 way tandem with G-clamp			
3.8.28.1	Tandem (two 7/8" cables) clamp complete with mounting hardware.	State Compliance & Provide Evidence		
3.8.29	Clamp: 7/8" 2 way tandem with G-clamp			
3.8.29.1	Dual tandem (four 7/8" cables) clamp complete with mounting hardware.	State Compliance & Provide Evidence		
3.8.30	Clamp: 7/8" 3 way tandem with G-clamp			
3.8.30.1	Triple tandem (six 7/8" cables) clamp complete with mounting hardware.	State Compliance & Provide Evidence		
3.8.31	Clamp: cable two-way 32 mm			
3.8.31.1	Two-way clamp for BC400-9 cable 32 mm.	State Compliance & Provide Evidence		
3.8.32	Clamp: cable one-way 32 mm			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 35 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.8.32.1	One-way clamp for BC400-9 cable 32 mm.	State Compliance & Provide Evidence		
3.9	Protector			
3.9.1	Protector: surge filter 1.7 GHz to 2.3 GHz bulkhead N-female\N-female			
3.9.1.1	PolyPhaser.	State Compliance & Provide Evidence		
3.9.2	Protector: surge suppressor DC-2 GHz N-female bulkhead mount 90 V			
3.9.2.1	Telegartner/Suhner.	State Compliance & Provide Evidence		
3.9.3	Protector: 125 MHz to 1 000 MHz N-female			
3.9.3.1	PolyPhaser C2.	State Compliance & Provide Evidence		
3.9.4	Protector: data line surge bulkhead RJ45			
3.9.4.1	IP 67.	State Compliance & Provide Evidence		
3.9.4.2	10/100 Mbps PoE. Gigabit Ethernet and Gigabit PoE.	State Compliance & Provide Evidence		
3.9.5	Protector: surge AC3 phase kit			
3.9.5.1	UAC 240 V/ UAC 415 V three-phase.	State Compliance & Provide Evidence		
3.9.5.2	IP 67 enclosure.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 36 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.9.5.3	Class I and II IEC surge suppressor with remote monitoring.	State Compliance & Provide Evidence		
3.9.6	Protector: surge AC single phase			
3.9.6.1	UAC 240 V single phase.	State Compliance & Provide Evidence		
3.9.6.2	IP 67 enclosure.	State Compliance & Provide Evidence		
3.9.6.3	Class I and II IEC surge suppressor with remote monitoring.	State Compliance & Provide Evidence		
3.9.7	Protector: solar panel 120 V			
3.9.7.1	UAC 120 V single -phase.	State Compliance & Provide Evidence		
3.9.7.2	DIN rail mounting.	State Compliance & Provide Evidence		
3.9.7.3	Max. discharge current: 20 kA at 8/20 μ s.	State Compliance & Provide Evidence		
3.9.8	Protector: component AC surge protector			
3.9.8.1	Hybrid Silicon diode with combined Metal Oxide Varistor (MOV).	State Compliance & Provide Evidence		
3.9.8.2	Class I and II IEC surge suppressor with remote monitoring.	State Compliance & Provide Evidence		
3.9.9	Protector: outdoor 60 V PoE surge protector			
3.9.9.1	Impedance: 85 Ω to 115 Ω.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 37 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.9.9.2	Standards: GR1089, NEC800.100, NEC830.100, Restriction of Hazardous Substances (RoHS).	State Compliance & Provide Evidence		
3.9.10	Protector: 48 VDC DIN rail SADS			
3.9.10.1	Hybrid Silicon diode with combined MOV.	State Compliance & Provide Evidence		
3.9.10.2	Class I and II IEC surge suppressor with remote monitoring.	State Compliance & Provide Evidence		
3.9.11	Protector: AC common mode			
3.9.11.1	DIN rail mounting.	State Compliance & Provide Evidence		
3.9.11.2	UAC 230 V.	State Compliance & Provide Evidence		
3.9.11.3	RoHS compliant.	State Compliance & Provide Evidence		
3.10	Other			
3.10.1	Tape: self-vulcanizing Scotch 23			
3.10.1.1	0.76 mm thickness black.	State Compliance & Provide Evidence		
3.10.1.2	3M Scotch™23.	State Compliance & Provide Evidence		
3.10.2	Tape: insulation black 3M			
3.10.2.1	Vinyl electrical tape.	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 38 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.10.2.2	10 m × 14 mm.	State Compliance & Provide Evidence		
3.10.3	Tape: insulation black 3M			
3.10.3.1	Vinyl electrical tape.	State Compliance & Provide Evidence		
3.10.3.2	10 m × 48 mm.	State Compliance & Provide Evidence		
3.10.4	Tape: Butyl			
3.10.4.1	Highly adhesive, double-sided, self-bonding sealing tape.	State Compliance & Provide Evidence		
3.10.4.2	0.5 m × 48 mm.	State Compliance & Provide Evidence		
3.10.5	Saddle: 5 mm BH500			
3.10.5.1	BH500 Polypropylene.	State Compliance & Provide Evidence		
3.10.5.2	Complete with high tensile pin.	State Compliance & Provide Evidence		
3.10.6	Crimper: crimp for L910			
3.10.6.1	Ratchet type.	State Compliance & Provide Evidence		
3.10.6.2	Replicable jaws for L910 cable.	State Compliance & Provide Evidence		
3.10.7	Bundle: 9 × coax LMR 400			

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user
to ensure it is in line with the authorized version on the WEB.

Document Classification: Controlled Disclosure

TELECOMMUNICATIONS RF CABLES AND CONNECTORS

Unique Identifier: 240-64013506

Revision: 3

Page: 39 of 39

Spec. clause number	Description	Schedule A: Eskom's minimum technical requirements	Schedule B: Supplier's statements of compliance	Supplier's Reference/Comment (Supporting evidence)
3.10.7.1	LMR400 × 9 with outside sheath.	State Compliance & Provide Evidence		
3.10.8	Seal: boot weather			
3.10.8.1	Breakout kit with weather seal for bundled coaxial for LMR400-9.	State Compliance & Provide Evidence		
3.10.9	Kit: grounding kit BC400-9			
3.10.9.1	Grounding kit for BC400-9 bundled coaxial.	State Compliance & Provide Evidence		
3.10.9.2	Fixing clamps and necessary hardware (lugs, etc.).	State Compliance & Provide Evidence		
3.10.10	Bundle: 4 × LMR400			
3.10.10.1	LMR400 × 4 with outside sheath.	State Compliance & Provide Evidence		
3.10.11	Shroud: BC400-4, cold shrink			
3.10.11.1	Breakout kit with weather seal for BC400-4 bundled coaxial.	State Compliance & Provide Evidence		
3.10.12	Kit: grounding kit BC400-4			
3.10.12.1	Grounding kit for BC400-4 bundled coaxial.	State Compliance & Provide Evidence		
3.10.12.2	Fixing clamps and necessary hardware (lugs, etc.).	State Compliance & Provide Evidence		

ESKOM COPYRIGHT PROTECTED

When downloaded from the WEB, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the WEB.