



FRONT ELEVATION



TOP ELEVATION




NOTES:

1. ALL STRUCTURAL STEEL SHALL BE MANUFACTURED WITH GRADE S355JR STEEL TO SANS 1431 AND HOT DIP GALVANISED TO SANS 121.
2. BOLTS SHALL BE GRADE 4.6 ORDINARY BOLTS, NUTS AND WASHERS AND SHALL BE HOT DIP GALVANIZED TO SANS 121
3. FOR DETAIL OF CROSSARM REFER TO D-DT-7802
4. SPECIFIC HOLE SIZES TO BE OBTAINED AFTER GALVANISING.

5

F

|  |                              |     |       |          |
|--|------------------------------|-----|-------|----------|
|  <b>Eskom</b><br>Distribution | FREE STATE OPERATING UNIT    |     |       |          |
|  | SHACKLE STRAP FOR            |     |       |          |
|  | ANGLE STRAIN CROSSARM DETAIL |     |       |          |
|  | (TYPE 7808 & 7802)           |     |       |          |
| AUTH: P VD HEEVER  | FOR TENDER PURPOSES ONLY     |     |       |          |
| DATE: 08/07/2014   | D-FS-17744                   | SET | SHEET | REVISION |
| CHKD: H PRETORIUS  |                              | 1   | 1     | Ø        |
| DATE: 08/07/2014   |                              |     |       |          |
| DRAWN: H PRETORIUS   |                              |     |       |          |
| DATE: 08/07/2014   |                              |     |       |          |