

	Tender Questions and Answers	Document Identifier	559-222407715	Rev	1
		Effective Date	July 2024		
		Review Date	July 2027		

To whom it may concern	Date	<u>31 October 2025</u>
	Enquiries	<u>Providence Sedupane</u>
	E-mail address	<u>sedupap@ntcsa.co.za</u>

Dear Sir/Madam

Request for Enquiry Number	E1665NTCSAMWP
Description / Project Title	THE DEVELOPMENT, MANUFACTURING, TESTING, TRAINING, SUPPLY, DELIVERY, OFF-LOADING AND INSTALLATION/SITE ERECTION OF PHASE 6 PHASOR MEASUREMENT UNIT SCHEMES FOR USE IN NTCSA, ON AN “AS AND WHEN REQUIRED” BASIS OVER A PERIOD OF FIVE (5) YEARS WITH AN OPTION TO EXTEND WITH ANOTHER FIVE (5) YEARS.
Tender Questions Closing Date	10 working days before the deadline for tender submission. This includes the requests for extension for tender closing date.

Clause	Questions	Answers	Clarity Published Dates
Technical-Proconics	With regards to the sPDC that is integrated into the scheme, are we allowed to deviate and use the sPDC function on the relay?	“The sPDC may be integrated into the Supplier's proposed solution as they see fit, however, all technical requirements for the sPDC, specifically section 3.5.2 & 3.5.3 in 240-185000265: Specification for Phase 6 Phasor Measurement Unit Schemes for NTCSA, must still be met.”	2025/10/31

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of NTCSA SOC Ltd, © copyright NTCSA SOC Ltd, Reg No 2021/539129/30