

UPS						
ROW	POS	FUNCTION	TYPE	CORE	CABLE	SHEET
A	—	UPS LCD DISPLAY, CONTROL PANEL & LED INDICATORS	MODULAR UPS SYSTEM	—	—	P013
B	—	UPS POWER MODULE	20KVA/16KW MODULE	—	—	P013
C	—	EMPTY SLOT	20KVA/16KW MODULE	—	—	—
D	—	EMPTY SLOT	20KVA/16KW MODULE	—	—	—
E	—	EMPTY SLOT	20KVA/16KW MODULE	—	—	—
F	—	I/O CIRCUIT BREAKER SWITCH	MODULAR UPS SYSTEM	—	—	P013
G	—	I/O CIRCUIT BREAKER SWITCH	MODULAR UPS SYSTEM	—	—	P013
H	—	I/O CIRCUIT BREAKER SWITCH	MODULAR UPS SYSTEM	—	—	P013
J	—	INTERFACE (REAR)	MODULAR UPS SYSTEM	—	—	P013
K	—	I/O CIRCUIT BREAKER TERMINALS (REAR)	MODULAR UPS SYSTEM	—	—	P013

THALES 										DRAWN _____ LC _____ DATE 8/14		Producer CHECKED  Date 16/03/2018		Internal Checker REVIEWED _____ Date _____		External Checker CHECKED _____ Date _____		Technical Advisor REVIEWED _____ Date _____		PRASA REGION APPROVED _____ Date _____		PRASA HQ APPROVED _____ Date _____		DRAWN _____ DATE _____		SCALE _____ TRACED _____		NTS _____		SIMONSTOWN (ST)				CSE _____		1C _____		UPS ANALYSIS	
WCRP TMC SIG BMD 1.2 DWG 00008		Amend _____ No. _____ 0		Sheet _____ P015																																			