

 Eskom	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

To whom it may concern	Date	<u>06/10/2026</u>
	Enquiries	<u>Neo Sithole</u>
	E-mail address	<u>Sitholn7@eskom.co.za</u>

Dear Sir/Madam

Request for Enquiry Number	<u>E3447GXMPGRO</u>
Description / Project Title	SERVICE, REPAIR AND REFURBISHMENT OF MILLING PLANT GEARBOX INPUT SHAFT BEARING HOUSING FOR UNIT 1 TO 3 ON AS AND WHEN REQUIRED BASIS AT GROOTVLEI POWER STATION
Tender Questions Closing Date	<u>09 October 2026</u>

Item	Questions	Answers	Clarity Published Dates
1.	What would be the Preferred Bearing types?	Suppliers may quote on any of the following bearing manufacturers: FAG, Timken, or SKF	
2.	Would you accept Metal Spray on Bearing Journals?	Yes, suppliers may undertake metal spraying and/or sleeving of bearing journals where required.	
3.	Can Reverse Engineering be permitted?	Reverse engineering will not be necessary. We have existing spare components which will be removed from site by the appointed supplier for repair and refurbishment.	
4.	Kindly provide us with Serial Numbers on Gearboxes?	We do not have serial numbers available for gearboxes. However, the suppliers may quote based on the following gearbox brands, as these are the input cartridges that will be worked on: • David Brown • Hitachi • Premium	

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

5.	Are you only looking for Contract Orders and or Three Purchase Orders (POs) for reference purpose?	Either three (3) Purchase Orders (POs) or Contract Orders will be accepted as reference projects for completed gearbox or input cartridge work of a similar nature.	
6.	Please see uploaded NEC documents	The document is available in the NEC folder on the Eskom Tender Bulletin and has also been published on the National Treasury eTender Portal.	
7.	Please see uploaded Input bearing housing spares list	The document is available in the technical folder on the Eskom Tender Bulletin and has also been published on the National Treasury eTender Portal.	
8.	Please see uploaded GVL 0697 documents	The document is available in the technical folder on the Eskom Tender Bulletin and has also been published on the National Treasury eTender Portal.	

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30