

CLARIFICATION NR 1 (05.12.2022)

TENDER MPKRI10523GX (closing 13.12.2022)

	Question	Answer
1	<p>In the NEC scope of works it states that the below items to be replaced - will Eskom supply or is the Contractor expected to supply and replace what is mentioned in the scope of work?</p> <ul style="list-style-type: none"> • Back spray nozzels and associated valves • Damaged liners inside the hopper • (16 off) peep doors size 450mm x 250mm high with new doors • Damaged inner ash hopper doors including all the door seals • Swivel bolts and nuts with new units • New supports every 850mm. (please note the current supports is every 1700mm) • External door boxes, including hinges and closing hatches (plan for 3) • Ash hopper inner doors seals, retaining pins and hydraulic cylinders move the point to hopper internal section • sluiceway spray nozzles and associated valves • Hopper grizzly-bars in front of the ash hoppers • Ash sump agitating nozzles and pipeline inside the sumps • Ash hopper door guides such that they can operate without restrictions or getting stuck • Sump level indicators and peer balls pipeline 	Everything that is not in the price list is a free issue from Eskom
2	If to supplying the above mentioned items where do we price for them on the price list?	Everything that is not in the price list is a free issue from Eskom
3	Spares for the refurbishment i.e. pumps, valves etc - how are they to be prized for as there are no details on quantities or is ESKOM providing these? Also applies to nozzels, gaskets, bolts and nuts – are they being freely issued?	What is not on the price list is issued as a free issue
4	The Price List, Section 104 Equipment for consumables. Does this mean equipment per outage or consumables per outage	It is consumables and tools per outage