



CLEANSING AND SOLID WASTE UNIT

17 Electron Road, Springfield
✉ P. O. Box 1038, Durban, 4000
☎ Tel: 031 311 1111
Fax: 031 263 1119
Helpline: 031 311 8804
Website: www.durban.org.za



ALL TENDERERS

Dear Sirs / Madams


CONTRACT 31854-6W: BUFFELSDRAAI LANDFILL: CONSTRUCTION OF CELL 3 AND ANCILARY WORKS.

QUERIES AND ANSWERS

This is to provide answers to the queries that were obtained from some of the tenderers regarding the tender document in respect of the compulsory clarification meeting that was held on the 7th of July 2025.

Kindly take note of the correction as outlined on the next page.

The details of this addendum shall form part of the Record of Addenda to the tender document.


24.07.25
Mfundo Nhlengethwa
Civil Eng. Technologist



BETTER WITHOUT LITTER

Queries Received :

TGC Response : 23.07.2025

1	Electronic Leak Location Testing is mentioned in the document but does not appear in the schedule of quantities. The type and method of testing is also not specified. Detail for this is requested.	Item 3.11.3 has been added to the schedule of quantities under the addendum which covers the Electronic Leak Location testing. The method is non-destructive dipole testing of the geomembrane liner in accordance with ASTM D7007.
2	An electronic copy (in Excel format) of the Schedule of Quantities was requested	This was sent out to all attendees of the site clarification meeting
3	Request for a clearer copy of page Annexure C – Local Content Declaration.	This was sent out to all attendees of the site clarification meeting
4	The allowance for the 5% for the CIDB BUILD programme i.e. where must the allowance be made within the tender BoQ and any further clarity that could be provided regarding the programme. We have been through the CIDB website, the referred to guides and government gazettes, but are still uncertain on how the implementation of the programme is to occur.	The 5% will be similar to the CPG requirement as it is 5% of the contract value that will need to be subcontracted to targeted enterprises in accordance with the CIDB BUILD Requirement. The subcontracted CPG work can form part of this 5% target. Item 1.3.9 in the bill of quantities allows for mentoring of CPG contractors. This allowance will also incorporate mentoring, development and upskilling of targeted groups as per the programme.