

Technical Evaluation Criteria for SSC Chain supply

Gatekeepers

- ISO 9001 accreditation.
- Compliance with technical specification.
- Match sets must be marked and packed in different crates.

Supply of SSC Chains

No	Weight %	Qualitative Technical Criteria Description	Evaluation Scoring Breakdown			
			0	2	4	5
1	40	Proof of previous Purchase Orders for the supply of SSC chains to Lethabo power station.	Not Provided	Proof of 2 orders	Proof of 4 orders	Proof of 6 orders
2	30	CHAIN, POWER TRANSMISSION: PITCH: 108 MM; MATERIAL: STL; LENGTH: 83 M; SPECIFICATION: DIN22252-2-2; TYPE WING; 30MM X 108MM ENDLESS; UTS 1400-1500MPA; HARDENING 47RHC THROUGHOUT	Not Provided	0	0	Comply to all specifications
3	20	<ul style="list-style-type: none">• Material analysis certificates to be provided.• Break tests & tensile strength certificates to be provided.• Hardness certificates to be provided	Not Provided	1 Certificate	2 Certificates	3 Certificates
4	10	Confirmation letter that an Eskom representative can attend an inspection of the Chains before accepting delivery to site	Not Provided			

Any tenderer that does not meet the gatekeepers or obtains a score below 75% will be deemed unacceptable.