

ADDENDUM 3

Date: 25 August 2025
Ref: E1494DXKZNOU Addendum 3
Enquiries: Dawn Geeson
Tel: 031 710 5325
Email: geesond@eskom.co.za

To whom it may concern

RE: E1494DXKZNOU – The design, manufacture testing and supply of estimated quantities of Polymer Distribution Class, Non-Linear Metal-Oxide Neutral Surge Arresters on an “as and when” required basis for Distribution Division for a period of five (05) years.

The following changes have been effected to the tender enquiry E1494DXKZNOU:

The Technical Evaluation Criteria (TEC) is amended as follows as the neutral surge arrester is not always energized, unlike distribution-class and station-class surge arresters that are constantly energized as they are installed between a live phase and earth.

The amendments are as follows:

- Removal of sections 10.2 Pollution Performance Curves and 10.3 Material Fingerprint.
- Section 10.1 1000-hour Salt Fog Test will now refer to the Weather Ageing Test in accordance with IEC 60099-4, clause 10.8.17, and will carry a weighting of 20% (previously set at 10%).
- The total score remains at 100%, with no other changes made to the functional evaluation.

No late tenders will be accepted.
The tender closes on 11 September 2025.



Thandi Xaba
Procurement Manager
KZN Operating Unit