

Site: Cambridge (EL)

Date: 06-06-2025

[illegible]

Tender Clarification Query Shee

[illegible]

t – Cambridge

Response: Transnet

Yes

As per the site briefing , it was stated that Transnet does not have detailed drawings available of these systems , hence the plants were made available to do measurements , etc

As per the above , you can specify whatever size works with the system you are designing

If not required as part of the treatment process then do not supply the tank , it would depend on the oil removal process you would use.

Yes , both	
------------	--

There is power on the current DB Boards and we expect that power will still be drawn from here, if there other DB boards planned as part of the new system, the length will be based on where you would like this placed

We have security on site , but as Per NEC , sceuring of site camp , materials on site , etc remains the responsibility of the bidder.

No , a new system is to be installed

[illegible]

[illegible]