



NOTES

- 1 . Relays to be similar to the VAA 21 SPEC 288-05 . No flags required .
- 2 . Coils - resistance 51 ohms
- 3 . Operating voltage - 12 VOLTS D.C. .
- 4 . Contact current carrying capacity - 10 amps .
- 5 . Case size 1/4 N
- 6 . Number - refer to terminals on reverse side of relay

|                                   |              |   |                                 |      |       |
|-----------------------------------|--------------|---|---------------------------------|------|-------|
| DRAWN                             | A.J.R.W.     |   |                                 |      |       |
| DATE                              | 31/05/2004   |   |                                 |      |       |
| TRACED                            |              | REFERENCE DRAWINGS:   | REVISIONS:                      | BY:  | DATE: |
| CHIEF DRAUGHTSMAN                 |              | <b>ETHEKWINI ELECTRICITY</b><br><b>TERMINAL ALLOCATION</b><br><b>INTERPOSING RELAYS</b> |                                 |      |       |
| PLANNING OFFICER                  |              |   |                                 |      |       |
| PROTECTION ENGINEER               |              |   |                                 |      |       |
| PLAN/PROJ. ENGINEER               |              |   |                                 |      |       |
| PLAN/PROJ. MANAGER                |              |   |                                 |      |       |
| APPROVED<br>A.J. DOLD<br>DIRECTOR | TRANSMISSION | SCALE:<br><b>N.T.S.</b>   | DRAWING NUMBER:<br><b>TD 13</b> | REV: |       |