


SPEC SHEET

SAP MATERIAL No.:	0402243								
SHORT DESCRIPTION:	CT+VT 6.6kV-110V B 3VT+3CT I/LD D2118								
TECH. DESCRIPTION: CT + VT METERING UNIT * 6.6kV * 110V * 50VA * TYPE A * OIL FILLED * POLE MOUNTED * SUPPLIED WITH : 3 x VT WITH RATIO 6600-110V 50VA PER PHASE CLASS 0.2, 3 x CT 200/1A MULTI-RATIO 50-100/1A CLASS 0.5 AND 150-200/1A CLASS 0.2 BURDEN 7.5VA STC 12kA FOR 1 SECOND, 6 x 11kV OUTDOOR BUSHINGS * USED FOR INLAND APPLICATIONS * ESKOM DRAWING No. D-DT-2118 *									
SAP MATERIAL No.:	0597272								
SHORT DESCRIPTION:	TRFR, INSTR: C; CT+VT 3VT+3CT ILND								
TECH. DESCRIPTION: TRANSFORMER, INSTRUMENT: TYPE: C; CT+VT 3VT+3CT ILND; CURRENT: RATIOS: 100/1; 200/1; 300/1; 400/1; POTENTIAL: 6.6KV/110V; CT AND VT METERING UNIT; 6.6KV TO 110V; 25VA; TYPE C; OIL FILLED; POLE MOUNTED; SUPPLIED WITH: 3 X VT WITH RATIO 6600-110V 25VA PER PHASE CLASS 0.2; 3 X CT 400/1 MULTI-RATIO 100/1; 200/1; 300/1; 400/1 CLASS 0.2S BURDEN 5VA STC 20KA FOR 1 SECOND; 6 X 11KV OUTDOOR BUSHINGS; USED FOR INLAND APPLICATIONS; ESKOM DRAWING No. D-DT-2118 *									
ITEM	:- CT + VT 3 PHASE TYPE								
MATERIAL SPECIFICATION	:-								
CORROSION SPECIFICATION	:- 240-756055504								
STANDARD SPECIFICATION	:-								
ESKOM SPECIFICATION	:- 240-56065032								
TEST & CERTIFICATION REQUIREMENTS :- 240-56065032									
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No		
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS									
1	SAP 0008956 CORRECTED TO 0402243 AND CT/VT METERING UNIT TYPE C ADDED			P.A.T.	SIBONGILE MAPHOSA		P.A.T.		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE		
AUTH:	R. THERON	DATE:	12.12.2002	SCALE NTS	 D-DT-2118		SAP No: 0402243 0597272		
CHKD:	R. THERON	DATE:	12.12.2002	CAD REF: SERIES 2000			SET	SHEET	REV
DRAWN:	P.A. VERMAAK	DATE:	30.09.2002	FILE No: 2118			1	1	1